

COMPRESSED GAS CYLINDER SAFETY

Violations of any of the requirements listed below may result in enforcement action by Alameda County Environmental Health:

- ✓ **ALL CYLINDERS MUST BE SECURED to prevent falling due to contact, vibration or seismic activity.**
(California Fire Code, Art. 7401.6.4)
- ✓ **SAFETY CAPS MUST BE IN PLACE except when cylinders are in use. During any period of non-use, remove the regulators and replace the safety caps.**
(California Fire Code, Art. 7401.7.2)
- ✓ **FLAMMABLE and OXIDIZING GASES MUST BE SEPARATED by a distance of not less than 20 feet, or by an approved noncombustible partition.** (California Fire Code, Art. 8001.11.8)
- ✓ **IDENTIFICATION: cylinders must be labeled showing contents, and the labels must be visible from any direction of approach. Piping systems must have an arrow indicating direction of flow and be marked every 20 feet and at wall, floor or ceiling penetrations.**
(California Fire Code, Art. 7401.5)

**KEEP THIS AREA NEAT AND
ORDERLY AT ALL TIMES**