



COUNTY OF ALAMEDA

ADDENDUM No. 2

to

Project No. 17028

for

SRJ Boiler Upgrade

Specification Clarification/Modification and Recap of the Bidders Conferences
Held on 7/9/2018

This County of Alameda, General Services Agency (GSA), RFP/Q Addendum has been electronically issued to potential bidders via e-mail. E-mail addresses used are those in the County's Small Local Emerging Business (SLEB) Vendor Database or from other sources. If you have registered or are certified as a SLEB, please ensure that the complete and accurate e-mail address is noted and kept updated in the SLEB Vendor Database. This RFP/Q Addendum will also be posted on the GSA Contracting Opportunities website located at http://www.acgov.org/gsa/purchasing/bid_content/ContractOpportunities.jsp.



The following Sections have been modified to read as shown below. Changes made to the original RFP document are in **bold** print and **highlighted**, and deletions made have a ~~strike through~~.

Item 1

Specifications Division 0: DOCUMENT 00 11 19 Request for Proposals:

SECTION 4: DUE DATE AND RECEIPT OF PROPOSALS.

Sealed Proposals must be submitted to the County – General Services Agency at the address in Paragraph 4.4. below no later than 2:00 P.M. on the following dates:

1.9.1.1 Phase I: Qualifications were due Thursday, May 10, 2018.

1.9.1.2 Phase II: Proposals shall be due, on ~~August 7, 2018~~ **August 22, 2018**.

Item 2

Specifications Division 0: DOCUMENT 01 11 13 Work Covered by Contract Documents:

SECTION 1.3: WORK COVERED BY CONTRACT DOCUMENTS

- 1.3.3 Design Builder will engineer, procure, and install ~~five~~ **eight** new Lochinvar (Model PBN5002-M9) boilers with Cupro-Nickel heat exchangers to replace four condensing boilers located in the main boiler plant room at 5325 Broder Boulevard, Dublin. **A total of two 20MMBtu plants will be installed back to back. One plant will be fully redundant. Plants will be operated in lead-standby configuration.** Boiler primary pumps shall be interlocked with the boiler's fan controls to maintain manufacturer's specifications for performance and efficiency. The new boilers shall be installed on the existing **and or an extended** housekeeping pad. Heating hot water plant scope shall include, but is not limited, to the following: