



**PROJECT # CPP21C201180000**  
**ACSO Tactical Tower Project**  
**Addendum 3**  
**MANDATORY PRE-BID SITE MEETING ATTENDEES**

**MANDATORY BID WALK**  
**Held on September 1st, 2021 @ 10:00 a.m/p.m.**  
**@5301 Madigan Road Firearms Training Room #2**

*Blank fields below indicate no information provided*

Company Name	Contact	Phone	E-mail	SLEB	Certif. SLEB	Local	MBE	WBE	MWBE	Prime	Sub-Cont	Type
Roebbelen Contracting, Inc.	Kevin Saenz	916.939.4000	<a href="mailto:estimating@robbelen.com/">estimating@robbelen.com/</a> KevinS@robbelen.com							X		
California Plus Engineering Inc	Ali Farzan	408-913-3226	bid@cpeinc.us/ afarzan@cpeinc.us							X		
VNH Builders	Bruno Vieira	415-629-9005	bruno.vieira@vnbuilders.com				X			X		
Castillo Plumbing, Inc.	Enedino Neto	415.670.0661	office@castilloplumbinginc.com/ jose.castillo@castilloplumbinginc.com				X			X		

## **Responses to Questions in field**

Q1) Is the complete set of drawings on the web?

**A1) The recent version with in addendum 3 attachment 2 will be as current as possible. Tactical Tower and foundation are completed. The electrical has minor updates to be supplied in addendum 4.**

Q2) Will Prime need to pull permit for this job?

**A2) [To be continued. Updates as to this process will be provided in next round of questions.]**

Q3) Is there any sprinklers or smoke alarm in this tower?

**A3) [NO. This structure is seeking non occupied class as this is a training prop that looks like a building]**

Q4) Are Primes responsible for restrooms?

**A4) [Yes. Portable solutions will need to be supplied by Prime for this project]**

Q5) Can Hours of access to jobsite be extended?

**A5) [Yes. In order to meet the 12/31 deadline, the prime can work extended hours provided access is coordinated]**

Q6) Site contractors will require clearance, what about delivery drivers like Cement providers?

**A6) [Clearance will be required for any staff performing daily activities. Delivery drivers need to be coordinated but not require site clearance]**

Q7) Are all power items noted in the latest set of drawings?

**A7) [Special Note – All electrical outlets are to be GFCI and exterior grade water tight for outlets and lights. This structure is not water tight. ADDITIONALLY there is one outstanding outlet 230V single phase detail on the 1<sup>st</sup> floor that is not identified but required for smoke generator. Details will be provided in Addendum 4. Please plan for this termination in the vicinity of the smoke generation machine.]**

Q8) Are all of the outlets identified for power on this set of addendum 3 drawings

**A8) [No. Tactical Tower supplied (2) exhaust fans 240 V P1 10A, smoke generator 230V P1 12A, and smoke distribution fan 120V P1 4A] are not indicated on this current set. Addendum 4 will provide this detail**

Q9) X

**A9) [respond here]**

Q10) X

**A10) [respond here]**

Q11) x

**A11) [respond here]**