

**SPECIFICATIONS AND OTHER BIDDING AND CONTRACT DOCUMENTS**

**ALAMEDA COUNTY CONTRACT #901911  
AS-NEEDED HEATING, VENTILATION, AND AIR CONDITIONING (HVAC)  
MAINTENANCE AND REPAIRS**

**PRE-BID MEETING**

**Tuesday, January 5, 2021 at 1:00 PM**

**Location: Online Only**

**To Attend Online: [Microsoft Teams Meeting](#)**

**Dial in Number: 1 415-915-3950**

**Conference ID: 972 561 126#**

**ALAMEDA COUNTY  
GENERAL SERVICES AGENCY  
BUILDING MAINTENANCE DEPARTMENT  
2054 FAIRMONT DRIVE  
SAN LEANDRO, CALIFORNIA  
PHONE: 510-667-3046 FAX: 510-667-3050**



DOCUMENT 00 01 09

**SUMMARY BIDDING CALENDAR**

**NOTICE** – THIS SUMMARY IS FOR INFORMATIONAL PURPOSES ONLY AND DOES NOT LIST ALL DATES, OR TIMES IN THE BIDDING DOCUMENTS. The dates and times listed may not be relied upon or enforced. This summary does not form a part of the contract documents and does not establish contractual obligations. All bidders and contractors must refer to the actual documents for all applicable dates, times and time periods.

<b><u>Event</u></b>	<b><u>Date</u></b>	<b><u>Reference</u></b>
Contract Documents Available	<b>December 22, 2020</b>	00 11 16 Notice to Bidders
Pre-Bid Conference & Site Visit	<b>January 5, 2021</b>	00 11 16 Notice to Bidders
Last Day for Receipt of Requests for Substitutions before Receipt of Bids	10 business days before date for Receipt of Bids	00 21 13 Instructions to Bidders
Last Day for Receipt of Questions	10 business days before date for Receipt of Bids	00 21 13 Instructions to Bidders
Last Day to Submit Bid Protest	5 <sup>th</sup> Business Day from Date of Notice of Intent to Award	00 21 13 Instructions to Bidders
Receipt of Bids and Bid Opening	<b>January 22, 2021</b>	00 11 16 Notice to Bidders
Estimated Date of Notice of Award	<b>March 2, 2021</b>	TBD by County
Signing of Contract	7 Calendar days after Notice of Award	00 11 16 Notice to Bidders 00 51 00 Notice of Award
Submit Post-Award Documents	7 Calendar days after Notice of Award	00 21 13 Instructions to Bidders
Last Day to Submit Escrow Bid Documentation	7 Calendar days after Notice of Award	00 56 00 Escrow Bid Documentation
Contract Duration	<b>3 years</b>	00 52 13 Agreement Form – Stipulated Sum (Single-Prime Contract)
Contract Duration Begins	<b>April 1, 2021</b>	00 55 00 Notice to Proceed
Contract Duration Ends	<b>April 1, 2024</b>	00 55 00 Notice to Proceed
Last Day to Submit Preliminary Schedule, etc. per Notice to Proceed	10 <sup>th</sup> Business Day following Notice to Proceed	00 55 00 Notice to Proceed

END OF DOCUMENT

DOCUMENT 00 01 10

**TABLE OF CONTENTS**

**DIVISION 00 — PROCUREMENT AND CONTRACTING REQUIREMENTS**

**00 00 00      PROCUREMENT AND CONTRACTING REQUIREMENTS**

**INTRODUCTORY INFORMATION**

<b>00 01 01</b>	<b>Project Title Page</b>
<b>00 01 09</b>	<b>Summary Bidding Calendar</b>
<b>00 01 10</b>	<b>Table of Contents</b>

**PROCUREMENT REQUIREMENTS**

**00 10 00      SOLICITATION**

<b>00 11 00</b>	<b>Advertisements and Invitations</b>
<b>00 11 16</b>	<b>Notice to Bidders</b>

**00 20 00      INSTRUCTIONS FOR PROCUREMENT**

<b>00 21 00</b>	<b>Instructions</b>
<b>00 21 13</b>	<b>Instructions to Bidders</b>

**00 40 00      PROCUREMENT FORMS AND SUPPLEMENTS**

<b>00 41 00</b>	<b>Bid Forms</b>
<b>00 41 13</b>	<b>Bid Form – Stipulated Sum (Single-Prime Contract)</b>
<b>00 43 00</b>	<b>Procurement Form Supplements</b>
<b>00 43 13</b>	<b>Bid Security Form</b>
<b>00 43 36</b>	<b>Designated Subcontractors List</b>
<b>00 45 00</b>	<b>Representations and Certifications</b>
<b>00 45 13</b>	<b>Non-Collusion Affidavit</b>
<b>00 45 26</b>	<b>Worker's Compensation Certification</b>
<b>00 45 46</b>	<b>Governmental Certifications</b>
<b>00 45 46.01</b>	<b>Prevailing Wage and Related Labor Requirements Certification</b>
<b>00 45 46.04</b>	<b>Hazardous Materials Certification</b>
<b>00 45 46.06</b>	<b>Imported Materials Certification</b>

**CONTRACTING REQUIREMENTS**

**00 50 00      CONTRACTING FORMS AND SUPPLEMENTS**

<b>00 51 00</b>	<b>Notice of Award</b>
<b>00 51 13</b>	<b>Notice of Intent to Award</b>
<b>00 52 00</b>	<b>Agreement Forms</b>
<b>00 52 13</b>	<b>Agreement Form – Stipulated Sum (Single-Prime Contract)</b>
<b>00 52 13.1</b>	<b>Debarment and Suspension Certification Form</b>
<b>00 55 00</b>	<b>Notice to Proceed</b>
<b>00 56 00</b>	<b>Escrow of Bid Documentation</b>

**00 57 00 Escrow Agreement for Security Deposits in Lieu of Retention**

**00 60 00 PROJECT FORMS**

**00 61 00 Bond Forms**

**00 61 13 Performance and Payment Bond Forms**

**00 61 13.13 Performance Bond Form**

**00 61 13.16 Payment Bond Form**

**00 65 00 Closeout Forms**

**00 65 19 Certificate of Completion Forms**

**00 65 19.26 Final Settlement Certificate Form**

**00 65 36 Warranty Form**

**00 70 00 CONDITIONS OF THE CONTRACT**

**00 72 00 General Conditions**

**00 72 13 General Conditions – Stipulated Sum (Single-Prime Contract)**

**00 73 00 Supplementary Conditions**

**00 73 13 Special Conditions**

**00 73 56 Hazardous Materials Procedures and Requirements**

**DIVISION 01 — GENERAL REQUIREMENTS**

**01 00 00 GENERAL REQUIREMENTS**

**01 10 00 Summary**

**01 11 00 Summary of Work**

**01 20 00 PRICE AND PAYMENT PROCEDURES**

**01 22 00 Unit Prices and Alternates**

**01 29 00 Payment Procedures**

**01 30 00 ADMINISTRATIVE REQUIREMENTS**

**01 31 19 Project Meetings**

**01 33 00 Submittal Procedures**

**01 35 23 Construction Indoor Air Quality Management**

**01 40 00 QUALITY REQUIREMENTS**

**01 41 00 Regulatory Requirements**

**01 42 00 References**

**01 42 13 Abbreviations and Acronyms**

**01 42 16 Definitions and Reference Standards**

**01 43 00 Quality Assurance – materials and equipment**

**01 45 00 Quality Control**

**01 50 00 TEMPORARY FACILITIES AND CONTROLS**

**01 60 00 PRODUCT REQUIREMENTS**

**01 62 00 Product Options and Substitutions**

**01 65 00 Delivery, Storage and Handling**

- 01 70 00 EXECUTION AND CLOSEOUT REQUIREMENTS
  - 01 71 00 Examination and Preparation
  - 01 71 23 Field Engineering**
  - 01 73 00 Execution
    - 01 73 29 Cutting and Patching**
  - 01 74 19 Construction Waste Management**
  - 01 76 00 Protecting Installed Construction**
  - 01 77 00 Closeout Procedures**
  - 01 78 00 Closeout Submittals
    - 01 78 23 Operation and Maintenance Instructions**
    - 01 78 36 Warranties**
    - 01 78 39 Project Record Documents**
- 01 90 00 LIFE CYCLE ACTIVITIES
  - 01 91 00 Commissioning
    - 01 91 13 General Commissioning Requirements**

DIVISION 26 — ELECTRICAL

- 26 00 00 Electrical Basic Requirements**
- 26 05 09 Equipment Wiring**
- 26 05 19 Low-Voltage Electrical Power Conductors and Cables**
- 26 05 26 Grounding and Bonding for Electrical Systems**
- 26 05 29 Hangers and Supports for Electrical Systems and Equipment**
- 26 05 33 Raceways**
- 26 05 34 Boxes**
- 26 05 54 Identification for Electrical Systems**
- 26 27 26 Wiring Devices**
- 26 28 00 Overcurrent Protective Devices**
- 26 28 16 Enclosed Switches and Circuit Breakers**
- 26 29 13 Enclosed Controllers**

ATTACHMENTS

- Exhibit A Task Order Form
- Exhibit B Task Order Change Order Form
- Exhibit C Insurance Requirements

DOCUMENT 00 11 16

**NOTICE TO BIDDERS**

1. Notice is hereby given that The County of Alameda General Services Agency (“GSA”) Purchasing Department (“County” or “Owner”) will receive sealed bids for the following project, Bid No. 901911 (“Project” or Contract”)

As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

2. Sealed Bids will be received until 11:00 a.m., January 22, 2021 at 2054 Fairmont Drive, San Leandro, California, at or after which time the bids will be opened and publicly read aloud via online video conference.

To attend the online bid opening visit: [Microsoft Teams Meeting](#); **Dial in Number:** 1 415-915-3950; **Conference ID:** 917 774 265# . Any claim by a bidder of error in its bid must be made in compliance with §5100 et seq. of the Public Contract Code. Any bid that is submitted after this time shall be considered non-responsive and returned to the bidder.

3. The Project consists of:

The County is seeking qualified bidders who can provide as-needed Heating, Ventilation, and Air Conditioning (HVAC) installation, maintenance, and repairs. This includes general repair, maintenance, replacement, upgrading, installation, diagnosing, testing, and troubleshooting of all aspects of the County’s HVAC systems, equipment, devices, components, and parts. A full range of HVAC services is required and will be requested on an on-call, as-needed basis by individually assigned Task Orders. Services to the County will include all maintenance, repairs, and support for existing systems and equipment. The maintenance services include all software, equipment, parts, labor, and onsite configuration expertise support.

This contract will apply to existing County owned buildings and leased buildings in most cases depending on the site and the project. This contract will not apply to Task Orders exceeding \$125,000. Capital projects below the \$125,000 threshold may or may not be procured separately from this contract.

This contract shall not-to-exceed \$900,000. The County intends to award up to three (3) contracts of equal value for a three-year term, with an option to extend for an additional two years, from the Notice to Proceed.

4. All bids shall be on the Bid Form Document 00 41 13 provided by the County. Each bid must conform to and be responsive to all pertinent Contract Documents.

5. To bid on this Project, the Bidder is required to possess the following State of California Contractor Licenses:

**C-4 – Boiler, Hot Water, Heating and Steam Fitting**

**AND**

**C-20 – Low Voltage Systems Contractor**

**AND**

**C-38 – Refrigeration**

The Bidder's license must remain active and in good standing throughout the term of the Contract.

6. A bid bond by an admitted surety insurer on the form provided by the County, cash, or a cashier's check or a certified check, drawn to the order of the County of Alameda, in the amount of ten percent (10%) of the total bid price, shall accompany the Bid Form, as a guarantee that the Bidder will, within seven (7) calendar days after the date of the Notice of Award, enter into a contract with the County for the performance of the services as stipulated in the bid.
7. The successful Bidder shall be required to furnish a 100% Performance Bond and a 100% Payment Bond if it is awarded the contract for the Work.
8. The successful Bidder may substitute securities for any monies withheld by the County to ensure performance under the Contract, in accordance with the provisions of §22300 of the Public Contract Code.
9. The Contractor and all Subcontractors under the Contractor shall pay all workers on all work performed pursuant to this Contract not less than the general prevailing rate of per diem wages and the general prevailing rate for holiday and overtime work as determined by the Director of the Department of Industrial Relations, State of California, for the type of work performed and the locality in which the work is to be performed within the boundaries of the County, pursuant to §§1770 et seq. of the California Labor Code. Prevailing wage rates are also available from the County or on the Internet at: <http://www.dir.ca.gov>.
10. This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations. The following requirements apply to this bid and contract:

- A. No contractor or subcontractor may be listed on a bid proposal for a public works project (submitted on or after March 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code §1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code §1771.1(a)].
  - B. No contractor or subcontractor may be awarded a contract for public work on a public works project (awarded on or after April 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code §1725.5.
- 11. A voluntary pre-bid conference will be held **online only** via Microsoft Teams on January 5, 2020, at 1:00 p.m. **To attend online visit:** [Microsoft Teams Meeting](#); **Dial in Number:** 1 415-915-3950; **Conference ID:** 972 561 126#. If mandatory, failure to attend or arrival after the material start of the meeting will render bid ineligible.
  - 12. It is County policy to minimize the expenditure of County funds on goods and services produced by any entity which buys, sell, leases or distributes commodities and/or professional services to (1) the government of Burma; or (2) any entity organized under the laws of Burma; or (3) any entity which does business with any private or public entity located in Burma, or conducts operations in Burma. Contractors are urged to comply with the policy in making purchases and subcontracts. (ref. Alameda County, Cal., Adm. Code tit.4, §4.32.050(B), (F) )
  - 13. Contractors must comply with County Administrative Code's CONSTRUCTION DEBRIS MANAGEMENT AND GREEN BUILDING PRACTICES. This Project is designed to meet minimum LEED™ "Silver" rating under the LEED rating system, or a county-approved equivalent, and Contractors are required to perform all work in a manner that will not hinder LEED™ certification of the Project.
  - 14. The County reserves the right to reject any and all bids and/or waive any irregularity in any bid received. If the County awards the Contract, the security of unsuccessful bidder(s) shall be returned within sixty (60) days from the time the award is made. Unless otherwise required by law, no bidder may withdraw its bid for ninety (90) days after the date of the bid opening.
  - 15. The County shall award the Contract, if it awards it at all, to the three (3) lowest responsive, responsible bidder(s) based on:
    - A. The base bid amount only.

END OF DOCUMENT



**PLAN ROOM ADVERTISING LIST**

<input type="checkbox"/> 1	Bay Area Builders Exchange** 3055 Alvarado Street San Leandro, CA 94577 Phone: (510) 483-8880 ;Fax: (925) 685-3424 Email: <a href="mailto:planroom@bayareabx.com">planroom@bayareabx.com</a> (This is a merger of Builders Exchange of Alameda County and Contra Costa Builders Exchange 5/18/15.)	<input type="checkbox"/> 2	San Francisco Builders Exchange 850 South Van Ness Avenue San Francisco, CA 94110 Phone: (415) 282-8220 Fax: (415) 821-0363 Email: <a href="mailto:djohnsonsf@sbcglobal.net">djohnsonsf@sbcglobal.net</a>
<input type="checkbox"/> 3	Dodge Data and Analytics (Dodge Plan Room, formerly McGraw-Hill Construction Dodge) (Online) 3315 Central Avenue Hot Springs Arkansas (AR) 71913 (Contact: <b>Gerry McCarthy</b> ) 626-531-6818; Fax: 626-226-1623 Email <a href="mailto:gerry.mccarthy@construction.com">gerry.mccarthy@construction.com</a>	<input type="checkbox"/> 4	Small Business Exchange 703 Market Street, Suite 1000 San Francisco, CA 94103 Phone: (415) 778-6250 Fax: (415) 778-6255 Email: <a href="mailto:sbe@sbeinc.com">sbe@sbeinc.com</a>
<input type="checkbox"/> 5	Central California Builders Exchange 1244 N. Mariposa St. Fresno, Ca 93703 Phone (559) 237-1831; Fax (559) 264-2532 Email: <a href="mailto:megan@cencalbx.com">megan@cencalbx.com</a>	<input checked="" type="checkbox"/> 6	County of Alameda Current Contracting Opportunities Website located at <a href="http://www.acgov.org/gsa_app/gsa/purchasing/bid_content/contractopportunities.jsp">http://www.acgov.org/gsa_app/gsa/purchasing/bid_content/contractopportunities.jsp</a>
<input type="checkbox"/> 7	The Blue Book Building & Construction Network ( <a href="http://www.bb-bid.com">www.bb-bid.com</a> Online) Contact: Amanda Limitone, Project Communication Specialist Phone: (855) 805-2560, ext.3145; Email: <a href="mailto:alimitone@thebluebook.com">alimitone@thebluebook.com</a>		
<input type="checkbox"/> 8	Reed Construction Data** – Online/Electronic Plan Room 30 Technology Parkway South, Suite 100 Norcross, GA 30092-2912 Phone: (770) 209-3396 Jeannie Kwan; Fax (Addenda only): (800) 303-8629; Fax (Notice to Bidders/IFB): (800) 642-2437; Email (addenda only): <a href="mailto:docprocessing@reedbusiness.com">docprocessing@reedbusiness.com</a> -Send requests to advertise to above address/fax/phone- Local Email: <a href="mailto:jeannie.kwan@reedbusiness.com">jeannie.kwan@reedbusiness.com</a> (EPR: <a href="http://www.reedconstructiondata.com">http://www.reedconstructiondata.com</a> )		
<input type="checkbox"/> 9	East Bay Blue Print & Supply Co. 1745 Fourteenth Ave Oakland, CA 94606 Phone: (510) 261-2990 - Sandy Petty Email: <a href="mailto:ebbp@eastbayblueprint.com">ebbp@eastbayblueprint.com</a>		
<input type="checkbox"/> 10	Construction Bidboard, Inc. (Online)** 11622 El Camino Real, Suite 100 San Diego, CA 92130 800-479-5314 phone; 619-688-0585 fax (Contact <b>Dorothy Ellithorpe</b> <a href="mailto:dellithorpe@ebidboard.com">dellithorpe@ebidboard.com</a> ) <u>Alternate: <a href="mailto:planroom@ebidboard.com">planroom@ebidboard.com</a> * <a href="mailto:ebidboard@gmail.com">ebidboard@gmail.com</a></u>		

\* Plans/Specs must be sent to individual Plan Rooms to ensure posting at that location.

\*\*Construction trade journals specified for alternate bidding procedures for projects between \$25,000 and \$125,000 minimum advertising requirements. County policy is to post all construction projects over \$25,000 in all listed Plan Rooms, Press/Newspaper Publications and Local Chambers of Commerce/Trade Organizations

**DOCUMENT 00 21 13**

**INSTRUCTIONS TO BIDDERS**

Bidders shall follow the instructions in this document, and shall submit all documents, forms, and information required for consideration of a Bid.

County will evaluate information submitted by the apparent low Bidder and, if incomplete or unsatisfactory to County, Bidder's bid may be rejected at the sole discretion of County.

1. Bids are requested for a general construction contract, or work described in general, for the following contract ( "Contract"):

As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

2. County will receive sealed Bids from Bidders as stipulated in the Notice to Bidders Document 00 11 16.
3. Bidders must submit Bids on Bid Form 00 41 13 and all other required County forms. Bids not submitted on the County's required forms shall be deemed non-responsive and shall not be considered. Additional sheets required to fully respond to requested information are permissible.
4. Bidders must supply all information required by each Bid Document. Bids must be completed in full. County reserves the right in its sole discretion to reject any Bid as non-responsive as a result of any error or omission in the Bid. Bidders must complete and submit all of the following documents with Bid Form Document 00 41 13:
  - a. Bid Bond on Bid Security Form Document 00 43 13 or other security
  - b. Designated Subcontractors List Document 00 43 36
  - c. Site-Visit Certification Document 00 45 01, if a site visit was required
  - d. Non-Collusion Affidavit Document 00 45 13
  - e. Completed Debarment Form, Document 00 52 13.1.
5. Bidders must submit with their Bids cash, a cashier's check or a certified check payable to County, or a Bid Bond of not less than ten percent (10%) of amount of base Bid, plus all additive alternates. Required form of corporate surety, Bid Security Form, is provided by County and must be used and fully completed by Bidders choosing to provide a Bid Bond as security. The Surety on Bidder's Bid Bond must be an insurer admitted in the State of California and authorized to issue surety bonds in the State of California. Bids submitted without necessary bid security will be deemed non-responsive and will not be considered.

6. If Bidder to whom Contract is awarded shall for **SEVEN (7)** calendar days after the date of the Notice of Award, fail or neglect to enter into Contract and submit required bonds, insurance certificates, and all other required documents, County may deposit Bid Bond, cash, cashier's check, or certified check for collection, and proceeds thereof may be retained by County as liquidated damages for failure of Bidder to enter into Contract, in the sole discretion of County. It is agreed that calculation of damages County may suffer as a result of Bidder's failure to enter into the Contract would be extremely difficult and impractical to determine and that the amount of the Bidder's required bid security shall be the agreed and conclusively presumed amount of damages.
7. Bidders must submit with the Bid the Designated Subcontractors List for those subcontractors who will perform any portion of Work, including labor, rendering of service, or specially fabricating and installing a portion of the Work or improvement according to detailed drawings contained in the plans and specifications, in excess of one half of one percent (0.5%) of total Base Bid. Failure to submit this list when required by law shall result in Bid being deemed non-responsive and the Bid will not be considered.
8. If a mandatory pre-bid conference and site visit ("Site Visit") is requested as referenced in the Instructions to Bidders, then Bidders must submit the Site-Visit Certification with their Bid. County will transmit to all prospective Bidders of record such Addenda as County in its discretion considers necessary in response to questions arising at the Site Visit. Oral statements shall not be relied upon and will not be binding or legally effective. Addenda issued by the County as a result of the Site Visit, if any shall constitute the sole and exclusive record and statement of the results of the Site Visit.
9. Bidders shall submit the Non-Collusion Affidavit with their Bids. Bids submitted without the Non-Collusion Affidavit shall be deemed non-responsive and will not be considered.
10. Bids shall be clearly written without erasure or deletions. County reserves the right to reject any Bid containing erasures or deletions.
11. Bidders shall not modify Bid Form 00 41 13 or qualify their Bids. Bidders shall not submit to the County a scanned, re-typed, word-processed, or otherwise recreated version of Bid Form 00 41 13 or other County-provided document.

The successful Bidder and all its subcontractors shall pay all workers on all work performed pursuant to this Contract not less than the general prevailing rate of per diem wages and the general prevailing rate for holiday and overtime work as determined by the Director of the Department of Industrial Relations, State of California, for the type of work performed and the locality in which the work is to be performed within the boundaries of the County, pursuant to §§1770 et seq. of the California Labor Code.

12. Submission of Bid signifies careful examination of Contract Documents and complete understanding of the nature, extent, and location of Work to be performed. Bidders must

complete the tasks listed below as a condition to bidding, and submission of Bid shall constitute the Bidder's express representation to County that Bidder has fully completed the following:

- a. Bidder has visited the Site and has examined thoroughly and understood the nature and extent of the Contract Documents, Work, Site, locality, actual conditions, as-built conditions, and all local conditions and federal, state and local laws, and regulations that in any manner may affect cost, progress, performance, or furnishing of Work or that relate to any aspect of the means, methods, techniques, sequences, or procedures of construction to be employed by Bidder and safety precautions and programs incident thereto;
- b. Bidder has conducted or obtained and has understood all examinations, investigations, explorations, tests, reports, and studies that pertain to the subsurface conditions, as-built conditions, underground facilities, and all other physical conditions at or contiguous to the Site or otherwise that may affect the cost, progress, performance, or furnishing of Work, as Bidder considers necessary for the performance or furnishing of Work at the Contract Sum, within the Contract Time, and in accordance with the other terms and conditions of Contract Documents, including specifically the provisions of the General Conditions; and no additional examinations, investigations, explorations, tests, reports, studies, or similar information or data are or will be required by Bidder for such purposes;
- c. Bidder has correlated its knowledge and the results of all such observations, examinations, investigations, explorations, tests, reports, and studies with the terms and conditions of the Contract Documents;
- d. Bidder has given County prompt written notice of all conflicts, errors, ambiguities, or discrepancies that it has discovered in or among the Contract Documents and the actual conditions, and the written resolution thereof by County is acceptable to Bidder;
- e. Bidder has made a complete disclosure in writing to County of all facts bearing upon any possible interest, direct or indirect, that Bidder believes any representative of County or other officer or employee of County presently has or will have in this Contract or in the performance thereof or in any portion of the profits thereof;
- f. Bidder must, prior to bidding, perform the work, investigations, research, and analysis required by this document and that Bidder represents in its Bid Form 00 41 13 and the Agreement that it performed prior to bidding. Bidders are charged with all information and knowledge that a reasonable bidder would ascertain from having performed this required work, investigation, research, and analysis. Bid prices must include entire cost of all work "incidental" to completion of the Work.

- g. Conditions Shown on the Contract Documents: Information as to underground conditions, as-built conditions, or other conditions or obstructions, indicated in the Contract Documents, e.g., on Drawings or in Specifications, has been obtained with reasonable care, and has been recorded in good faith. However, County only warrants, and Bidder may only rely, on the accuracy of limited types of information.
- (1) As to above-ground conditions or as-built conditions shown or indicated in the Contract Documents, there is no warranty, express or implied, or any representation express or implied, that such information is correctly shown or indicated. This information is verifiable by independent investigation and Bidder is required to make such verification as a condition to bidding. In submitting its Bid, Bidder shall rely on the results of its own independent investigation. In submitting its Bid, Bidder shall not rely on County-supplied information regarding above-ground conditions or as-built conditions.
  - (2) As to any subsurface condition shown or indicated in the Contract Documents, Bidder may rely only upon the general accuracy of actual reported depths, actual reported character of materials, actual reported soil types, actual reported water conditions, or actual obstructions shown or indicated. County is not responsible for the completeness of such information for bidding or construction; nor is County responsible in any way for any conclusions or opinions of Bidder drawn from such information; nor is County responsible for subsurface conditions that are not specifically shown (for example, County is not responsible for soil conditions in areas contiguous to areas where a subsurface condition is shown).
- h. Conditions Shown in Reports and Drawings Supplied for Informational Purposes: Reference is made to the document entitled Geotechnical Data, and the document entitled Existing Conditions Information, for identification of:
- (1) Subsurface Conditions: Those reports of explorations and tests of subsurface conditions at or contiguous to the Site that have been utilized by Architect in preparing the Contract Documents; and
  - (2) Physical Conditions: Those drawings of physical conditions in or relating to existing surface or subsurface structures at or contiguous to the Site that has been utilized by Architect in preparing the Contract Documents.
  - (3) These reports and drawings are **not** Contract Documents and, except for any "technical" data regarding subsurface conditions specifically identified in Geotechnical Data and Existing Conditions Information, and

underground facilities data, Bidder may not in any manner rely on the information in these reports and drawings. Subject to the foregoing, Bidder must make its own independent investigation of all conditions affecting the Work and must not rely on information provided by County.

13. Bidders may examine any available "as-built" drawings of previous work by giving County reasonable advance notice. County will not be responsible for accuracy of "as-built" drawings. The document entitled Existing Conditions Information applies to all supplied "as-built" drawings.
14. Copies of the general prevailing rates of per diem wages for each craft, classification, or type of worker needed to execute the Contract, as determined by Director of the State of California Department of Industrial Relations, are on file at the County's principal office. Prevailing wage rates are also available from the County or on the internet at (<http://www.dir.ca.gov>)
15. All questions about the meaning or intent of the Contract Documents are to be directed in writing, including by e-mail, to County. Interpretations or clarifications considered necessary by County in response to such questions will be issued in writing by Addenda faxed, mailed, or delivered to all parties recorded by County as having received the Contract Documents. Questions received less than **TEN(10)** business days prior to the date for opening Bids may not be answered. Only questions answered by formal written Addenda will be binding. Oral and other interpretations or clarifications will be without legal effect.
16. Addenda may also be issued to modify other parts of the Contract Documents as deemed advisable by County.
17. Each Bidder must acknowledge each Addendum in its Bid Form 00 41 13 by number or its Bid shall be considered non-responsive. Addenda shall be part of the Contract Documents. A complete listing of Addenda may be secured from County.
18. Bids shall be based on products and systems specified in Contract Documents or listed by name in Addenda. County is not responsible and/or liable in any way for a Bidder's damages and/or claims related, in any way, to that Bidder's basing its bid on any requested substitution that County has not approved. Bidders and materials suppliers who submit requests for substitutions prior to the award of the Contract must do so in writing and in compliance with Public Contract Code §3400. All requests must comply with the following:
  - a. County must receive any request for substitution a minimum of **TEN (10)** business days prior to bid opening.
  - b. Requests for substitutions shall contain sufficient information to assess acceptability of product or system and impact on Project, including, without

- limitation, the requirements specified in the Special Conditions and the Specifications. Insufficient information shall be grounds for rejection of substitution.
- c. Approved substitutions shall be listed in Addenda. County reserves the right not to act upon submittals of substitutions until after bid opening.
  - d. Substitutions may be requested after Contract has been awarded only if indicated in and in accordance with requirements specified in the Special Conditions and the Specifications.
19. All Bids must be sealed, and marked with name and address of the Bidder and the Project Number, Bid number, Bid package, and time of bid opening. Bids will be received as indicated in the Notice to Bidders.
- a. Mark envelopes with the name of the Project.
  - b. Bids must be submitted at the place and by date and time shown in the Instructions to Bidders.
  - c. Bids must contain all documents as required herein.
20. Bids will be opened publicly immediately after the time indicated for receipt of bids.
21. This Contract may include alternates. Alternates are defined as alternate products, materials, equipment, systems, methods, or major elements of the construction that may, at the County's option and under terms established in the Contract and pursuant to §20103.8 of the Public Contract Code, be selected for the Work. County shall award the Contract, if it awards it at all, to the lowest responsive responsible bidder based on the criteria as indicated in these contract documents.
22. Time for Completion: County may issue a Notice to Proceed within **NINETY (90)** calendar days from the date of the Notice of Award. Once Contractor has received the Notice to Proceed, Contractor shall complete the Work within the period of time indicated in the Contract Documents.
- a. In the event that County desires to postpone issuing the Notice to Proceed beyond the 90-day period above, it is expressly understood that with reasonable notice to the Contractor, County may postpone issuing the Notice to Proceed.
  - b. It is further expressly understood by Bidder that Contractor shall not be entitled to any claim of additional compensation as a result of the postponement of the issuance of the Notice to Proceed beyond the 90-day period. If the Contractor believes that a postponement of issuance of the Notice to Proceed will cause a hardship to the Contractor, the Contractor may terminate the Contract.

Contractor's termination due to a postponement beyond this 90-day period shall be by written notice to County within **TEN (10)** calendar days after receipt by Contractor of County's notice of postponement.

- c. It is further understood by Bidder that in the event that Contractor terminates the Contract as a result of postponement by County, County shall only be obligated to pay Contractor for the Work that Contractor had performed at the time of notification of postponement and which County had in writing authorized Contractor to perform prior to issuing a Notice to Proceed.
  - d. Should the Contractor terminate the Contract as a result of a notice of postponement, County shall have the authority to award the Contract to the next lowest responsive responsible bidder.
23. The Bidder to whom Contract is awarded shall execute and submit the following documents by 5:00 p.m. of the **SEVENTH (7<sup>TH</sup>)** calendar day following the date of the Notice of Award. Failure to properly and timely submit these documents entitles County to reject the bid as non-responsive.
- a. Agreement: To be executed by successful Bidder. Submit four (4) copies, each bearing an original signature.
  - b. Escrow of Bid Documentation: This must include all required documentation. See the document Escrow of Bid Documentation for more information.
  - c. Performance Bond (100%): On the form provided in the Contract Documents and fully executed as indicated on the form.
  - d. Payment Bond (100%) (Contractor's Labor and Material Bond): On the form provided in the Contract Documents and fully executed as indicated on the form.
  - e. Insurance Certificates and Endorsements as required.
  - f. Workers' Compensation Certification.
  - g. Prevailing Wage and Related Labor Requirements Certification.
  - h. Hazardous Materials Certification.
  - i. Contractor's Safety Plan specifically adapted for the Project.
24. Any Bid protest by any Bidder regarding any other Bid must be submitted in writing to the County's GSA–Office of Acquisition Policy, ATTN: Contract Compliance Officer, located at 1401 Lakeside Drive, 10th Floor, Oakland, CA 94612, Fax: (510) 208-9720,



before 5:00 p.m. of the FIFTH (5th) business day following the date of issuance of the Notice of Intent to Award, not the date received by the Bidder. A Bid protest received after 5:00 p.m. is considered received as of the next business day.

- a. The Bid protest must contain a complete statement of the reasons and facts for the protest.
- b. The protest must refer to the specific portions of all documents that form the basis for the protest.
- c. The protest must include the name, address, email address, fax number and telephone number of the person representing the protesting party.
- d. The County Agency/Department will notify all bidders of the protest as soon as possible.
- e. Upon receipt of written protest, GSA–Office of Acquisition Policy, or designee, will review and evaluate the protest and issue a written decision. The GSA–Office of Acquisition Policy, may, at its discretion, investigate the protest, obtain additional information, provide an opportunity to settle the protest by mutual agreement, and/or schedule a meeting(s) with the protesting Bidder and others (as appropriate) to discuss the protest. The decision on the bid protest will be issued at least ten (10) business days prior to the Board hearing or GSA award date.
- f. The decision will be communicated by e-mail, fax, or US Postal Service mail, and will inform the bidder whether or not the recommendation to the Board of Supervisors or GSA in the Notice of Intent to Award is going to change. A copy of the decision will be furnished to all Bidders affected by the decision. As used in this paragraph, a Bidder is affected by the decision on a Bid protest if a decision on the protest could have resulted in the Bidder not being the apparent successful Bidder on the Bid.
- g. The decision of the GSA-Office of Acquisition Policy on the bid protest may be appealed to the Auditor-Controller's Office of Contract Compliance & Reporting (OCCR) located at 1221 Oak St., Room 249, Oakland, CA 94612, Fax: (510) 272-6502 unless the OCCR determines that it has a conflict of interest in which case an alternate will be identified to hear the appeal and all steps to be taken by OCCR will be performed by the alternate. The Bidder whose Bid is the subject of the protest, all Bidders affected by the GSA-Office of Acquisition Policy's decision on the protest, and the protestor have the right to appeal if not satisfied with the GSA-Office of Acquisition Policy's decision. All appeals to the Auditor-Controller's OCCR shall be in writing and submitted within five (5) business days following the issuance of the decision by the GSA-Office of Acquisition Policy, not the date received by the Bidder. An appeal received after 5:00 p.m. is considered received as of the next business day. An appeal received after the

FIFTH (5th) business day following the date of issuance of the decision by the GSA-Office of Acquisition Policy shall not be considered under any circumstances by the GSA or the Auditor-Controller OCCR.

- h. The appeal shall specify the decision being appealed and all the facts and circumstances relied upon in support of the appeal.
  - i. In reviewing protest appeals, the OCCR will not re-judge the proposal(s). The appeal to the OCCR shall be limited to review of the procurement process to determine if the contracting department materially erred in following the Bid or, where appropriate, County contracting policies or other laws and regulations.
  - j. The appeal to the OCCR also shall be limited to the grounds raised in the original protest and the decision by the GSA-Office of Acquisition Policy. As such, a Bidder is prohibited from stating new grounds for a Bid protest in its appeal. The Auditor-Controller (OCCR) shall only review the materials and conclusions reached by the GSA-Office of Acquisition Policy or department designee, and will determine whether to uphold or overturn the protest decision.
  - k. The Auditor's Office may overturn the results of a bid process for ethical violations by Procurement staff, County Selection Committee members, subject matter experts, or any other County staff managing or participating in the competitive bid process, regardless of timing or the contents of a bid protest.
  - l. The decision of the Auditor-Controller's OCCR is the final step of the appeal process. A copy of the decision of the Auditor-Controller's OCCR will be furnished to the protestor, the Bidder whose Bid is the subject of the Bid protest, and all Bidders affected by the decision.
  - m. The County will complete the Bid protest/appeal procedures set forth in this paragraph before a recommendation to award the Contract is considered by the Board of Supervisor or GSA.
  - n. The procedures and time limits set forth in this paragraph are mandatory and are each Bidder's sole and exclusive remedy in the event of Bid Protest. A Bidder's failure to timely complete both the Bid protest and appeal procedures shall be deemed a failure to exhaust administrative remedies. Failure to exhaust administrative remedies, or failure to comply otherwise with these procedures, shall constitute a waiver of any right to further pursue the Bid protest, including filing a Government Code Claim or legal proceedings.
25. A responsive bid is a solicited bid that has been determined to be in conformance with the conditions, completion or delivery requirements, and specifications detailed in the

- solicitation for bid. Responsive bids are those submitted on time; contain complete information, and required submittals and/or supporting documentation.
26. A responsible bidder is defined by the California Public Contract Code §1103 as "a bidder who has demonstrated the attribute of trustworthiness, as well as quality, fitness, capacity, and experience to satisfactorily perform this public works contract."
  27. County reserves the right to reject any or all bids, including without limitation the right to reject any or all nonconforming, non-responsive, unbalanced, or conditional bids, to re-bid, and to reject the bid of any bidder if County believes that it would not be in the best interest of County to make an award to that bidder, whether because the bid is not responsive or the bidder is unqualified or of doubtful financial ability or fails to meet any other pertinent standard or criteria established by County. County also reserves the right to waive inconsequential deviations not involving price, time, or changes in the Work. For purposes of this paragraph, an "unbalanced bid" is one having nominal prices for some work items and/or enhanced prices for other work items.
  28. Discrepancies between written words and figures, or words and numerals, will be resolved in favor of the figures or numerals.
  29. Prior to the award of Contract, County reserves the right to consider the responsibility of the Bidder. County may conduct investigations as County deems necessary to assist in the evaluation of any bid and to establish the responsibility, including, without limitation, qualifications and financial ability of Bidders, proposed subcontractors, suppliers, and other persons and organizations to perform and furnish the Work in accordance with the Contract Documents to County's satisfaction within the prescribed time.

END OF DOCUMENT

DOCUMENT 00 41 13

**BID FORM – STIPULATED SUM (SINGLE-PRIME CONTRACT)**

To: The County of Alameda

From: \_\_\_\_\_  
(Proper Name of Bidder)

The undersigned declares that the Contract Documents including, without limitation, the Notice to Bidders Document 00 11 16 and the Instructions to Bidders Document have been read and agrees and proposes to furnish all necessary labor, materials, and equipment to perform and furnish all work in accordance with the terms and conditions of the Contract Documents of Bid No. 901911

CONTRACT: As-needed Heating, Ventilation, and Air Conditioning (HVAC)  
Maintenance and Repairs

("Contract") and will accept in full payment for that Work the following total lump sum amount, all taxes included:

1. The below quantities are estimates only and are given as a basis for evaluation of bids. No guarantee is made or implied as to the exact quantity that will be needed.
2. In the case of discrepancy between the unit price and the total set forth for a unit basis item, the unit price shall prevail.
3. Any alternatives, modifications or changes to this bid proposal sheet by the proposer will be grounds for bid rejection.
4. Each line must be bid, do not leave any unit price column blank or this bid will be disqualified from competition for contract award.
5. Upon contract award, Contractor(s) shall provide rate sheets for their hourly and equipment rates. These hourly rates listed within the rate sheet shall be consistent with the rates listed in this bid proposal.

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

Item	Description	Unit of Measure	Estimated Quantity (A)	Hourly Rate (B)	Extended Price (=A*B)				
1	Standard Rate – Foreperson Monday – Friday between 7:00 AM to 5:00 PM	Hourly Rate	500	\$ _____	\$ _____				
2	Standard Rate – Journeyperson Monday – Friday between 7:00 AM to 5:00 PM	Hourly Rate	2500	\$ _____	\$ _____				
3	Standard Rate – Apprentice Monday – Friday between 7:00 AM to 5:00 PM	Hourly Rate	500	\$ _____	\$ _____				
4	After-hours Rate - Foreperson After 5:00 PM. Includes Weekends & Holidays	Hourly Rate	100	\$ _____	\$ _____				
5	After-hours Rate – Journeyperson After 5:00 PM. Includes Weekends & Holidays	Hourly Rate	500	\$ _____	\$ _____				
6	After-hours Rate - Apprentice After 5:00 PM. Includes Weekends & Holidays	Hourly Rate	100	\$ _____	\$ _____				
<b>SUBTOTAL</b>					\$ _____ (C)				
8	<p><b>For evaluation purposes only, calculate 20% of the subtotal above for Projected Parts/Materials/Supplies/Equipment</b></p> <p><i>(Contractor shall charge the actual cost of parts/materials/supplies/equipment approved by the County up to the total without additional allowance for mark-up)</i></p> <p><b>Projected Parts/Materials/Supplies/ Equipment (D) = Subtotal (C)* 20%</b></p>				\$ _____ (D)				
<b>TOTAL PROPOSAL</b>					\$ _____				
<b>Total Proposal (E) =Subtotal (C) + Projected Parts/Materials/Supplies/ Equipment (D)</b>					<b>(E)</b>				

- The undersigned has reviewed the Work outlined in the Contract Documents and fully understands the scope of Work required in this Bid, understands the construction and project management function(s) is described in the Contract Documents, and that each Bidder who is awarded a contract shall be in fact a prime contractor, not a subcontractor, to County, and agrees that its Bid, if accepted by County, will be the basis for the Bidder

**ALAMEDA COUNTY GSA-BMD**

**Page 2 of 5**

**BID FORM – STIPULATED SUM  
(SINGLE-PRIME CONTRACT)  
DOCUMENT 00 41 13  
Rev 1/3/20**

- to enter into a contract with County in accordance with the intent of the Contract Documents.
2. The undersigned has notified County in writing of any discrepancies or omissions or of any doubt, questions, or ambiguities about the meaning of any of the Contract Documents, and has contacted the Construction Manager before bid date to verify the issuance of any clarifying Addenda.
  3. The undersigned agrees to commence work under this Contract on the date established in the Contract Documents and to complete all work within the time specified in the Contract Documents.
  4. The liquidated damages clause of the General Conditions and Agreement is hereby acknowledged.
  5. It is understood that County reserves the right to reject this bid and that the bid shall remain open to acceptance and is irrevocable for a period of ninety (90) days.
  6. The following documents are attached hereto:
    - a. Bid Bond on Bid Security Form Document 00 43 13 or other security
    - b. Designated Subcontractors List Document 00 43 36
    - c. Site-Visit Certification Document 00 45 01, if a site visit was required
    - d. Non-Collusion Affidavit Document 00 45 13
    - e. Completed Debarment Form, Document 00 52 13.1

Receipt and acceptance of the following addenda is hereby acknowledged:

No.____, Dated _____	No.____, Dated _____
No.____, Dated _____	No.____, Dated _____
No.____, Dated _____	No.____, Dated _____
No.____, Dated _____	No.____, Dated _____

7. Bidder acknowledges that the license required for performance of the Work is a **C-4 and C-20 and C-38** license.

8. The undersigned hereby certifies that Bidder is able to furnish labor that can work in harmony with all other elements of labor employed or to be employed on the Work.
9. The Bidder represents that it is competent, knowledgeable and has special skills with respect to the nature, extent, and inherent conditions of the Work to be performed. Bidder further acknowledges that there are certain peculiar and inherent conditions existent in the construction of the Work that may create, during the Work, unusual or peculiar unsafe conditions hazardous to persons and property.
10. Bidder expressly acknowledges that it is aware of such peculiar risks and that it has the skill and experience to foresee and to adopt protective measures to adequately and safely perform the Work with respect to such hazards.
11. Bidder expressly acknowledges that it is aware that if a false claim is knowingly submitted (as the terms "claim" and "knowingly" are defined in the California False Claims Act, Cal. Gov. Code, §12650 et seq.), County will be entitled to civil remedies set forth in the California False Claim Act. It may also be considered fraud and the Contractor may be subject to criminal prosecution.
12. The undersigned Bidder certifies that it is, at the time of bidding, and shall be throughout the period of the contract, licensed by the State of California to do the type of work required under the terms of the Contract Documents. Bidder further certifies that it is regularly engaged in the general class and type of work called for in the Contract Documents.

Furthermore, Bidder hereby certifies to County that all representations, certifications, and statements made by Bidder, as set forth in this bid form, are true and correct and are made under penalty of perjury pursuant to the laws of California.

Dated this \_\_\_\_\_ day of \_\_\_\_\_ 20 \_\_\_\_

Name of Bidder \_\_\_\_\_

Type of Organization \_\_\_\_\_

Signed by \_\_\_\_\_

Title of Signer \_\_\_\_\_

Address of Bidder \_\_\_\_\_

Taxpayer's Identification No. of Bidder \_\_\_\_\_

ALAMEDA COUNTY GSA-BMD

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

Telephone Number \_\_\_\_\_

Fax Number \_\_\_\_\_

E-mail \_\_\_\_\_ Web page \_\_\_\_\_

Contractor's License No(s): No.: \_\_\_\_\_ Class: \_\_\_\_\_ Expiration Date: \_\_\_\_\_

No.: \_\_\_\_\_ Class: \_\_\_\_\_ Expiration Date: \_\_\_\_\_

No.: \_\_\_\_\_ Class: \_\_\_\_\_ Expiration Date: \_\_\_\_\_

Department of Industrial Relations Registration Number: \_\_\_\_\_

If Bidder is a corporation, affix corporate seal.

Name of Corporation: \_\_\_\_\_

President: \_\_\_\_\_

Secretary: \_\_\_\_\_

Treasurer: \_\_\_\_\_

Manager: \_\_\_\_\_

END OF DOCUMENT



DOCUMENT 00 43 13

**BID SECURITY FORM**

**(Bid Bond)**

**(Note: If Bidder is providing a bid bond as its bid security, Bidder must use this form, NOT a surety company form.)**

KNOW ALL PERSONS BY THESE PRESENTS:

That the undersigned, as \_\_\_\_\_ as Principal ("Principal"),  
and \_\_\_\_\_ as Surety ("Surety"),

a corporation organized and existing under and by virtue of the laws of the State of \_\_\_\_\_  
and authorized to do business as a surety in the State of California, are held and firmly bound  
unto the County of Alameda, State of California as Obligee, in the sum of

\_\_\_\_\_ (\$ \_\_\_\_\_)

lawful money of the United States of America, for the payment of which sum well and truly to  
be made, we, and each of us, bind ourselves, our heirs, executors, administrators, successors, and  
assigns, jointly and severally, firmly by these presents.

THE CONDITION OF THIS OBLIGATION IS SUCH that whereas the Principal has submitted  
a bid to County for all Work specifically described in the accompanying bid;

Now, therefore, if the Principal is awarded the Contract and, within the time and manner required  
under the Contract Documents, after the prescribed forms are presented to Principal for  
signature, enters into a written contract, in the prescribed form in accordance with the bid, and  
files two bonds, one guaranteeing faithful performance and the other guaranteeing payment for  
labor and materials as required by law, and meets all other conditions to the contract between the  
Principal and the Obligee becoming effective, or if the Principal shall fully reimburse and save  
harmless the Obligee from any damage sustained by the Obligee through failure of the Principal  
to enter into the written contract and to file the required performance and labor and material  
bonds, and to meet all other conditions to the Contract between the Principal and the Obligee  
becoming effective, then this obligation shall be null and void; otherwise, it shall be and remain  
in full force and effect. The full payment of the sum stated above shall be due immediately if  
Principal fails to execute the Contract within seven (7) days of the date of the County's Notice of  
Award to Principal.

Surety, for value received, hereby stipulates and agrees that no change, extension of time,  
alteration or addition to the terms of the Contract or the call for bids, or to the work to be  
performed thereunder, or the specifications accompanying the same, shall in any way affect its

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

obligation under this bond, and it does hereby waive notice of any such change, extension of time, alteration or addition to the terms of the Contract or the call for bids, or to the work, or to the specifications.

In the event suit is brought upon this bond by the Obligee and judgment is recovered, the Surety shall pay all costs incurred by the Obligee in such suit, including a reasonable attorneys' fee to be fixed by the Court.

If the County awards the bid, the security of unsuccessful bidder(s) shall be returned within sixty (60) days from the time the award is made. Unless otherwise required by law, no bidder may withdraw its bid for ninety (90) days after the date of the bid opening.

IN WITNESS WHEREOF, this instrument has been duly executed by the Principal and Surety above named, on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

(Affix Corporate Seal)

\_\_\_\_\_  
Principal

\_\_\_\_\_  
By

(Affix Corporate Seal)

\_\_\_\_\_  
Surety

\_\_\_\_\_  
By

\_\_\_\_\_  
Name of California Agent of Surety

\_\_\_\_\_  
Address of California Agent of Surety

\_\_\_\_\_  
Telephone Number of California Agent of Surety

**Bidder must attach Power of Attorney and Certificate of Authority for Surety and a Notarial Acknowledgment for all Surety's signatures. The California Department of Insurance must authorize the Surety to be an admitted Surety Insurer.**

END OF DOCUMENT

DOCUMENT 00 43 36

**DESIGNATED SUBCONTRACTORS LIST**

CONTRACT: As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

Bidder must list hereinafter the name and location of each subcontractor who will be employed, and the kind of Work that each will perform if the Contract is awarded to the Bidder. Bidder acknowledges and agrees that under Public Contract Code section 4100, et seq., it must clearly set forth below the name and location of each subcontractor who will perform work or labor or render service to the Bidder in or about the construction of the Work in an amount in excess of one-half of one percent (1/2 of 1%) of Bidder's total Bid, and that as to any Work that Bidder fails to list, Bidder agrees to perform that portion itself or be subjected to penalty under applicable law.

In case more than one subcontractor is named for the same kind of Work, state the portion that each will perform. Vendors or suppliers of materials only do not need to be listed.

If further space is required for the list of proposed subcontractors, additional sheets showing the required information, as indicated below, shall be attached hereto and made a part of this document.

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

Name and City of Subcontractor (1)	Description of Work: Reference to Contract Items (1)	Prices Under Subcontract (1)	Subcontractor's License Numbers.		
			State of California Contractor's License (1)	Dept. of Industrial Relations Registration No. (DIR) (1)	Business License and City/County Issued (1)

(Bidder to attach additional sheet(s) if necessary)

(1) Submit this information with sealed bid.

END OF DOCUMENT

DOCUMENT 00 45 13

**NON-COLLUSION AFFIDAVIT**  
**Public Contract Code Section 7106**

TO BE EXECUTED BY BIDDER AND SUBMITTED WITH BID

STATE OF CALIFORNIA                    )  
  ) ss.  
COUNTY OF \_\_\_\_\_)

\_\_\_\_\_ being first  
duly sworn deposes and says that he or she is \_\_\_\_\_  
of \_\_\_\_\_, the Bidder making the foregoing Bid that the Bid is not  
made in the interest of, or on behalf of, any undisclosed person, partnership, company,  
association, organization, or corporation; that the Bid is genuine and not collusive or sham; that  
the Bidder has not directly or indirectly induced or solicited any other bidder to put in a false or  
sham bid, and has not directly or indirectly colluded, conspired, connived, or agreed with any  
bidder or anyone else to put in a sham bid, or that anyone shall refrain from bidding; that the  
Bidder has not in any manner, directly or indirectly, sought by agreement, communication, or  
conference with anyone to fix the Bid price of the Bidder or any other bidder, or to fix any  
overhead, profit, or cost element of the Bid price, or of that of any other bidder, or to secure any  
advantage against the County of anyone interested in the proposed Contract; that all statements  
contained in the bid are true; and, further, that the Bidder has not, directly or indirectly,  
submitted his or her Bid price or any breakdown thereof, or the contents thereof, or divulged  
information or data relative thereto, or paid, and will not pay, any fee to any corporation,  
partnership, company association, organization, bid depository, or to any member or agent  
thereof to effectuate a collusive or sham bid.

I certify and declare under penalty of perjury under the laws of the State of California that  
all the foregoing information in this Non-Collusion Affidavit is true and correct.

Date: \_\_\_\_\_

Proper Name of Bidder: \_\_\_\_\_

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

**(ATTACH NOTARIAL ACKNOWLEDGMENT FOR THE ABOVE SIGNATURE)**

END OF DOCUMENT

DOCUMENT 00 45 26

**WORKERS' COMPENSATION CERTIFICATION**

CONTRACT NO.: 901911 As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs between County of Alameda (the "County" or the "Owner") and \_\_\_\_\_ (the "Contractor" or the "Bidder") (the "Contract").

Labor Code section 3700 in relevant part provides:

Every employer except the State shall secure the payment of compensation in one or more of the following ways:

- a. By being insured against liability to pay compensation by one or more insurers duly authorized to write compensation insurance in this state.
- b. By securing from the Director of Industrial Relations a certificate of consent to self-insure, which may be given upon furnishing proof satisfactory to the Director of Industrial Relations of ability to self-insure and to pay any compensation that may become due to his employees.

I am aware of the provisions of section 3700 of the Labor Code which require every employer to be insured against liability for workers' compensation or to undertake self-insurance in accordance with the provisions of that code, and I will comply with such provisions before commencing the performance of the Work of this Contract.

Date: \_\_\_\_\_

Proper Name of Contractor: \_\_\_\_\_

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

(In accordance with Article 5 - commencing at section 1860, chapter 1, part 7, division 2 of the Labor Code, the above certificate must be signed and filed with the awarding body prior to performing any Work under this Contract.)

END OF DOCUMENT

DOCUMENT 00 45 46.01

**PREVAILING WAGE AND  
RELATED LABOR REQUIREMENTS CERTIFICATION**

CONTRACT NO.: 901911 As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs between County of Alameda (the "County" or the "Owner") and \_\_\_\_\_ (the "Contractor" or the "Bidder") (the "Contract").

I hereby certify that I will conform to the State of California Public Works Contract requirements regarding prevailing wages, benefits, on-site audits with 48-hours notice, payroll records, and apprentice and trainee employment requirements, for all Work on the above Project.

I hereby acknowledge that County will use the Alameda County Contract Compliance System, including the Elation Systems, Inc. program, to monitor contract labor compliance and Local Hiring Program compliance monitoring. Contractor shall use these Compliance Systems to meet County's requirements, and shall participate in training as directed by County in order to become and remain competent in the use of the Compliance Systems. Costs associated with the Alameda County Contract Compliance System, including the Elation Systems, Inc. programs shall be borne by Contractor and shall not increase the cost of the Contract.

Date: \_\_\_\_\_

Proper Name of Contractor: \_\_\_\_\_

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

END OF DOCUMENT

DOCUMENT 00 45 46.04

**HAZARDOUS MATERIALS CERTIFICATION**

CONTRACT NO.: 901911 As-needed Heating, Ventilation, and Air Conditioning (HVAC)  
Maintenance and Repairs ("Contract") between the County of Alameda ("County") and \_\_\_\_\_  
\_\_\_\_\_  
("Contractor")

1. Contractor hereby certifies that no Asbestos, or Asbestos-Containing Materials, polychlorinated biphenyl (PCB), or any material listed by the federal or state Environmental Protection Agency or federal or state health agencies as a hazardous material, or any other material defined as being hazardous under federal or state laws, rules, or regulations ("New Hazardous Material"), shall be furnished, installed, or incorporated in any way into the Project or in any tools, devices, clothing, or equipment used to affect any portion of Contractor's work on the Project for County.
2. Contractor further certifies that it has instructed its employees with respect to the above-mentioned standards, hazards, risks, and liabilities.
3. Asbestos and/or asbestos-containing material shall be defined as all items containing detectable amounts of, but not limited to, chrysotile, crocidolite, amosite, anthophyllite, tremolite, and actinolite.
4. Any disputes involving the question of whether or not material is New Hazardous Material shall be settled by electron microscopy or other appropriate and recognized testing procedure, at the County's determination. The costs of any such tests shall be paid by Contractor if the material is found to be New Hazardous Material.
5. All Work or materials found to be New Hazardous Material or Work or material installed with equipment containing "New Hazardous Material" will be immediately rejected and this Work will be removed at Contractor's expense at no additional cost to the County.
6. Contractor has read and understood the document Hazardous Materials Procedures & Requirements, and shall comply with all the provisions outlined therein.

Date: \_\_\_\_\_

Proper Name of Contractor: \_\_\_\_\_

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

END OF DOCUMENT



## IMPORTED MATERIALS CERTIFICATION

delivered, and/or supplied or that will be provided, delivered, and/or supplied by this Firm to the Project Site are free of any and all hazardous material as defined in section 25260 of the Health and Safety Code. I further certify that I am authorized to make this certification on behalf of the Firm.

Date: \_\_\_\_\_

Proper Name of Contractor: \_\_\_\_\_

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

END OF DOCUMENT

DOCUMENT 00 51 00

**NOTICE OF AWARD**

Dated: \_\_\_\_\_ 2020

To: \_\_\_\_\_  
(Contractor)

To: \_\_\_\_\_  
(Address)

From: The County of Alameda

CONTRACT: As-needed Heating, Ventilation, and Air Conditioning (HVAC)  
Maintenance and Repairs

( "Contract").

Contractor has been awarded the referenced Contract on \_\_\_\_\_, 20\_\_\_\_, by action of  
the County's Board of Supervisors. The Contract Price is \_\_\_\_\_  
\_\_\_\_\_ Dollars (\$\_\_\_\_\_), and includes alternates  
\_\_\_\_\_.

Three (3) copies of each of the Contract Documents (except Drawings) accompany this Notice of Award. Three (3) sets of the Drawings will be delivered separately or otherwise made available. Additional copies are available at cost of reproduction.

The Bidder to whom Contract is awarded shall execute and submit the following documents by 5:00 p.m. of the **SEVENTH (7<sup>TH</sup>)** Calendar day following the date of the Notice of Award. Failure to properly and timely submit these documents entitles County to reject the bid as non-responsive.

- a. Agreement: To be executed by successful Bidder. Submit four (4) copies, each bearing an original signature.
- b. Escrow of Bid Documentation: This must include all required documentation. See the document Escrow of Bid Documentation for more information.
- c. Performance Bond (100%): On the form provided in the Contract Documents and fully executed as indicated on the form.
- d. Payment Bond (100%) (Contractor's Labor and Material Payment Bond): On the form provided in the Contract Documents and fully executed as indicated on the form.

- e. Insurance Certificates and Endorsements as required.
- f. Workers' Compensation Certification.
- g. Prevailing Wage and Related Labor Requirements Certification.
- h. Hazardous Materials Certification.
- i. Imported Materials Certification.
- j. Completed, signed Document 00 52 13.1 Debarment And Suspension Certification Form

Failure to comply with these conditions within the time specified will entitle County to consider your bid abandoned, to annul this Notice of Award, and to declare your Bid Security forfeited, as well as any other rights the County may have against the Contractor.

After you comply with those conditions, County will return to you one fully signed counterpart of the Agreement.

The County of Alameda

BY: \_\_\_\_\_

NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

END OF DOCUMENT

DOCUMENT 00 51 13

**NOTICE OF INTENT TO AWARD**

[DATE]  
[NAME]  
[COMPANY]  
[ADDRESS]  
[CITY, STATE ZIP]

SUBJECT: **INTENT TO AWARD A CONTRACT FOR CONTRACT NO. 901911**

Thank you for your participation and interest in the County of Alameda. Based on its evaluation and acceptance of the bids submitted, GSA will be recommending to its Board of Supervisors that the contract for As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs (Master Contract No. 901911; Procurement Contract No. XXXXX) be awarded to [CONTRACTOR].

GSA's recommendation to accept and award a contract should go before the Board on Tuesday, [DATE]. Upon Board approval a draft contract will be submitted to the awardee for review. A signed contract will be issued along with an Agreement Form and Notice to Proceed. The County is unable to pay for goods and services received without a signed contract.

Below is a summary of all bids/proposals received for this project.

Bidder	Location	Bid Price*

Please refer to Document 00 21 13 - Instructions to Bidders for additional information.

For information on other contracting opportunities please visit our website at [http://www.acgov.org/gsa/purchasing/bid\\_content/ContractOpportunities.jsp](http://www.acgov.org/gsa/purchasing/bid_content/ContractOpportunities.jsp) for Current Contracting Opportunities.

The County of Alameda

BY: \_\_\_\_\_

NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

END OF DOCUMENT

DOCUMENT 00 52 13

**AGREEMENT FORM – STIPULATED SUM**  
**(SINGLE-PRIME CONTRACT)**

THIS AGREEMENT IS MADE AND ENTERED INTO THIS \_\_\_\_\_ DAY OF \_\_\_\_\_, 20\_\_\_\_, by and between the County of Alameda (“County”) and \_\_\_\_\_ (“Contractor”) (“Agreement”).

**WITNESSETH:** That the parties hereto have mutually covenanted and agreed, and by these presents do covenant and agree with each other, as follows:

- 1. The Work:** Contractor agrees to furnish all tools, equipment, apparatus, facilities, labor, and material necessary to perform and complete in a good and workmanlike manner, the work of

CONTRACT: As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

(“Project” or “Contract” or “Work”)

for which the Drawings and Specifications are identified by the signature of the parties to this Agreement. It is understood and agreed that the Work shall be performed and completed as required in the Contract Documents including, without limitation, the Drawings and Specifications and Exhibit D Cabling Task Order, under the direction and supervision of, and subject to, the approval of County or its authorized representative.

- 2. The Contract Documents:** The complete Contract consists of all Contract Documents as defined in the General Conditions and incorporated herein by this reference. Any and all obligations of the County and Contractor are fully set forth and described in the Contract Documents. All Contract Documents are intended to cooperate so that any Work called for in one and not mentioned in the other or vice versa is to be executed the same as if mentioned in all Contract Documents.
- 3. Interpretation of Contract Documents:** Should any question arise concerning the intent or meaning of Contract Documents, including the Drawings or Specifications, the question shall be submitted to the County for interpretation. If a conflict exists in the Contract Documents, modifications, beginning with the most recent, shall control over this Agreement, which shall control over the Special Conditions, which shall control over the General Conditions, which shall control over the remaining Division 00 documents, which shall control over Division 01 Documents, which shall control over Division 02 through Division 49 documents, which shall control over figured dimensions, which shall control over large-scale drawings, which shall control over small-scale drawings. In no

case shall a document calling for lower quality and/or quantity material or workmanship control. The decision of County in the matter shall be final.

4. **Contract Term:** The term of this Agreement shall be from \_\_\_\_\_ through \_\_\_\_\_.
5. **Extension:** This agreement may be extended for an additional two years by mutual agreement of the County and the Contractor.
6. **Completion-Extension Of Time:** Should the Contractor fail to complete this Contract, and the Work provided herein, within the time fixed for completion, due allowance being made for the contingencies provided for herein, the Contractor shall become liable to the County for all loss and damage that the County may suffer on account thereof. The Contractor shall coordinate its work with the Work of all other contractors. County shall not be liable for delays resulting from Contractor's failure to coordinate its Work with other contractors in a manner that will allow timely completion of Contractor's Work. Contractor shall be liable for delays to other contractors caused by Contractor's failure to coordinate its Work with the work of other contractors.
7. **Liquidated Damages:** Time is of the essence for all work under this Agreement. It is hereby understood and agreed that it is and will be difficult and/or impossible to ascertain and determine the actual damage that County will sustain in the event of and by reason of Contractor's delay; therefore, Contractor agrees that it shall pay to the County the sum of three hundred eighty dollars (\$380.00) per day as liquidated damages for each and every day's delay beyond the time herein prescribed in finishing the Work. It is hereby understood and agreed that this amount is not a penalty.

In the event any portion of the liquidated damages is not paid to County, County may deduct that amount from any money due or that may become due the Contractor under this Agreement. County's right to assess liquidated damages is as indicated herein and in the General Conditions.

The time during which the Contract is delayed for cause as hereinafter specified may extend the time of completion for a reasonable time as County may grant. This provision does not exclude the recovery of damages for delay by either party under other provisions in the Contract Documents.

8. **Indemnity:** To the fullest extent permitted by law (including, without limitation, California Civil Code Section 2782), Contractor shall defend (with legal counsel reasonably acceptable to the County), indemnify and hold harmless County and its officers, agents, departments, officials, representatives and employees (collectively "Indemnitees") from and against any and all claims, loss, cost, damage, injury (including, without limitation, injury to or death of an employee of Contractor or its Subcontractors), expense and liability of every kind, nature and description

(including, without limitation, incidental and consequential damages, court costs, attorneys' fees, litigation expenses and fees of expert consultants or expert witnesses incurred in connection therewith and costs of investigation) which arises out of or is in any way connected to the performance of this agreement (collectively "Liabilities") except where such Liabilities are caused solely by the negligence or willful misconduct of any indemnitee. The County may participate in the defense of any such claim without relieving Contractor of any obligation hereunder. This indemnification, defense, and hold harmless obligation includes any failure or alleged failure by Contractor to comply with any provision of law or the Contract Documents, including, without limitation, any stop notice actions, or liens by the California Department of Labor Standards Enforcement. This indemnity obligation shall be for the full amount of all damage to County, including defense costs, and shall not be limited by any insurance limits.

8.1 Contractor shall defend (with legal counsel reasonably acceptable to the County), indemnify and hold harmless the Indemnitees from all loss, cost, damage, expense, liability or claims, in law or in equity, including attorneys' fees, court costs, litigation expenses and fees of expert consultants or expert witnesses, that may at any time arise for any infringement of the patent rights, copyright, trade secret, trade name, trademark, service mark or any other proprietary right of any person or persons in consequence of the use by County, or any of the other Indemnitees, of articles or Services to be supplied in the performance of this Agreement.

8.2 Contractor shall place in its subcontracting agreements and cause its Subcontractors to agree to indemnities and insurance obligations in favor of County and other Indemnitees in the exact form and substance of those contained in this Agreement. Contractor shall require all subcontractors to comply with all indemnification and insurance requirements of this agreement, including, without limitation, Exhibit C. Contractor shall verify subcontractor's compliance.

9. **Loss Or Damage:** County and its authorized representatives shall not in any way or manner be answerable or suffer loss, damage, expense, or liability for any loss or damage that may happen to the Work, or any part thereof, or in or about the same during its construction and before acceptance, and the Contractor shall assume all liabilities of every kind or nature arising from the Work, either by accident, negligence, theft, vandalism, or any cause whatever; and shall hold County and its authorized representatives harmless from all liability of every kind and nature arising from accident, negligence, or any cause whatever.
10. **Insurance and Bonds:** Contractor shall provide all required certificates of insurance, and payment and performance bonds as evidence thereof.
11. **Prosecution of Work:** If the Contractor should neglect to prosecute the Work properly or fail to perform any provisions of this contract, County, may, pursuant to the General Conditions and without prejudice to any other remedy it may have, make good such deficiencies and may deduct the cost thereof from the payment then or thereafter due the Contractor.



12. **Authority of Architect:** Contractor hereby acknowledges that the Architect has authority to approve and/or stop Work if the Contractor's Work does not comply with the requirements of the Contract Documents and all applicable laws. The Contractor shall be liable for any delay caused by its non-compliant Work.
13. **Assignment of Contract:** Neither the Contract, nor any part thereof, nor any moneys due or to become due thereunder, may be assigned by the Contractor without the written approval of the County, nor without the written consent of the Surety on the Contractor's Performance Bond (the "Surety"), unless the Surety has waived in writing its right to notice of assignment.
14. **Classification Of Contractor's License:** Contractor hereby acknowledges that it currently holds valid Type **C-4 and C-20 and C-38** Contractor's license(s) issued by the State of California, Contractor's State Licensing Board, in accordance with division 3, chapter 9, of the Business and Professions Code and in the classification called for in the Contract Documents.
15. It is County policy to minimize the expenditure of County funds on goods and services produced by any entity which buys, sell, leases or distributes commodities and/or professional services to (1) the government of Burma; or (2) any entity organized under the laws of Burma; or (3) any entity which does business with any private or public entity located in Burma, or conducts operations in Burma. Contractors are urged to comply with the policy in making purchases and subcontracts. (ref. Alameda County, Cal., Adm. Code Title.4, §4.32.050(B),(F) )
16. **Payment of Prevailing Wages:** The Contractor and all Subcontractors under the Contractor shall pay all workers on all Work performed pursuant to this Contract not less than the general prevailing rate of per diem wages and the general prevailing rate for holiday and overtime work as determined by the Director of the Department of Industrial Relations, State of California, for the type of work performed and the locality in which the work is to be performed within the boundaries of County, pursuant to §§ 1770 et seq. of the California Labor Code copies of the prevailing rate of per diem wages are on file at the Alameda County General Services Agency, 1401 Lakeside Drive, Oakland, California 94612, and will be made available to any interested party upon request.
17. This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations. The following requirements apply to this bid and contract:
  - A. No contractor or subcontractor may be listed on a bid proposal for a public works project (submitted on or after March 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code section 1771.1(a)].

- B. No contractor or subcontractor may be awarded a contract for public work on a public works project (awarded on or after April 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5

- 18. Contract Price:** In consideration of the foregoing covenants, promises, and agreements on the part of the Contractor, and the strict and literal fulfillment of each and every covenant, promise, and agreement, and as compensation agreed upon for the Work and construction, erection, and completion as aforesaid, County covenants, promises, and agrees that it will well and truly pay and cause to be paid to the Contractor in full, and as the full Contract Price and compensation for construction, erection, and completion of the Work hereinabove agreed to be performed by the Contractor, the following price:

<u><b>Not To Exceed</b></u>	<u><b>Dollars</b></u>
-----------------------------	-----------------------

(\$ \_\_\_\_\_),

in lawful money of the United States, which sum is to be paid according to the schedule provided by the Contractor and accepted by County and subject to additions and deductions as provided in the Contract. This amount supersedes any previously stated and/or agreed to amount(s). The County neither warrants nor guarantees any minimum or maximum compensation to Contractor under this Agreement.

- 19. Severability:** If any term, covenant, condition, or provision in any of the Contract Documents is held by a court of competent jurisdiction to be invalid, void or unenforceable, the remainder of the provisions in the Contract Documents shall remain in full force and effect and shall in no way be affected, impaired, or invalidated thereby.
- 20. Contractor Registration:** Contractor represents that it is registered and qualified to perform public work pursuant to Labor Code § 1725.5. Contractor is required to maintain DIR registration as required by Labor Code § 1725.5, without interruption, as long as Contractor is performing work on the Project. Contractor is further obligated to ensure that subcontractors of every tier are registered with the DIR as required by Labor Code § 1725.5 as long as those subcontractors are performing work on the Project. Contractor will prohibit any unregistered subcontractor from performing work on the Project.

IN WITNESS WHEREOF, accepted and agreed on the date indicated above:

**CONTRACTOR**

**COUNTY OF ALAMEDA**

By: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Title: \_\_\_\_\_

ALAMEDA COUNTY GSA-BMD

AGREEMENT FORM – STIPULATED SUM  
(SINGLE-PRIME CONTRACT)

NOTE: If the party executing this Contract is a corporation, a certified copy of the by-laws, or of the resolution of the Board of Directors, authorizing the officers of said corporation to execute the Contract and the bonds required thereby must be attached hereto.

Approved as to form: \_\_\_\_\_  
(Deputy) County Counsel

END OF DOCUMENT

DOCUMENT 00 52 13.1

**COUNTY OF ALAMEDA**  
**DEBARMENT AND SUSPENSION CERTIFICATION FORM**

The bidder, under penalty of perjury, certifies that, except as noted below, bidder, its Principal, and any named and unnamed subcontractor:

- Is not currently under suspension, debarment, voluntary exclusion, or determination of ineligibility by any federal agency;
- Has not been suspended, debarred, voluntarily excluded or determined ineligible by any federal agency within the past three years;
- Does not have a proposed debarment pending; and
- Has not been indicted, convicted, or had a civil judgment rendered against it by a court of competent jurisdiction in any matter involving fraud or official misconduct within the past three years.

If there are any exceptions to this certification, insert the exceptions in the following space.

Exceptions will not necessary result in denial of award, but will be considered in determining bidder responsibility. For any exception noted above, indicate below to whom it applies, initiating agency, and dates of action.

Notes: Providing false information may result in criminal prosecution or administrative sanctions. The above certification is part of the Proposal. Signing this Proposal on the signature portion thereof shall also constitute signature of this Certification.

BIDDER: \_\_\_\_\_

PRINCIPAL: \_\_\_\_\_

TITLE: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

DOCUMENT 00 55 00

**NOTICE TO PROCEED**

Dated: \_\_\_\_\_, 2020

TO: \_\_\_\_\_  
(Contractor)

ADDRESS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

CONTRACT: As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

CONTRACT NO.: 901911 between County of Alameda and Contractor ("Contract").

You are notified that the Contract Time under the above Contract will commence to run on \_\_\_\_\_, 20\_\_\_\_. By that date, you are to start performing your obligations under the Contract Documents. In accordance with the Agreement executed by Contractor, the date of completion is \_\_\_\_\_, 20\_\_\_\_.

You must submit the following documents by 5:00 p.m. of the **TENTH (10<sup>TH</sup>)** business day following the date of this Notice to Proceed:

- a. Contractor's preliminary schedule of construction.
- b. Contractor's preliminary schedule of values for all of the Work.
- c. Contractor's preliminary schedule of submittals, including Shop Drawings, Product Data, and Samples submittals
- d. Contractor's Safety Plan specifically adapted for the Project.
- e. A complete subcontractors list, including the name, address, telephone number, facsimile number, California State Contractors License number, classification, and monetary value of all Subcontracts.

Thank you. We look forward to a very successful Project.

COUNTY OF ALAMEDA

BY: \_\_\_\_\_

NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

END OF DOCUMENT

DOCUMENT 00 56 00

**ESCROW OF BID DOCUMENTATION**

**1. Requirement to Escrow Bid Documentation**

- a. Contractor shall submit, within **SEVEN (7)** calendar days after the date of the Notice of Award, one copy of all documentary information received or generated by Contractor in preparation of bid prices for this Contract, as specified herein. This material is referred to herein as "Escrow Bid Documentation." The Escrow Bid Documentation of the Contractor will be held in escrow for the duration of the Contract.
- b. Contractor agrees, as a condition of award of the Contract, that the Escrow Bid Documentation constitutes all written information used in the preparation of its bid, and that no other written bid preparation information shall be considered in resolving disputes or claims. Contractor also agrees that nothing in the Escrow Bid Documentation shall change or modify the terms or conditions of the Contract Documents.
- c. The Escrow Bid Documentation will not be opened by County except as indicated herein. The Escrow Bid Documentation will be used only for the resolution of change orders and claims disputes.
- d. Contractor's submission of the Escrow Bid Documentation, as with the bonds and insurance documents required, is considered an essential part of the Contract award. Should the Contractor fail to make the submission within the allowed time specified above, County may deem the Contractor to have failed to enter into the Contract, and the Contractor shall forfeit the amount of its bid security, accompanying the Contractor's bid, and County may award the Contract to the next lowest responsive responsible bidder.
- e. NO PAYMENTS WILL BE MADE, NOR WILL COUNTY ACCEPT PROPOSED CHANGE ORDERS UNTIL THE ABOVE REQUIRED INFORMATION IS SUBMITTED AND APPROVED.
- f. The Escrow Bid Documentation shall be submitted in person by an authorized representative of the Contractor to County.

**2. Ownership of Escrow Bid Documentation**

- a. The Escrow Bid Documentation is, and shall always remain, the property of Contractor, subject to review by County, as provided herein.

- b. Escrow Bid Documentation constitute trade secrets, not known outside Contractor's business, known only to a limited extent and only by a limited number of employees of Contractor, safeguarded while in Contractor's possession, extremely valuable to Contractor, and could be extremely valuable to Contractor's competitors by virtue of it reflecting Contractor's contemplated techniques of construction. Subject to the provisions herein, County agrees to safeguard the Escrow Bid Documentation, and all information contained therein, against disclosure to the fullest extent permitted by law.

### **3. Format and Contents of Escrow Bid Documentation**

- a. Contractor may submit Escrow Bid Documentation in its usual cost-estimating format; a standard format is not required. The Escrow Bid Documentation shall be submitted in the English language.
- b. Escrow Bid Documentation must clearly itemize the estimated costs of performing the work of each bid item contained in the bid schedule, separating bid items into sub-items as required to present a detailed cost estimate and allow a detailed cost review. The Escrow Bid Documentation shall include all subcontractor bids or quotes, supplier bids or quotes, quantity takeoffs, crews, equipment, calculations of rates of production and progress, copies of quotes from subcontractors and suppliers, and memoranda, narratives, add/deduct sheets, and all other information used by the Contractor to arrive at the prices contained in the bid proposal. Estimated costs should be broken down into Contractor's usual estimate categories such as direct labor, repair labor, equipment ownership and operation, expendable materials, permanent materials, and subcontract costs as appropriate. Plant and equipment and indirect costs should be detailed in the Contractor's usual format. The Contractor's allocation of indirect costs, contingencies, markup, and other items to each bid item shall be identified.
- c. All costs shall be identified. For bid items amounting to less than \$10,000, estimated unit costs are acceptable without a detailed cost estimate, provided that labor, equipment, materials, and subcontracts, as applicable, are included and provided that indirect costs, contingencies, and markup, as applicable, are allocated.
- d. Bid Documentation provided by County should not be included in the Escrow Bid Documentation unless needed to comply with the following requirements.

### **4. Submittal of Escrow Bid Documentation**

- a. The Escrow Bid Documentation shall be submitted by the Contractor in a sealed container within **SEVEN (7)** calendar days after the date of the Notice of Award. The container shall be clearly marked on the outside with the Contractor's name, date of submittal, project name and the words "Escrow Bid Documentation –



Intended to be opened in the presence of Authorized Representatives of Both County and Contractor".

- b. By submitting Escrow Bid Documentation, Contractor represents that the material in the Escrow Bid Documentation constitutes all the documentary information used in preparation of the bid and that the Contractor has personally examined the contents of the Escrow Bid Documentation container and has found that the documents in the container are complete.
- c. If Contractor's proposal is based upon subcontracting any part of the work, each subcontractor whose total subcontract price exceeds 5 percent of the total contract price proposed by Contractor, shall provide separate Escrow Documents to be included with those of Contractor. Those documents shall be opened and examined in the same manner and at the same time as the examination described above for Contractor.
- d. If Contractor wishes to subcontract any portion of the Work after award, County retains the right to require Contractor to submit Escrow Documents for the Subcontractor before the subcontract is approved.

**5. Storage, Examination and Final Disposition of Escrow Bid Documentation**

- a. The Escrow Bid Documentation will be placed in escrow, for the life of the Contract, in a mutually agreeable institution. The cost of storage will be paid by Contractor for the duration of the project until final Contract payment. The storage facilities shall be the appropriate size for all the Escrow Bid Documentation and located conveniently to both County's and Contractor's offices.
- b. The Escrow Bid Documentation shall be examined by both County and Contractor, at any time deemed necessary by either County or Contractor, to assist in the negotiation of price adjustments and change orders or the settlement of disputes and claims. In the case of legal proceedings, Escrow Bid Documentation shall be used subject to the terms of an appropriate protective order if requested by Contractor and ordered by a court of competent jurisdiction. Examination of the Escrow Bid Documentation is subject to the following conditions:
  - (1) As trade secrets, the Escrow Bid Documentation is proprietary and confidential to the extent allowed by law.
  - (2) County and Contractor shall each designate, in writing to the other party **SEVEN (7)** calendar days prior to any examination, the names of representatives who are authorized to examine the Escrow Bid Documentation. No other person shall have access to the Escrow Bid Documentation.

- (3) Access to the documents may take place only in the presence of duly designated representatives of the County and Contractor. If Contractor fails to designate a representative or appear for joint examination on **SEVEN (7)** calendar days notice, then the County representative may examine the Escrow Bid Documents alone upon an additional **THREE (3)** calendar days notice if a representative of the Contractor does not appear at the time set.
  - (4) If a subcontractor has submitted sealed information to be included in the Escrow Bid Documents, access to those documents may take place only in the presence of a duly designated representative of the County, Contractor and that subcontractor. If that subcontractor fails to designate a representative or appear for joint examination on **SEVEN (7)** calendar days notice, then the County representative and/or the Contractor may examine the Escrow Bid Documentation without that subcontractor present upon an additional **THREE (3)** calendar days notice if a representative of that subcontractor does not appear at the time set.
- c. The Escrow Bid Documentation will be returned to Contractor at such time as the Contract has been completed and final settlement has been achieved.

END OF DOCUMENT

DOCUMENT 00 57 00

**ESCROW AGREEMENT FOR  
SECURITY DEPOSITS IN LIEU OF RETENTION**

Public Contract Code Section 22300

This Escrow Agreement ("Escrow Agreement") is made and entered into this \_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, by and between County of Alameda, whose address is \_\_\_\_\_, \_\_\_\_\_, California ("County"); and

\_\_\_\_\_, whose place of business is located at \_\_\_\_\_, ("Contractor"); and

\_\_\_\_\_, a state or federally chartered bank in the state of California, whose place of business is located at \_\_\_\_\_, ("Escrow Agent").

For the consideration hereinafter set forth, County, Contractor, and Escrow Agent agree as follows:

1. Pursuant to section 22300 of Public Contract Code of the State of California, which is hereby incorporated by reference, Contractor has the option to deposit securities with Escrow Agent as a substitute for retention earnings required to be withheld by County pursuant to the Construction Contract No. \_\_\_\_\_ entered into between County and Contractor for the \_\_\_\_\_ [Name of Project], in the amount of \_\_\_\_\_ dated, \_\_\_\_\_, 20\_\_\_\_, (the "Contract"). Alternatively, on written request of Contractor, County shall make payments of the retention earnings directly to Escrow Agent. When Contractor deposits the securities as a substitute for Contract earnings, Escrow Agent shall notify County within ten (10) calendar days of the deposit. The market value of the securities at the time of substitution and at all times from substitution until the termination of the Escrow Agreement shall be at least equal to the cash amount then required to be withheld as retention under terms of Contract between County and Contractor.

Securities shall be held in name of County of Alameda, and shall designate Contractor as beneficial owner.

2. County shall make progress payments to Contractor for those funds which otherwise would be withheld from progress payments pursuant to Contract provisions, provided that Escrow Agent holds securities in form and amount specified above.
3. When County makes payment of retention earned directly to Escrow Agent, Escrow Agent shall hold them for the benefit of Contractor until the time that the escrow created

ALAMEDA COUNTY GSA-BMD

ESCROW AGREEMENT FOR  
SECURITY DEPOSITS IN LIEU OF RETENTION  
DOCUMENT 00 57 00

under this Escrow Agreement is terminated. Contractor may direct the investment of the payments into securities. All terms and conditions of this Escrow Agreement and the rights and responsibilities of the Parties shall be equally applicable and binding when County pays Escrow Agent directly.

4. Contractor shall be responsible for paying all fees for the expenses incurred by Escrow Agent in administering the Escrow Account, and all expenses of County. These expenses and payment terms shall be determined by County, Contractor, and Escrow Agent.
5. Interest earned on securities or money market accounts held in escrow and all interest earned on that interest shall be for sole account of Contractor and shall be subject to withdrawal by Contractor at any time and from time to time without notice to County.
6. Contractor shall have the right to withdraw all or any part of the principal in the Escrow Account only by written notice to Escrow Agent accompanied by written authorization from County to Escrow Agent that County consents to withdrawal of amount sought to be withdrawn by Contractor.
7. County shall have the right to draw upon the securities and/or withdraw amounts from the Escrow Account in event of default by Contractor. Upon seven (7) days written notice to Escrow Agent from County of the default, if applicable, Escrow Agent shall immediately convert the securities to cash and shall distribute the cash as instructed by County.
8. Upon receipt of written notification from County certifying that the Contract is final and complete, and that Contractor has complied with all requirements and procedures applicable to the Contract, Escrow Agent shall release to Contractor all securities and interest on deposit less escrow fees and charges of the Escrow Account. The escrow shall be closed immediately upon disbursement of all monies and securities on deposit and payments of fees and charges.
9. Escrow Agent shall rely on written notifications from County and Contractor pursuant to Paragraphs 5 through 8, inclusive, of this Escrow Agreement and County and Contractor shall hold Escrow Agent harmless from Escrow Agent's release and disbursement of securities and interest as set forth above.
10. Names of persons who are authorized to give written notice or to receive written notice on behalf of County and on behalf of Contractor in connection with the foregoing, and exemplars of their respective signatures are as follows:

On behalf of County:

On behalf of Contractor:

\_\_\_\_\_  
Title

\_\_\_\_\_  
Title

ALAMEDA COUNTY GSA-BMD

ESCROW AGREEMENT FOR  
SECURITY DEPOSITS IN LIEU OF RETENTION  
DOCUMENT 00 57 00

**Alameda County General Services Agency  
AS-NEEDED HVAC MAINTENANCE  
AND REPAIRS**

**MASTER CONTRACT ID #901911**

Name

Name

Signature

Signature

Address

Address

On behalf of Escrow Agent:

Title

Name

Signature

Address

At the time of Escrow Account is opened, County and Contractor shall deliver to Escrow Agent a fully executed of this Agreement.

IN WITNESS WHEREOF, the parties have executed this Agreement by their proper officers on the date first set forth above.

On behalf of County:

On behalf of Contractor:

Title

Title

Name

Name

Signature

Signature

Address

Address

On behalf of Escrow Agent:

Title

Name

Signature

Address

**ALAMEDA COUNTY GSA-BMD**

**ESCROW AGREEMENT FOR  
SECURITY DEPOSITS IN LIEU OF RETENTION  
DOCUMENT 00 57 00**

**END OF DOCUMENT**

DOCUMENT 00 61 13.13

**PERFORMANCE BOND FORM**  
**(100% of Contract Price)**

**(Note: Bidders must use this form, NOT a surety company form.)**

KNOW ALL PERSONS BY THESE PRESENTS:

That WHEREAS, the Board of Supervisors of the County of Alameda ("County") and \_\_\_\_\_, ("Principal") have entered into a contract for the furnishing of all materials and labor, services and transportation, necessary, convenient, and proper to perform the following project:

As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

( "Contract")

which Contract dated \_\_\_\_\_, 20\_\_\_\_, and all of the Contract Documents attached to or forming a part of the Contract, are hereby referred to and made a part hereof, and

And WHEREAS, said Principal is required under the terms of the Contract to furnish a bond for the faithful performance of the Contract;

NOW, THEREFORE, the Principal and \_\_\_\_\_ ("Surety") are held and firmly bound unto the Board of County in the penal sum of \_\_\_\_\_ DOLLARS (\$ \_\_\_\_\_), lawful money of the United States, for the payment of which sum well and truly to be made we bind ourselves, our heirs, executors, administrators, successors, and assigns jointly and severally, firmly by these presents, to perform all the work required to complete the Project and to pay to County all damages County incurs as a result of the Principal's failure to perform all the Work required to complete the Project.

The condition of the obligation is such that, if the above bounden Principal, his or its heirs, executors, administrators, successors, or assigns, shall in all things stand to and abide by, and well and truly keep and perform the covenants, conditions, and agreements in the Contract and any alteration thereof made as therein provided, on his or their part to be kept and performed at the time and in the intent and meaning, and shall indemnify and save harmless County, its trustees, officers and agents, as therein stipulated, then this obligation shall become null and void, otherwise it shall be and remain in full force and virtue.

And the Surety, for value received, hereby stipulates and agrees that no change, extension of time, alteration, or addition to the terms of the contract or to the work to be performed

thereunder or the specifications accompanying the same shall in any way affect its obligation on this bond, and it does hereby waive notice of any such change, extension of time, alteration, or addition to the terms of the Contract or to the work or to the specifications.

IN WITNESS WHEREOF, two (2) identical counterparts of this instrument, each of which shall for all purposes be deemed an original thereof, have been duly executed by the Principal and Surety above named, on the \_\_\_\_ day of \_\_\_\_\_, 20\_\_.

(Affix Corporate Seal)

\_\_\_\_\_  
Principal

\_\_\_\_\_  
By

\_\_\_\_\_  
Surety

\_\_\_\_\_  
By

\_\_\_\_\_  
Name of California Agent of Surety

\_\_\_\_\_  
Address of California Agent of Surety

\_\_\_\_\_  
Telephone Number of California Agent of  
Surety

**Bidder must attach a Notarial Acknowledgment for all Surety's signatures and a Power of Attorney and Certificate of Authority for Surety. The California Department of Insurance must authorize the Surety to be an admitted surety insurer.**

END OF DOCUMENT



DOCUMENT 00 61 13.16

**PAYMENT BOND FORM**

**Contractor's Labor & Material Payment Bond  
(100% of Contract Price)**

**(Note: Bidders must use this form, NOT a surety company form.)**

KNOW ALL PERSONS BY THESE PRESENTS:

That WHEREAS, the Board of Supervisors of the County of Alameda ("County") and \_\_\_\_\_, ("Principal") have entered into a contract for the furnishing of all materials and labor, services and transportation, necessary, convenient, and proper to

As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and Repairs

("Contract")

which Contract dated \_\_\_\_\_, 20\_\_\_\_, and all of the Contract Documents attached to or forming a part of the Contract, are hereby referred to and made a part hereof, and

WHEREAS, pursuant to law and the Contract, the Principal is required, before entering upon the performance of the work, to file a good and sufficient bond with the body by which the Contract is awarded in an amount equal to 100 percent (100%) of the Maximum Contract Value, to secure the claims to which reference is made in sections 9000, 9100, 9356 through 9560, and 9564 of the Civil Code of California, and division 2, part 7, of the Labor Code of California.

NOW, THEREFORE, WE, the Principal and \_\_\_\_\_, ("Surety") are held and firmly bound unto all laborers, material men, and other persons referred to in said statutes in the sum of \_\_\_\_\_ Dollars (\$ \_\_\_\_\_), lawful money of the United States, being a sum not less than the total amount payable by the terms of Contract, for the payment of which sum well and truly to be made, we bind ourselves, our heirs, executors, administrators, successors, or assigns, jointly and severally, by these presents.

The condition of this obligation is that if the Principal or any of his or its subcontractors, of the heirs, executors, administrators, successors, or assigns of any, all, or either of them shall fail to pay for any labor, materials, provisions, provender, or other supplies, used in, upon, for or about the performance of the work contracted to be done, or for any work or labor thereon of any kind, or for amounts due under the Unemployment Insurance Act with respect to such work or labor, that the Surety will pay the same in an amount not exceeding the amount herein above set forth, and also in case suit is brought upon this bond, will pay a reasonable attorney's fee to be awarded

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

and fixed by the Court, and to be taxed as costs and to be included in the judgment therein rendered.

It is hereby expressly stipulated and agreed that this bond shall inure to the benefit of any and all persons, companies, and corporations entitled to file claims under sections 9000, 9100, 9356 through 9560, and 9564 of the Civil Code, so as to give a right of action to them or their assigns in any suit brought upon this bond.

Should the condition of this bond be fully performed, then this obligation shall become null and void; otherwise it shall be and remain in full force and affect.

And the Surety, for value received, hereby stipulates and agrees that no change, extension of time, alteration, or addition to the terms of Contract or the specifications accompanying the same shall in any manner affect its obligations on this bond, and it does hereby waive notice of any such change, extension, alteration, or addition.

IN WITNESS WHEREOF, two (2) identical counterparts of this instrument, each of which shall for all purposes be deemed an original thereof, have been duly executed by the Principal and Surety above named, on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_.

(Affix Corporate Seal)

\_\_\_\_\_  
Principal

\_\_\_\_\_  
By

\_\_\_\_\_  
Surety

\_\_\_\_\_  
By

\_\_\_\_\_  
Name of California Agent of Surety

\_\_\_\_\_  
Address of California Agent of Surety

\_\_\_\_\_  
Telephone Number of California Agent of Surety

**Bidder must attach a Notarial Acknowledgment for all Surety's signatures and a Power of Attorney and Certificate of Authority for Surety. The California Department of Insurance must authorize the Surety to be an admitted surety insurer.**

**END OF DOCUMENT**

DOCUMENT 00 65 19.26

**FINAL SETTLEMENT CERTIFICATE FORM**

THIS FINAL SETTLEMENT AGREEMENT AND RELEASE OF CLAIMS  
("Agreement and Release") IS MADE AND ENTERED INTO THIS \_\_\_\_\_ DAY  
OF \_\_\_\_\_, 20\_\_ by and between the County of Alameda ("County") and \_\_\_\_  
\_\_\_\_ ("Contractor"), whose place of  
business is \_\_\_\_\_.

RECITALS:

1. County and Contractor entered into CONTRACT NO.: 901911 ("Contract") in the County of Alameda, California.
2. The Work under the Contract has been completed.

NOW, THEREFORE, it is mutually agreed between County and Contractor as follows:

**AGREEMENT**

3. Contractor will only be assessed liquidated damages as detailed below:

Original Contract Sum	\$ _____
Modified Contract Sum	\$ _____
Payment to Date	\$ _____
Liquidated Damages	\$ _____
Payment Due Contractor	\$ _____
4. Subject to the provisions hereof, County shall forthwith pay to Contractor the undisputed sum of \$\_\_\_\_\_ (\_\_\_\_\_ Dollars and \_\_\_\_\_ Cents) under the Contract, less any amounts represented by any notice to withhold funds on file with County as of the date of such payment.
5. Contractor acknowledges and hereby agrees that there are no unresolved or outstanding claims in dispute against County arising from the performance of work under the Contract, except for the claims described in Paragraph 6 and continuing obligations described in Paragraph 8. It is the intention of the parties in executing this Agreement and Release that this Agreement and Release shall be effective as a full, final and general release of all claims, demands, actions, causes of action, obligations, costs, expenses, damages, losses and liabilities of

Contractor against County, all its respective agents, employees, inspectors, assignees and transferees except for the Disputed Claim is set forth in Paragraph 6 and continuing obligations described in Paragraph 8 hereof.

6. The following claims are disputed (hereinafter, the "Disputed Claims") and are specifically excluded from the operation of this Agreement and Release:

<u>Claim No.</u>	<u>Description of Claim</u>	<u>Amount of Claim</u>	<u>Date Claim Submitted</u>
------------------	-----------------------------	------------------------	-----------------------------

7. Consistent with California Public Contract Code section 7100, Contractor hereby agrees that, in consideration of the payment set forth in Paragraph 4 hereof, Contractor hereby releases and forever discharges County, all its agents, employees, inspectors, assignees, and transferees from any and all liability, claims, demands, actions, or causes of action of whatever kind or nature arising out of or in any way concerned with the Work under the Contract.
8. Guarantees and warranties for the Work, and any other continuing obligation of Contractor, shall remain in full force and effect as specified in the Contract Documents.
9. To the furthest extent permitted by California law, Contractor shall defend, indemnify, and hold harmless the County, its agents, representatives, officers, consultants, employees, trustees, and volunteers (the "indemnified parties") from any and all losses, liabilities, claims, suits, and actions of any kind, nature, and description, including, but not limited to, attorneys' fees and costs, directly or indirectly arising out of, connected with, or resulting from the performance of the Contract unless caused wholly by the sole negligence or willful misconduct of the indemnified parties.
10. Contractor hereby waives the provisions of California Civil Code section 1542 which provides as follows:

A GENERAL RELEASE DOES NOT EXTEND TO CLAIMS WHICH THE CREDITOR DOES NOT KNOW OR SUSPECT TO EXIST IN HIS OR HER FAVOR AT THE TIME OF EXECUTING THE RELEASE, WHICH IF KNOWN BY HIM OR HER MUST HAVE MATERIALLY AFFECTED HIS OR HER SETTLEMENT WITH THE DEBTOR.

11. The provisions of this Agreement and Release are contractual in nature and not mere recitals and shall be considered independent and severable. If any such provision or any part thereof shall be at any time held invalid in whole or in part under any federal, state, county, municipal, or other law, ruling, or regulations, then such provision, or part thereof, shall remain in force and effect to the extent

permitted by law, and the remaining provisions of this Agreement and Release shall also remain in full force and effect, and shall be enforceable.

- 12.** All rights of County shall survive completion of the Work or termination of Contract, and execution of this Release.

\* \* \* CAUTION: THIS IS A RELEASE - READ BEFORE EXECUTING \* \* \*

COUNTY OF ALAMEDA

TITLE: \_\_\_\_\_

NAME: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

CONTRACTOR

TITLE: \_\_\_\_\_

NAME: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

END OF DOCUMENT

DOCUMENT 00 65 36

**WARRANTY FORM**

\_\_\_\_\_("Contractor") hereby agrees that the \_\_\_\_\_  
\_\_\_\_\_("Work" of Contractor) which Contractor has installed for County of  
Alameda ("County") for the following project:

CONTRACT: As-needed Heating, Ventilation, and Air Conditioning (HVAC) Maintenance and  
Repairs

("Contract")

has been performed in accordance with the requirements of the Contract Documents and that the  
Work as installed will fulfill the requirements of the Contract Documents.

The undersigned agrees to repair or replace any or all of such Work that may prove to be defective in  
workmanship or material together with any other adjacent Work that may be displaced in connection  
with such replacement within a period of \_\_\_\_\_ year(s) from the date of completion as  
defined in Public Contract Code section 7107, subdivision (c), ordinary wear and tear and unusual  
abuse or neglect excepted. The date of completion is \_\_\_\_\_, 20\_\_.

In the event of the undersigned's failure to comply with the above-mentioned conditions within a  
reasonable period of time, as determined by County, but not later than seven (7) days after being  
notified in writing by County, the undersigned authorizes the County to proceed to have said defects  
repaired and made good at the expense of the undersigned. The undersigned shall pay the costs and  
charges therefor upon demand.

Date: \_\_\_\_\_

Proper Name of Contractor: \_\_\_\_\_

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

Representatives to be contacted for service subject to terms of Contract:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

END OF DOCUMENT



DOCUMENT 00 72 13

**GENERAL CONDITIONS**

**TABLE OF CONTENTS**

	<u>Page</u>
<b>1. CONTRACT TERMS AND DEFINITIONS .....</b>	<b>8</b>
1.1 Definitions .....	8
1.2 Laws Concerning The Contract .....	12
1.3 No Oral Agreements .....	12
1.4 No Assignment .....	12
1.5 Notice And Service Thereof.....	12
1.6 No Waiver .....	12
1.7 Substitutions For Specified Items .....	13
1.8 Materials and Work.....	13
<b>2. COUNTY.....</b>	<b>14</b>
2.1 Occupancy .....	14
<b>3. ARCHITECT .....</b>	<b>14</b>
3.1 Role and Authority.....	14
3.2 Interpretations .....	14
3.3 Laws .....	15
3.4 Communications .....	15
<b>4. CONSTRUCTION MANAGER.....</b>	<b>15</b>
4.1 Role and Authority.....	15
4.2 Authority to Reject.....	15
4.3 If No Construction Manager.....	15
<b>5. INSPECTIONS AND TESTS .....</b>	<b>15</b>
5.1 Tests and Inspections .....	15

5.2 Costs for After Hours and/or Off Site Inspections.....	16
6. <b>CONTRACTOR</b> .....	16
6.1 Status of Contractor .....	16
6.2 Contractor's Supervision.....	16
6.3 Duty to Provide Fit Workers .....	17
6.4 Purchase of Materials and Equipment.....	17
6.5 Documents On Work Site.....	18
6.6 Preservation of Records .....	18
6.7 Integration of Work.....	19
6.8 Obtaining of Permits and Licenses .....	19
6.9 Work to Comply With Applicable Laws and Regulations .....	19
6.10 Safety/Protection of Persons and Property .....	20
6.11 Working Evenings and Weekends .....	22
6.12 Badge Policy For Contractors.....	23
6.13 County Drug Policy - Drug Free Work Place.....	23
6.14 Cleaning Up.....	23
7. <b>SUBCONTRACTORS</b> .....	24
7.1 Contractor Shall Provide Subcontractor Information .....	24
7.2 No Contractual Relationship Between County and Subcontractors .....	24
7.3 Contractor Binds Every Subcontractor by Terms of Contract.....	24
7.4 No Waiver of Obligations .....	24
7.5 Contractor to Familiarize Itself with Laws.....	24
7.6 Subcontractor Substitutions.....	25
7.7 Subcontractor Coordination.....	25
7.8 Subcontractor Relations .....	25

7.9 Assignment or Termination .....	25
<b>8. OTHER CONTRACTS/CONTRACTORS.....</b>	<b>25</b>
8.1 County Right to Perform .....	25
8.2 Protection of Work.....	25
8.3 Coordination with Other Work .....	26
8.4 Measurement of Work Performed .....	26
8.5 Knowledge of Other Work .....	26
8.6 No Exclusive Occupancy of Site .....	26
<b>9. DRAWINGS AND SPECIFICATIONS .....</b>	<b>26</b>
9.1 List of all Drawings.....	26
9.2 Technical and Trade Words.....	26
9.3 Trade Name or Trade Term .....	26
9.4 The Naming of any Material and/or Equipment Shall Mean Furnishing.....	27
9.5 Contract Documents are Complementary .....	27
9.6 Drawings and Specifications are Intended to Comply With All Laws .....	27
9.7 Plans, Drawings, Designs, Specifications are County Property .....	27
9.8 Order of Precedence.....	27
9.9 Resolution of Discrepancy or Ambiguity.....	27
9.10 County Clarification.....	28
<b>10. CONTRACTOR’S SUBMITTALS AND SCHEDULES.....</b>	<b>28</b>
10.1 Schedule of Work, Schedule of Submittals, and Schedule of Values.....	28
10.2 Monthly Progress Schedule(s).....	30
10.3 Material Safety Data Sheets (MSDS) .....	31
<b>11. SITE ACCESS, CONDITIONS, AND REQUIREMENTS .....</b>	<b>31</b>
11.1 Site Investigation .....	31

11.2 Soils Investigation Report .....	31
11.3 Access to Work.....	31
11.4 Layout and Field Engineering.....	32
11.5 Utilities.....	32
11.6 Sanitary Facilities.....	32
11.7 Surveys.....	32
11.8 Regional Notification Center.....	32
11.9 Existing Utility Lines.....	32
11.10 Notification .....	33
11.11 Hazardous Materials .....	33
11.12 No Signs.....	33
12. <b>TRENCHES</b> .....	33
12.1 Trenches Greater Than Five Feet.....	33
12.2 Excavation Safety .....	34
12.3 No Tort Liability of County .....	34
12.4 No Excavation Without Permits.....	34
12.5 Discovery of Hazardous Waste and/or Unusual Conditions .....	34
13. <b>INSURANCE AND BONDS</b> .....	35
13.1 Insurance .....	35
13.2 Contract Security - Bonds .....	37
14. <b>WARRANTY/GUARANTEE/INDEMNITY</b> .....	37
14.1 Warranty/Guarantee .....	37
14.2 Indemnity.....	38
15. <b>TIME</b> .....	39
15.1 Notice to Proceed.....	39

15.2 Computation of Time / Adverse Weather .....	40
15.3 Hours of Work.....	41
15.4 Progress and Completion.....	41
15.5 Expeditious Completion .....	41
<b>16. EXTENSIONS OF TIME – LIQUIDATED DAMAGES .....</b>	<b>41</b>
16.1 Liquidated Damages .....	41
16.2 Excusable Delay .....	41
16.3 No Additional Compensation for Delays Within Contractor’s Control .....	42
16.4 Float or Slack in the Schedule .....	43
<b>17. CHANGES IN THE WORK.....</b>	<b>43</b>
17.1 No Changes Without Authorization.....	43
17.2 Architect Authority to Order Minor Changes .....	43
17.3 Change Orders .....	43
17.4 Construction Change Directives.....	44
17.5 Force Account Directives .....	44
17.7 Proposed Change Order .....	45
17.6 Price Request .....	45
17.8 Format for Proposed Change .....	46
17.9 Change Order Certification .....	47
17.10 Determination of Change Order Cost .....	47
17.11 Allowable Costs .....	47
17.12 Deductive Change Orders .....	48
17.13 Discounts, Rebates, and Refunds .....	49
17.14 Accounting Records.....	49
17.15 Notice Required.....	49

17.16 Applicability to Subcontractors.....	49
17.17 Alteration to Change Order Language.....	49
17.18 Failure of Contractor to Execute Change Order.....	49
<b>18. REQUEST FOR INFORMATION.....</b>	<b>49</b>
18.1 Coordination of Contract Work.....	49
18.2 Reference Contract Documents .....	50
18.3 Contractor Responsible For Costs .....	50
<b>19. PAYMENTS .....</b>	<b>50</b>
19.1 Contract Price .....	50
19.2 Applications for Progress Payments .....	50
19.3 Progress Payments.....	52
19.4 Decisions to Withhold Payment .....	54
19.5 Subcontractor Payments.....	56
<b>20. COMPLETION OF THE WORK .....</b>	<b>57</b>
20.1 Completion .....	57
20.2 Close-Out Procedures.....	57
<b>21. FINAL PAYMENT AND RETENTION .....</b>	<b>59</b>
21.1 Final Payment .....	60
21.2 Prerequisites for Final Payment.....	60
21.3 Retention .....	60
21.4 Substitution of Securities .....	61
<b>22. UNCOVERING OF WORK .....</b>	<b>61</b>
<b>23. NONCONFORMING WORK, CORRECTION OF WORK AND COUNTY’S RIGHT TO PERFORM WORK .....</b>	<b>61</b>
23.1 Nonconforming Work.....	61
23.2 Correction of Work .....	62

23.3	County's Right to Perform Work .....	62
24.	<b>TERMINATION AND SUSPENSION</b> .....	63
24.1	County's Right to Terminate Contractor for Cause.....	63
24.2	Termination of Contractor for Convenience .....	65
24.3	Emergency Termination of Public Contracts Act of 1949 .....	66
25.	<b>CLAIMS AND DISPUTES</b> .....	66
25.1	Performance During Claim Process .....	66
25.2	Definition of Claim .....	67
25.3	Claim Presentations.....	67
25.4	Claim Resolution .....	67
26.	<b>LABOR, WAGE &amp; HOUR, APPRENTICE, AND RELATED PROVISIONS</b> .....	69
26.1	Wage Rates, Travel, and Subsistence .....	69
26.2	Hours of Work .....	71
26.3	Payroll Records.....	72
26.4	Apprentices.....	73
26.5	Non-Discrimination .....	75
26.6	Labor First Aid .....	75
27.	<b>MISCELLANEOUS</b> .....	75
27.1	Assignment of Antitrust Actions .....	75
27.2	Excise Taxes .....	76
27.3	Taxes.....	76
27.4	Shipments.....	76

## GENERAL CONDITIONS

### 1. CONTRACT TERMS AND DEFINITIONS

#### 1.1 Definitions

Wherever used in the Contract Documents, the following terms shall have the meanings indicated, which shall be applicable to both the singular and plural thereof:

**1.1.1 Adverse Weather:** Shall be only weather that satisfies all of the following conditions: (1) unusually severe precipitation, sleet, snow, hail, heat, or cold conditions in excess of the norm for the location and time of year it occurred, (2) unanticipated, and (3) at the Project.

**1.1.2 Approval, Approved, and/or Accepted:** Refer to written authorization, unless stated otherwise.

**1.1.3 Architect:** The individual, partnership, corporation, joint venture, or any combination thereof, named as Architect, who will have the rights and authority assigned to the Architect in the Contract Documents. The term Architect means the County's Architect on this Project or the Architect's authorized representative.

**1.1.4 Architect's Supplemental Instruction:** A document prepared by the Architect to provide supplemental instructions or interpretations or to order minor changes in the work not involving an adjustment in the Contract Amount or Contract Time.

**1.1.5 Bidder:** A contractor who intends to provide a bid to the County to perform the Work of this Contract.

**1.1.6 Change Order:** A written order to the Contractor authorizing an addition to, deletion from, or revision in the Work, and/or authorizing an adjustment in the Contract Price or Contract Time.

**1.1.7 Construction Change Directive:** A written order prepared and issued by the County, the Construction Manager, and/or the Architect and signed by the County and the Architect, directing a change in the Work.

**1.1.8 Construction Manager:** The individual, partnership, corporation, joint venture, or any combination thereof, or its authorized representative, named as such by the County. If no Construction Manager is used on the Project that is the subject of this contract, then all references to Construction Manager herein shall be read to refer to County.

**1.1.9 Construction Schedule:** The progress schedule of construction of the Project as provided by Contractor and approved by County.

**1.1.10 Contract, Contract Documents:** The Contract consists exclusively of the documents evidencing the agreement of the County and Contractor, identified as the Contract Documents. The Contract Documents consist of the following documents:

**1.1.10.1** Notice to Bidders

**1.1.10.2** Instructions to Bidders

**1.1.10.3** Supplementary Instructions to Bidders – Construction Outreach Program



- 1.1.10.4** Bid Form
- 1.1.10.5** Bid Security Form
- 1.1.10.6** Task Order
- 1.1.10.7** Designated Subcontractors List
- 1.1.10.8** Site-Visit Certification, if a site visit was required.
- 1.1.10.9** Non-Collusion Affidavit
- 1.1.10.10** Workers' Compensation Certification
- 1.1.10.11** Prevailing Wage and Related Labor Requirements Certification
- 1.1.10.12** Construction Outreach Program Certifications
- 1.1.10.13** Hazardous Materials Certification
- 1.1.10.14** Imported Materials Certification
- 1.1.10.15** Notice of Award
- 1.1.10.16** Agreement
- 1.1.10.17** Notice to Proceed
- 1.1.10.18** Escrow of Bid Documentation
- 1.1.10.19** Escrow Agreement for Security Deposits in Lieu of Retention
- 1.1.10.20** Exhibit A: Task Order Form
- 1.1.10.21** Exhibit B: Task Order Change Order Form
- 1.1.10.22** Exhibit C: Insurance Requirements
- 1.1.10.23** Performance Bond
- 1.1.10.24** Payment Bond (Contractor's Labor & Material Payment Bond)
- 1.1.10.25** General Conditions
- 1.1.10.26** Special Conditions
- 1.1.10.27** Hazardous Materials Procedures and Requirements
- 1.1.10.28** Divisions 01 through 49
- 1.1.10.29** All Plans, Technical Specifications, and Drawings
- 1.1.10.30** Any and all addenda to any of the above documents
- 1.1.10.31** Any and all change orders or written modifications to the above documents if approved in writing by the County.

**1.1.11** Contract Price: The total monies payable to the Contractor under the terms and conditions of the Contract Documents.

**1.1.12** Contract Time: The time period stated in the Agreement for the completion of the Work.

**1.1.13 Contractor:** The person or persons identified in the Agreement as contracting to perform the Work to be done under this Contract, or the legal representative of such a person or persons.

**1.1.14 County:** County of Alameda, acting through its Board of Supervisors or any of its authorized agents. The County may, at any time:

**1.1.14.1** Direct the Contractor to communicate with or provide notice to the Construction Manager or the Architect on matters for which the Contract Documents indicate the Contractor will communicate with or provide notice to the County; and/or

**1.1.14.2** Direct the Construction Manager or the Architect to communicate with or direct the Contractor on matters for which the Contract Documents indicate the County will communicate with or direct the Contractor.

**1.1.15 Task Order(s):** The document setting forth the scope of work for the Project and attached to the Agreement as Exhibit A.

**1.1.16 Daily Job Report(s):** Daily Project reports prepared by the Contractor's employee(s) who are present on Site, which shall include the information required herein.

**1.1.17 Day(s):** Unless otherwise designated, day(s) means calendar day(s).

**1.1.18 Drawings:** (or "Plans") The graphic and pictorial portions of the Contract Documents showing the design, location, scope and dimensions of the work, generally including plans, elevations, sections, details, schedules, sequence of operation, and diagrams.

**1.1.19 Force Account Directive:** A process that may be used when the County and the Contractor cannot agree on a price for a specific portion of work or before the Contractor prepares prices for a specific portion of work and whereby the Contractor performs the work as indicated herein on a time and materials basis.

**1.1.20 Premises:** The real property owned by the County on which the Site is located.

**1.1.21 Product(s):** New material, machinery, components, equipment, fixtures, and systems forming the Work, including existing materials or components required and approved by the County for reuse.

**1.1.22 Product Data:** Illustrations, standard schedules, performance charts, instructions, brochures, diagrams, and other information furnished by the Contractor to illustrate a material, product, or system for some portion of the Work.

**1.1.23 Project:** The planned undertaking as provided for in the Contract Documents.

**1.1.24 Program Manager:** The individual, partnership, corporation, joint venture, or any combination thereof, or its authorized representative, named as such by the County. If no Program Manager is designated for Project that is the subject of this Contract, then all references to Project Manager herein shall be read to refer to County.

**1.1.25** Provide: Shall include “provide complete in place,” that is, “furnish and install,” and “provide complete and functioning as intended in place” unless specifically stated otherwise.

**1.1.26** Request for Information: A written request prepared by the Contractor requesting that the Architect provide additional information necessary to clarify or amplify an item in the Contract Documents that the Contractor believes is not clearly shown or called for in the Drawings or Specifications or other portions of the Contract Documents, or to address problems that have arisen under field conditions.

**1.1.27** Request for Substitution: A request by Contractor to substitute an equal or superior material, product, thing, or service for a specific material, product, thing, or service that has been designated in the Contract Documents by a specific brand or trade name.

**1.1.28** Safety Orders: Written and/or verbal orders for construction issued by the California Division of Industrial Safety (“CalOSHA”) or by the United States Occupational Safety and Health Administration (“OSHA”).

**1.1.29** Safety Plan: Contractor’s safety plan specifically adapted for the Project. Contractor’s Safety Plan shall comply with all provisions regarding Project safety, including all applicable provisions in these General Conditions.

**1.1.30** Samples: Physical examples that illustrate materials, products, equipment, finishes, colors, or workmanship and that, when approved in accordance with the Contract Documents, establish standards by which portions of the Work will be judged.

**1.1.31** Shop Drawings: All drawings, prints, diagrams, illustrations, brochures, schedules, and other data that are prepared by the Contractor, a subcontractor, manufacturer, supplier, or distributor, that illustrate how specific portions of the Work shall be fabricated or installed.

**1.1.32** Site: The Project site as shown on the Drawings.

**1.1.33** Specifications: That portion of the Contract Documents, Division 01 through Division 49, and all technical sections, and addenda to all of these, if any, consisting of written descriptions and requirements of a technical nature of materials, equipment, construction methods and systems, standards, and workmanship.

**1.1.34** Subcontractor: A contractor and/or supplier who is under contract with the Contractor or with any other subcontractor, regardless of tier, to perform a portion of the Work of the Project.

**1.1.35** Submittal Schedule: The schedule of submittals as provided by Contractor and approved by County.

**1.1.36** Surety: The person, firm, or corporation that executes as surety the Contractor’s Performance Bond and Payment Bond, and must be a California admitted surety insurer as defined in the Code of Civil Procedure § 995.120.

**1.1.37** Work: All labor, materials, equipment, components, appliances, supervision, coordination, and services required by, or reasonably inferred from, the Contract Documents, that are necessary for the construction and completion of the Project.

## **1.2 Laws Concerning The Contract**

Contract is subject to all provisions of the Constitution and laws of California governing, controlling, or affecting County, or the property, funds, operations, or powers of County, and such provisions are by this reference made a part hereof. Any provision required by law to be included in this Contract shall be deemed to be inserted.

## **1.3 No Oral Agreements**

No oral agreement or conversation with any officer, agent, or employee of County, either before or after execution of Contract, shall affect or modify any of the terms or obligations contained in any of the documents comprising the Contract.

## **1.4 No Assignment**

Contractor shall not assign this Contract or any part thereof including, without limitation, any services or money to become due hereunder without the prior written consent of the County. Assignment without County's prior written consent shall be null and void. Any assignment of money due or to become due under this Contract shall be subject to a prior lien for services rendered or material supplied for performance of work called for under this Contract in favor of all persons, firms, or corporations rendering services or supplying material to the extent that claims are filed pursuant to the Civil Code, Code of Civil Procedure, Government Code, Labor Code, and/or Public Contract Code, and shall also be subject to deductions for liquidated damages or withholding of payments as determined by County in accordance with this Contract. Contractor shall not assign or transfer in any manner to a Subcontractor or supplier the right to prosecute or maintain an action against the County.

## **1.5 Notice And Service Thereof**

**1.5.1** Any notice from one party to the other or otherwise under Contract shall be in writing and shall be dated and signed by the party giving notice or by a duly authorized representative of that party. Any notice shall not be effective for any purpose whatsoever unless served in one of the following manners:

- 1.5.1.1** If notice is given by personal delivery thereof, it shall be considered delivered on the day of delivery.
- 1.5.1.2** If notice is given by overnight delivery service, it shall be considered delivered on (1) day after date deposited, as indicated by the delivery service.
- 1.5.1.3** If notice is given by depositing same in United States mail, enclosed in a sealed envelope, it shall be considered delivered three (3) days after date deposited, as indicated by the postmarked date.
- 1.5.1.4** If notice is given by registered or certified mail with postage prepaid, return receipt requested, it shall be considered delivered on the day the notice is signed for.

## **1.6 No Waiver**

The failure of County in any one or more instances to insist upon strict performance of any of the terms of this Contract or to exercise any option herein conferred

shall not be construed as a waiver or relinquishment to any extent of the right to assert or rely upon any such terms or option on any future occasion. No action or failure to act by the County, Architect, or Construction Manager shall constitute a waiver of any right or duty afforded the County under the Contract, nor shall any action or failure to act constitute an approval of or acquiescence in any breach thereunder, except as may be specifically agreed in writing.

### **1.7 Substitutions For Specified Items**

See Special Conditions.

### **1.8 Materials and Work**

**1.8.1** Except as otherwise specifically stated in this Contract, Contractor shall provide and pay for all materials, labor, tools, equipment, transportation, supervision, temporary constructions of every nature, and all other services, management, and facilities of every nature whatsoever necessary to execute and complete this Contract within the Contract Time.

**1.8.2** Unless otherwise specified, all materials shall be new, and the best of their respective kinds and grades as noted or specified and workmanship shall be of good quality.

**1.8.3** Materials shall be furnished in ample quantities and at such times as to ensure uninterrupted progress of Work and shall be stored properly and protected as required.

**1.8.4** For all materials and equipment specified or indicated in the Drawings, the Contractor shall provide all labor, materials, equipment, and services necessary for complete assemblies and complete working systems, functioning as intended. Incidental items not indicated on Drawings, nor mentioned in the Specifications, that can legitimately and reasonably be inferred to belong to the Work described, or be necessary in good practice to provide a complete assembly or system, shall be furnished as though itemized here in every detail. In all instances, material and equipment shall be installed in strict accordance with each manufacturer's most recent published recommendations and specifications.

**1.8.5** Contractor shall, after award of Contract by County and after relevant submittals have been approved, place orders for materials and/or equipment as specified so that delivery of same may be made without delays to the Work. Contractor shall, upon demand from County, present documentary evidence showing that orders have been placed.

**1.8.6** County reserves the right but has no obligation, for any neglect in complying with the above instructions, to place orders for such materials and/or equipment as it may deem advisable in order that the Work may be completed at the date specified in the Agreement, and all expenses incidental to the procuring of said materials and/or equipment shall be paid for by Contractor or withheld from payment(s) to Contractor.

**1.8.7** Contractor warrants good title to all material, supplies, and equipment installed or incorporated in Work and agrees upon completion of all Work to deliver the Site to County, together with all improvements and appurtenances constructed or placed thereon by it, and free from any claims, liens, or charges. Contractor further agrees that

neither it nor any person, firm, or corporation furnishing any materials or labor for any work covered by the Contract shall have any right to lien any portion of the Premises or any improvement or appurtenance thereon, except that Contractor may install metering devices or other equipment of utility companies or of political subdivision, title to which is commonly retained by utility company or political subdivision. In the event of installation of any such metering device or equipment, Contractor shall advise County as to owner thereof.

**1.8.8** Nothing contained in this Article, however, shall defeat or impair the rights of persons furnishing materials or labor under any bond given by Contractor for their protection or any rights under any law permitting such protection or any rights under any law permitting such persons to look to funds due Contractor in hands of County (e.g., Stop Notices), and this provision shall be inserted in all subcontracts and material contracts and notice of its provisions shall be given to all persons furnishing material for work when no formal contract is entered into for such material.

**1.8.9** Title to new materials and/or equipment for the Work of this Contract and attendant liability for its protection and safety shall remain with Contractor until incorporated in the Work of this Contract and accepted by County. No part of any materials and/or equipment shall be removed from its place of storage except for immediate installation in the Work of this Contract. Contractor shall keep an accurate inventory of all materials and/or equipment in a manner satisfactory to County or its authorized representative and shall, at the County's request, forward it to the County.

## **2. COUNTY**

### **2.1 Occupancy**

County reserves the right to occupy portions of the Project at any time before completion. Neither the County's Final Acceptance, the making of Final Payment, any provision in Contract Documents, nor the use or occupancy of the Work, in whole or in part, by County shall constitute acceptance of Work not in accordance with the Contract Documents nor relieve the Contractor or the Contractor's Performance Bond Surety from liability with respect to any warranties or responsibility for faulty or defective Work or materials, equipment and workmanship incorporated therein.

## **3. ARCHITECT**

### **3.1 Role and Authority**

The Architect shall represent County during the Project and will observe the progress and quality of the Work on behalf of County. Architect shall have the authority to act on behalf of County to the extent expressly provided in the Contract Documents and to the extent determined by County. Architect shall have authority to reject materials, workmanship, and/or the Work whenever rejection may be necessary, in Architect's reasonable opinion, to ensure the proper execution of the Contract.

### **3.2 Interpretations**

Architect shall, with County and on behalf of County, determine the amount, quality, acceptability, and fitness of all parts of the Work, and interpret the Specifications, Drawings, and shall, with County, interpret all other Contract Documents.

### **3.3 Laws**

Architect shall have all authority and responsibility established by law, including Title 24 of the California Code of Regulations.

### **3.4 Communications**

Contractor shall provide County and the Construction Manager with a copy of all written communication between Contractor and Architect at the same time as that communication is made to Architect, including, without limitation, all RFIs, correspondence, submittals, claims, and proposed change orders.

## **4. CONSTRUCTION MANAGER**

### **4.1 Role and Authority**

If a construction manager is used on this Project ("Construction Manager" or "CM"), the Construction Manager will provide administration of the Contract on the County's behalf. After execution of the Contract and Notice to Proceed, all correspondence, and/or instructions from Contractor and/or County shall be forwarded through the Construction Manager. The Construction Manager will not be responsible for and will not have control or charge of construction means, methods, techniques, sequences, or procedures or for safety precautions in connection with the Work, which shall all remain the Contractor's responsibility.

### **4.2 Authority to Reject**

The Construction Manager, however, will have authority to reject materials and/or workmanship not conforming to the Contract Documents, as determined by the County and/or the Architect. The Construction Manager shall also have the authority to require special inspection or testing of any portion of the Work, whether it has been fabricated, installed or fully completed. Any decision made by the Construction Manager, in good faith, shall not give rise to any duty or responsibility of the Construction Manager to the Contractor, any Subcontractor, their agents, employees, or other persons performing any of the Work. The Construction Manager shall have free access to any or all parts of the Work at any time.

### **4.3 If No Construction Manager**

If the County does not use a Construction Manager on this Project, all references to Construction Manager or CM shall be read as County.

## **5. INSPECTIONS AND TESTS**

### **5.1 Tests and Inspections**

**5.1.1** The County will select an independent testing laboratory to conduct tests. Selection of the materials required to be tested shall be by the laboratory or the County's representative and not by the Contractor. The Contractor shall notify the County's representative a sufficient time in advance of its readiness for required observation or inspection.

**5.1.2** The Contractor shall notify the County's representative a sufficient time in advance of the manufacture of material to be supplied under the Contract Documents that must by terms of the Contract Documents be tested, in order that the County may

arrange for the testing of same at the source of supply. This notice shall be, at a minimum, seventy-two (72) hours prior to the manufacture of the material that needs to be tested.

**5.1.3** Any material shipped by the Contractor from the source of supply prior to having satisfactorily passed such testing and inspection or prior to the receipt of notice from said representative that such testing and inspection will not be required, shall not be incorporated into and/or onto the Project.

**5.1.4** The County will select and pay testing laboratory costs for all tests and inspections. Costs of tests of any materials found to be not in compliance with the Contract Documents shall be paid for by the County and reimbursed by the Contractor or deducted from the Contract Price.

## **5.2 Costs for After Hours and/or Off Site Inspections**

If the Contractor performs Work outside the County's regular working hours or requests the County to perform inspections off Site, costs of any inspections required outside regular working hours or off Site shall be borne by the Contractor and may be invoiced to the Contractor by the County or the County may deduct those expenses from the next Progress Payment.

## **6. CONTRACTOR**

Contractor shall construct the Work for the Contract price including any adjustment(s) to the Contract Price pursuant to provisions herein regarding changes to the Contract Price. Except as otherwise noted, Contractor shall provide and pay for all labor, materials, equipment, permits, fees, licenses, facilities, transportation, taxes, and services necessary for the proper execution and completion of the Work, except as indicated herein.

### **6.1 Status of Contractor**

**6.1.1** Contractor is and shall at all times be deemed to be an independent contractor and shall be wholly responsible for the manner in which it and its Subcontractors perform the services required of it by the Contract Documents. Nothing herein contained shall be construed as creating the relationship of employer and employee, or principal and agent, between the County, or any of the County's employees or agents, and Contractor or any of Contractor's Subcontractors, agents or employees. Contractor assumes exclusively the responsibility for the acts of its employees as they relate to the services to be provided during the course and scope of their employment. Contractor, its agents, its employees and its Subcontractors shall not be entitled to any rights or privileges of County employees. County shall be permitted to monitor the Contractor's activities to determine compliance with the terms of this Contract.

**6.1.2** As required by law, Contractor and all Subcontractors shall be properly licensed and regulated by the Contractor's State License Board, 3132 Bradshaw Road, Post Office Box 2600, Sacramento, California 98826, <http://www.cslb.ca.gov>.

### **6.2 Contractor's Supervision**

**6.2.1** At all times during progress of the Work, while any work is being performed, Contractor shall keep on the Premises, and at all other locations where any Work related to the Contract is being performed, a competent project manager and



construction superintendent who are employees of the Contractor, to whom the County does not object and at least one of whom shall be fluent in English, written and verbal.

**6.2.2** The project manager and construction superintendent shall both speak fluently the predominant language of the Contractor's employees fluently. All workers shall be sufficiently competent in English to respond to inquiries and instructions and give directions concerning matters of safety and concerning the identification and location of site foremen, the Contractor's construction superintendent, and the Contractor's project manager.

**6.2.3** Before commencing the Work herein, Contractor shall give written notice to County of the name and relevant credentials of its project manager and construction superintendent. Neither the Contractor's project manager nor construction superintendent shall be changed except with prior written notice to County and County's approval, unless the Contractor's project manager and/or construction superintendent proves to be unsatisfactory to Contractor, County, any of the County's employees, agents, the Construction Manager, or the Architect, in which case, Contractor shall notify County in writing. The Contractor's project manager and construction superintendent shall each represent Contractor, and all directions given to Contractor's project manager and/or construction superintendent shall be as binding as if given to Contractor.

**6.2.4** Contractor shall give efficient supervision to Work, using its best skill and attention. Contractor shall carefully study and compare all Contract Documents, Drawings, Specifications, and other instructions and shall at once report to County, Construction Manager, and Architect any error, inconsistency, or omission that Contractor or its employees and Subcontractors may discover, in writing. The Contractor shall have responsibility for discovery of errors, inconsistencies, or omissions.

### **6.3 Duty to Provide Fit Workers**

**6.3.1** Contractor and Subcontractor(s) shall at all times enforce strict discipline and good order among their employees and shall not employ or work any unfit person or anyone not skilled in work assigned to that person. It shall be the responsibility of Contractor to ensure compliance with this requirement. County may require Contractor to permanently remove unfit persons from Project Site.

**6.3.2** Any person in the employ of Contractor or Subcontractor(s) whom County may deem incompetent or unfit shall be excluded from working on the Project and shall not again be employed on the Project except with the prior written consent of County.

**6.3.3** The Contractor shall furnish labor that can work in harmony with all other elements of labor employed or to be employed in the Work.

**6.3.4** If Contractor intends to make any change in the name or legal nature of the Contractor's entity, Contractor must first notify the County. The County shall determine if Contractor's intended change is permissible while performing this Contract.

### **6.4 Purchase of Materials and Equipment**

The Contractor is required to order, obtain, and store materials and equipment sufficiently in advance of its Work at no additional cost or advance payment from County to assure that there will be no delays.

## **6.5 Documents On Work Site**

**6.5.1** Contractor shall at all times keep on the Work Site, or such other location as County may authorize in writing one legible copy of all Contract Documents, including Addenda and Change Orders, and titles 19 and 24 of the California Code of Regulations, the specified edition(s) of the Uniform Building Code, all approved Drawings, Plans, Schedules, and Specifications, and all codes and documents referred to in the Specifications, and made part thereof. These documents shall be kept in good order and available to County, Construction Manager, Architect, Architect's representatives, and all authorities having jurisdiction. Contractor shall be acquainted with and comply with the provisions of these titles as they relate to this Project. Contractor shall also be acquainted with and comply with all California Code of Regulations provisions relating to conditions on this Project. Contractor shall coordinate with Architect and Construction Manager.

**6.5.2** Daily Job Reports. Contractor shall maintain, at a minimum, at least one (1) set of Daily Job Reports on the Project. These must be prepared by the Contractor's employee(s) who are present on Site and must include, at a minimum, the following information:

- 6.5.2.1** A brief description of all Work performed on that day. This shall include a listing of what was done, which contractors were on site that day, and where on the site the work was performed.
- 6.5.2.2** A summary of all other pertinent events and/or occurrences on that day.
- 6.5.2.3** The weather conditions on that day.
- 6.5.2.4** A list of all Subcontractor(s) working on that day,
- 6.5.2.5** A list of each Contractor employee working on that day and the total hours worked for each employee.
- 6.5.2.6** A complete list of all equipment on Site that day, whether in use or not.
- 6.5.2.7** All complete list of all materials, supplies, and equipment delivered on that day.
- 6.5.2.8** A complete list of all inspections and tests performed on that day.
- 6.5.2.9** Each day Contractor shall provide a copy of the previous day's Daily Job Report to the County or the County's Construction Manager.

## **6.6 Preservation of Records**

The County shall have the right to examine and audit all Daily Job Reports or other Project records of Contractor's project manager(s), project superintendent(s), and/or project foreperson(s), all certified payroll records and/or related documents including, without limitation, payroll, payment, timekeeping and tracking documents; all books, estimates, records, contracts, documents, bid documents, bid cost data, subcontract job cost reports, and other data of the Contractor, any Subcontractor, and/or supplier, including computations and projections related to bidding, negotiating, pricing, or performing the Work or Contract modification, in order to evaluate the accuracy, completeness, and

currency of the cost, manpower, coordination, supervision, or pricing data at no additional cost to the County. These documents may be duplicative and/or be in addition to any Bid Documents held in escrow by the County. The Contractor shall make available at its office at all reasonable times the materials described in this paragraph for the examination, audit or reproduction until three (3) years after final payment under this Contract. Notwithstanding the provisions above, Contractor shall provide any records requested by any governmental agency if available, after the time set forth above.

#### **6.7 Integration of Work**

**6.7.1** Contractor shall do all cutting, fitting, patching, and preparation of Work as required to make its several parts come together properly, to fit it to receive or be received by work of other contractors, and to coordinate tolerances to various pieces of work, showing upon, or reasonably implied by, the Drawings and Specifications for the completed structure, and shall conform them as County and/or Architect may direct.

**6.7.2** All cost caused by defective or ill-timed Work shall be borne by Contractor, inclusive of repair work.

**6.7.3** Contractor shall not endanger any work performed by it or anyone else by cutting, excavating, or otherwise altering work and shall not cut or alter work of any other contractor except with the consent of County.

#### **6.8 Obtaining of Permits and Licenses**

Contractor shall secure and pay for all permits, licenses, and certificates necessary for prosecution of Work before the date of the commencement of the Work or before the permits, licenses, and certificates are legally required to continue the Work without interruption. The Contractor shall obtain and pay, only when legally required, for all licenses, permits, inspections, and inspection certificates required to be obtained from or issued by any authority having jurisdiction over any part of the Work included in the Contract. All final permits, licenses, and certificates shall be delivered to County before demand is made for final payment.

#### **6.9 Work to Comply With Applicable Laws and Regulations**

**6.9.1** Contractor shall give all notices and comply with the following specific laws, ordinances, rules, and regulations and all other applicable laws, ordinances, rules, and regulations bearing on conduct of Work as indicated and specified, including but not limited to the appropriate statutes and administrative code sections. If Contractor observes that Drawings and Specifications are at variance therewith, or should Contractor become aware of the development of conditions not covered by Contract Documents that will result in finished Work being at variance therewith, Contractor shall promptly notify County in writing, including by e-mail, and any changes deemed necessary by County shall be made as provided in Contract for changes in Work.

**6.9.1.1** National Electrical Safety Code, U. S. Department of Commerce

**6.9.1.2** National Board of Fire Underwriters' Regulations

**6.9.1.3** Uniform Building Code, latest addition, and the California Code of Regulations, title 24, including amendments

- 6.9.1.4** Manual of Accident Prevention in Construction, latest edition, published by A.G.C. of America
- 6.9.1.5** Industrial Accident Commission's Safety Orders, State of California
- 6.9.1.6** Regulations of the State Fire Marshall (title 19, California Code of Regulations) and Pertinent Local Fire Safety Codes
- 6.9.1.7** Americans with Disabilities Act
- 6.9.1.8** Government Code of the State of California
- 6.9.1.9** Labor Code of the State of California, Division 2, part 7, Public Works and Public Agencies
- 6.9.1.10** Public Contract Code of the State of California
- 6.9.1.11** California Art Preservation Act
- 6.9.1.12** U. S. Copyright Act
- 6.9.1.13** U. S. Visual Artists Rights Act

**6.9.2** Contractor shall comply with all applicable mitigation measures, if any, adopted by any public agency with respect to this Project pursuant to the California Environmental Quality Act (Public Resources Code § 21000 et. Seq.)

**6.9.3** If Contractor performs any Work that it knew, or through exercise of reasonable care should have known, to be contrary to any applicable laws, ordinance, rules, or regulations, Contractor shall bear all costs arising therefrom.

**6.9.4** Where Specifications or Drawings state that materials, processes, or procedures must be approved by the State Fire Marshall, or other body or agency, Contractor shall be responsible for satisfying requirements of such bodies or agencies.

## **6.10 Safety/Protection of Persons and Property**

**6.10.1** The Contractor will be solely and completely responsible for conditions of the Work Site, including safety of all persons and property during performance of the Work. This requirement will apply continuously and not be limited to normal working hours.

**6.10.2** The wearing of hard hats will be mandatory at all times for all personnel on Site. Contractor shall supply sufficient hard hats to properly equip all employees and visitors.

**6.10.3** Any construction review of the Contractor's performance is not intended to include a review of the adequacy of the Contractor's safety measures in, on, or near the Work Site.

**6.10.4** Implementation and maintenance of safety programs shall be the sole responsibility of the Contractor.

**6.10.5** The Contractor shall furnish to the County a copy of the Contractor's safety plan within the time frame indicated in the Contract Documents and specifically adapted for the Project.

**6.10.6** Contractor shall be responsible for all damages to persons or property that occur as a result of its fault or negligence in connection with the prosecution of this Contract and shall take all necessary measures and be responsible for the proper care and completion and final acceptance by County. All Work shall be solely at Contractor's risk with the exception of damage to the Work caused by "acts of God" as defined in Public Contract Code § 7105.

**6.10.7** Contractor shall take, and require Subcontractors to take, all necessary precautions for safety of workers on the Project and shall comply with all applicable federal, state, local, and other safety laws, standards, orders, rules, regulations, and building codes to prevent accidents or injury to persons on, about, or adjacent to premises where Work is being performed and to provide a safe and healthful place of employment. Contractor shall furnish, erect, and properly maintain at all times, all necessary safety devices, safeguards, construction canopies, signs, nets, barriers, lights, and watchmen for protection of workers and the public and shall post danger signs warning against hazards created by such features in the course of construction.

**6.10.8** Hazards Control – Contractor shall store volatile wastes in covered metal containers and remove them from the Site daily. Contractor shall prevent the accumulation of wastes that create hazardous conditions. Contractor shall provide adequate ventilation during use of volatile or noxious substances.

**6.10.9** Contractor shall designate a responsible member of its organization on the Project, whose duty shall be to post information regarding protection and obligations of workers and other notices required under occupational safety and health laws, to comply with reporting and other occupational safety requirements, and to protect the life, safety, and health of workers. Name and position of person so designated shall be reported to County by Contractor.

**6.10.10** Contractor shall correct any violations of safety laws, rules, orders, standards, or regulations. Upon the issuance of a citation or notice of violation by the Division of Occupational Safety and Health, Contractor shall correct such violation promptly.

**6.10.11** Contractor shall comply with any County stormwater requirements that are approved by the County and applicable to the Project, at no additional cost to the County.

**6.10.12** In an emergency affecting safety of life or of work or of adjoining property, Contractor, without special instruction or authorization, shall act, at its discretion, to prevent such threatened loss or injury. Any compensation claimed by Contractor on account of emergency work shall be determined by agreement.

**6.10.13** All connections to public utilities and/or existing on-site services shall be made and maintained in such a manner as to not interfere with the continuing use of same by the County during the entire progress of the Work.

**6.10.14** Contractor shall provide such heat, covering, and enclosures as are necessary to protect all Work, materials, equipment, appliances, and tools against damage by weather conditions, such as extreme heat, cold, rain, snow, dry winds, flooding, or dampness.

**6.10.15** The Contractor shall protect and preserve the Work from all damage or accident, providing any temporary roofs, window and door coverings, boxing, or other construction. The Contractor shall be responsible for existing structures, walks, roads, trees, landscaping, and/or improvements in working areas; and shall provide adequate protection therefor. If temporary removal is necessary of any of the above items, or damage occurs due to the Work, the Contractor shall replace same at his expense with same kind, quality, and size of Work or item damaged. This shall include any adjoining property of the County and others.

**6.10.16** Contractor shall take adequate precautions to protect existing roads, sidewalks, curbs, pavements, utilities, adjoining property, and structures (including, without limitation, protection from settlement or loss of lateral support), and to avoid damage thereto, and repair any damage thereto caused by construction operations.

**6.10.17** Contractor shall confine apparatus, the storage of materials, and the operations of workers to limits indicated by law, ordinances, permits, or directions of Architect, and shall not interfere with the Work or unreasonably encumber Premises or overload any structure with materials. Contractor shall enforce all instructions of County and Architect regarding signs, advertising, fires, and smoking, and require that all workers comply with all regulations while on Project Site.

**6.10.18** Contractor, Contractor's employees, Subcontractors, Subcontractors' employees, or any person associated with the Work shall conduct themselves in a manner appropriate for a public site. No verbal or physical contact with the public, neighbors, or tenants, or profanity, or inappropriate attire or behavior will be permitted. County may require Contractor to permanently remove non-complying persons from Project Site.

**6.10.19** Contractor shall take care to prevent disturbing or covering any survey markers, monuments, or other devices marking property boundaries or corners. If such markers are disturbed, Contractor shall have a civil engineer, registered as a professional engineer in California, replace them at no cost to County.

**6.10.20** In the event that the Contractor enters into any agreement with owners of any adjacent property to enter upon the adjacent property for the purpose of performing the Work, Contractor shall fully indemnify, defend, and hold harmless each person, entity, firm, or agency that owns or has any interest in adjacent property. The form and content of the agreement of indemnification shall be approved by the County prior to the commencement of any Work on or about the adjacent property. The Contractor shall also indemnify the County as provided in the indemnification provision herein. These provisions shall be in addition to any other requirements of the owners of the adjacent property.

## **6.11 Working Evenings and Weekends**

Contractor may be required to work evenings and/or weekends at no additional cost to the County. Contractor shall give the County seventy-two (72) hours notice prior to performing any evening and/or weekend work. Contractor shall perform all evening and/or weekend work only upon County's approval and in compliance with all applicable rules, regulations, laws, and local ordinances including, without limitation, all noise and light

limitations. Contractor shall reimburse the County for any expenses necessitated by the Contractor's evening and/or weekend work.

#### **6.12 Badge Policy For Contractors**

All Contractors doing work for Alameda County will provide their workers with identification badges. These badges will be worn by all members of the Contractor's staff who are working in a County facility.

**6.12.1** Badges must be filled out in full and contain the following information:

**6.12.1.1** Name of Contractor and Contractor's Company logo, if any

**6.12.1.2** Name and front facial photograph of Employee

**6.12.1.3** Contractor's address and phone number

**6.12.1.4** Name and phone number of Project Manager (County)

**6.12.2** Badges are to be worn when the Contractor or his/her employees are on site and must be visible at all times. Contractors must inform their employees that they are required to allow County employees to review the information on the badges upon request

**6.12.3** Failure to display identification badges as required by this policy may result in the assessment of fines against the Contractor.

#### **6.13 County Drug Policy - Drug-Free Work Place**

**6.13.1** Contractor, Contractor's employees, and Contractor's Subcontractors and their employees shall comply with the County's policy of maintaining a drug-free workplace. Neither Contractor/Subcontractor nor Contractor's/Subcontractor's employees shall unlawfully manufacture, distribute, dispense, possess or use controlled substances, as defined in 21 U.S. Code § 812, including marijuana, heroin, cocaine, and amphetamines, at any County facility or work site. If Contractor or any employee of contractor is convicted or pleads nolo contendere to a criminal drug statute violation occurring at a County facility or work site, the Contractor within five (5) calendar days thereafter shall notify the head of the County department/agency for which the contract services are performed. Violation of this provision shall constitute a material breach of this contract.

#### **6.14 Cleaning Up**

**6.14.1** The Contractor shall provide all services, labor, materials, and equipment necessary for protecting the Work, all Project occupants, furnishings, equipment, and building structure from damage until its completion and final acceptance by County. Dust barriers shall be provided to isolate dust and dirt from construction operations. At completion of the Work and portions thereof, Contractor shall clean to the original state any areas beyond the Work area that become dust laden as a result of the Work. The Contractor must erect the necessary warning signs and barricades to ensure the safety of all Project occupants. The Contractor at all times must maintain good housekeeping practices to reduce the risk of fire damage and must make a fire extinguisher, fire blanket, and/or fire watch, as applicable, available at each location where cutting,

braising, soldering, and/or welding is being performed and locations where there is an increased risk of fire.

**6.14.2** Contractor at all times shall keep Premises free from debris such as waste, rubbish, and excess materials and equipment caused by the Work. Contractor shall not leave debris under, in, or about the Premises, but shall promptly remove same from the Premises on a daily basis. If Contractor fails to clean up, County may do so, and the cost thereof shall be charged to Contractor. If Contract is for work on an existing facility, Contractor shall also perform specific clean-up on or about the Premises upon request by the County as it deems necessary for the continuing use of the facility. Contractor shall comply with all related provisions of the Specifications.

**6.14.3** If the Construction Manager, Architect, or County observes the accumulation of trash and debris, the County will give the Contractor a 24-hour written notice to mitigate the condition.

**6.14.4** Should the Contractor fail to perform the required clean-up, or should the clean-up be deemed unsatisfactory by the County, the County will then perform the clean-up. All cost associated with the clean-up work (including all travel, payroll burden, and costs for supervision) will be deducted from the Contract Price, or County may withhold those amounts from payment(s) to Contractor.

## **7. SUBCONTRACTORS**

### **7.1 Contractor Shall Provide Subcontractor Information**

Contractor shall provide the County with information for all Subcontracts as indicated in the Contractor's Submittals and Schedules Section herein.

### **7.2 No Contractual Relationship Between County and Subcontractors**

No contractual relationship exists between the County and any Subcontractor, Supplier, or sub-subcontractor supplier, or sub-subcontractor by reason of this Contract.

### **7.3 Contractor Binds Every Subcontractor by Terms of Contract**

Contractor agrees to bind every Subcontractor by terms of Contract as far as those terms are applicable to Subcontractor's work. If Contractor shall subcontract any part of this Contract, Contractor shall be as fully responsible to County for acts and omissions of any Subcontractor and of persons either directly or indirectly employed by any Subcontractor, as it is for acts and omissions of persons directly employed by Contractor. The divisions or sections of the Specifications are not intended to control the Contractor in dividing the Work among Subcontractors or limit the work performed by any trade.

### **7.4 No Waiver of Obligations**

County's consent to, or approval of, or failure to object to, any Subcontractor under this Contract shall not in any way relieve Contractor of any obligations under this Contract, and no such consent shall be deemed to waive any provisions of this Contract.

### **7.5 Contractor to Familiarize Itself with Laws**

Contractor is directed to familiarize itself with §§4100 through 4114 of the Public Contract Code of the State of California, as regards subletting and subcontracting,



and to comply with all applicable requirements therein. In addition, Contractor is directed to familiarize itself with §§1720 through 1861 of the Labor Code of the State of California, as regards the payment of prevailing wages and related issues, and to comply with all applicable requirements therein all including, without limitation, § 1775 and the Contractor's and Subcontractors' obligations and liability for violations of prevailing wage law and other applicable laws.

#### **7.6 Subcontractor Substitutions**

No Contractor whose Bid is accepted shall, without consent of the awarding authority and in full compliance with § 4100, et seq, of the Public Contract Code, including, without limitation, §§4107, 4107.5, and 4109 of the Public Contract Code, either:

**7.6.1** Substitute any person as a Subcontractor in place of the Subcontractor designated in the original Bid; or

**7.6.2** Permit any Subcontract to be assigned or transferred, or allow any portion of the Work to be performed by anyone other than the original Subcontractor listed in the Bid; or

**7.6.3** Sublet or subcontract any portion of the Work in excess of one-half of one percent (1/2 of 1%) of the Contractor's total bid as to which his original bid did not designate a Subcontractor.

#### **7.7 Subcontractor Coordination**

The Contractor shall be responsible for the coordination of the trades, Subcontractors, sub-subcontractors, and material or equipment suppliers working on the Project.

#### **7.8 Subcontractor Relations**

Contractor is solely responsible for settling any differences between the Contractor and its Subcontractor(s) or between Subcontractors.

#### **7.9 Assignment or Termination**

Contractor must include in all of its subcontracts the assignment provisions as indicated in the Termination section of these General Conditions.

### **8. OTHER CONTRACTS/CONTRACTORS**

#### **8.1 County Right to Perform**

County reserves the right to let other contracts, and/or to perform work with its own forces, in connection with the Project. Contractor shall afford other County and other contractors' reasonable opportunity for introduction and storage of their materials and execution of their work and shall properly coordinate and connect Contractor's Work with the work of County and other contractors.

#### **8.2 Protection of Work**

In addition to Contractor's obligation to protect its own Work, Contractor shall protect the work of County and any other contractor that Contractor encounters while working on the Project.

### **8.3 Coordination with Other Work**

If any part of Contractor's Work depends for proper execution or results upon work of County or any other contractor, the Contractor shall inspect and promptly report to the County in writing, including by e-mail, before proceeding with its Work any defects in County's or any other contractor's work that render Contractor's Work unsuitable for proper execution and results. Contractor shall be held accountable for damages to County for County's or any other contractor's work that Contractor failed to inspect or should have inspected. Contractor's failure to inspect and report shall constitute Contractor's acceptance of all County's or other contractor's work as fit and proper for reception of Contractor's Work, except as to defects that may develop in County's or other contractor's work after execution of Contractor's Work.

### **8.4 Measurement of Work Performed**

To ensure proper execution of its subsequent work, Contractor shall measure and inspect work already in place and shall at once report to the County in writing, including by e-mail, any discrepancy between that executed work and the Contract Documents.

### **8.5 Knowledge of Other Work**

Contractor shall ascertain to its own satisfaction the scope of the Project and nature of any County-performed work or other contracts that have been or may be awarded by County in prosecution of the Project to the end that Contractor may perform this Contract in light of the other contracts, if any.

### **8.6 No Exclusive Occupancy of Site**

Nothing herein contained shall be interpreted as granting to Contractor exclusive occupancy of the Site, the Premises, or of the Project. Contractor shall not cause any unnecessary hindrance or delay to the use and/or operation(s) of the Premises and/or to County or any other contractor working on the Project. If simultaneous execution of any contract or operation is likely to cause interference with performance of Contractor's Contract, Contractor shall coordinate with those contractor(s), person(s), and/or entity(s) and shall notify the County of the resolution.

## **9. DRAWINGS AND SPECIFICATIONS**

### **9.1 List of all Drawings**

A complete list of all Drawings that form a part of the Contract is to be found as an index on the Drawings themselves, and/or may be provided to the Contractor and/or in the Table of Contents.

### **9.2 Technical and Trade Words**

Materials or Work described in words that so applied have a well-known technical or trade meaning shall be deemed to refer to recognized standards unless noted otherwise.

### **9.3 Trade Name or Trade Term**

It is not the intention of this Contract to go into detailed descriptions of any materials and/or methods commonly known to the trade under "trade name" or "trade

term.” The mere mention or notation of “trade name” or “trade term” shall be considered a sufficient notice to Contractor that it will be required to complete the work so named, complete, finished, and operable, with all its appurtenances, according to the best practices of the trade.

**9.4 The Naming of any Material and/or Equipment Shall Mean Furnishing**

The naming of any material and/or equipment shall mean furnishing and installing of same, including all incidental and accessory items thereto and/or labor, therefore, as per best practices of the trade(s) involved, unless specifically noted otherwise.

**9.5 Contract Documents are Complementary**

Contract Documents are complementary, and what is called for by one shall be binding as if called for by all. As such, Drawings and Specifications are intended to be fully cooperative and to agree. However, if Contractor observes that Drawings and Specifications are in conflict, Contractor shall promptly notify County and Architect in writing, including by e-mail, and any necessary changes shall be made as provided in the Contract Documents.

**9.6 Drawings and Specifications are Intended to Comply With All Laws**

Drawings and Specifications are intended to comply with all laws ordinances, rules, and regulations of constituted authorities having jurisdiction, and where referred to in the Contract Documents, the laws, ordinances, rules, and regulations shall be considered as a part of the Contract within the limits specified. Contractor shall bear all expense of correcting work done contrary to said laws, ordinances, rules, and regulations.

**9.7 Plans, Drawings, Designs, Specifications are County Property**

All copies of Plans, Drawings, Designs, Specifications and copies of other incidental architectural and engineering work, or copies of other Contract Documents furnished by County, are the property of County. They are not to be used by Contractor in other work and, with the exception of signed sets of Contract Documents, are to be returned to County on request at completion of Work, or may be used by County as it may require without any additional costs to County. Neither the Contractor nor any Subcontractor, or material or equipment supplier shall own or claim copyright in the Drawings, Specifications, and other documents prepared by the Architect. County hereby grants the Contractor, Subcontractors, sub-subcontractors, and material or equipment suppliers a limited license to use applicable portions of the Drawings prepared for the Project in the execution of their Work under the Contract Documents.

**9.8 Order of Precedence**

In the case of discrepancy or ambiguity in the Contract Documents, the order of precedence in the Agreement shall prevail.

**9.9 Resolution of Discrepancy or Ambiguity**

However, in the case of discrepancy or ambiguity solely between and among the Drawings and Specifications, the discrepancy or ambiguity shall be resolved in favor of the interpretation that will provide County with the functionally complete and operable Project described in the Drawings and Specifications.

### **9.10 County Clarification**

In case of ambiguity, conflict, or lack of information, County will furnish clarifications with reasonable promptness. Should any clarification, in the opinion of Contractor, cause an increase in the Contract Price, Contractor may request a change in the Contract Price and/or Contract. Within seven (7) days after receipt of the interpretation or request, Contractor to submit to the Construction Manager a detailed description of the contract requirements that were exceeded and the resulting change in cost.

## **10. CONTRACTOR'S SUBMITTALS AND SCHEDULES**

Refer to § 01 33 00 "Submittal Requirements." Contractor's submittals shall comply with the provisions and requirements of the Specifications.

### **10.1 Schedule of Work, Schedule of Submittals, and Schedule of Values**

Within TEN (10) calendar days after the date of the Notice to Proceed (unless otherwise specified in the Specifications), the Contractor shall prepare and submit to the County for review, in a form supported by sufficient data to substantiate its accuracy as the County may require:

#### **10.1.1 Preliminary Schedule**

A preliminary schedule of construction indicating the starting and completion dates of the various stages of the Work, including any information and following any form as may be specified in the Specifications. Once approved by County, this shall become the Construction Schedule. This schedule shall include and identify all tasks that are on the Project's critical path with a specific determination of the start and completion of each critical path task as well as all contract milestones and each milestone's completion date(s) as may be required by the County.

#### **10.1.2 Preliminary Schedule of Values**

A preliminary schedule of values for all of the Work, which must include quantities and prices of items aggregating the Contract Price and must subdivide the Work into component parts in sufficient detail to serve as the basis for progress payments during construction. This preliminary schedule of values shall include, at a minimum, the following information, and the following structure:

##### **10.1.2.1 Divided into at least the following categories:**

**10.1.2.1.1** Overhead and profit;

**10.1.2.1.2** Supervision;

**10.1.2.1.3** General conditions;

**10.1.2.1.4** Layout;

**10.1.2.1.5** Mobilization;

**10.1.2.1.6** Submittals;

**10.1.2.1.7** Bonds and insurance;

**10.1.2.1.8** Close-out documentation;

- 10.1.2.1.9 Demolition;
- 10.1.2.1.10 Installation;
- 10.1.2.1.11 Rough-in;
- 10.1.2.1.12 Finishes;
- 10.1.2.1.13 Testing;
- 10.1.2.1.14 Punch list and acceptance.

10.1.2.2 Divided by each of the following areas:

- 10.1.2.2.1 Site work;
- 10.1.2.2.2 By each building;
- 10.1.2.2.3 By each floor.

10.1.3 The preliminary schedule of values shall not provide for values any greater than the following percentages of the Contract value:

- 10.1.3.1 Mobilization and layout combined to equal not more than 1%;
- 10.1.3.2 Submittals, samples and shop drawings combined to equal not more than 3%, bonds and insurance combined to equal not more than 2%.
- 10.1.3.3 Closeout documentation shall have a value in the preliminary schedule of not less than 5%.

10.1.4 Notwithstanding any provision of the Contract Documents to the contrary, payment of the Contractor's overhead, supervision, general conditions costs, and profit, as reflected in the Cost Breakdown, shall be paid by the County in equal installments, based on percentage complete, with the disbursement of Progress Payments and the Final Payment.

10.1.5 Contractor shall certify that the preliminary schedule of values, as submitted to the County, is accurate and reflects the costs as developed in preparing Contractor's bid. The preliminary schedule of values shall be subject to the County's review and approval of the form and content thereof. In the event that the County objects to any portion of the preliminary schedule of values, the County shall notify the Contractor, in writing, including by e-mail, of the County's objection(s) to the preliminary schedule of values. Within five (5) calendar days of the date of the County's written objection(s), Contractor shall submit a revised preliminary schedule of values to the County for review and approval. The foregoing procedure for the preparation, review, and approval of the preliminary schedule of values shall continue until the County has approved the entirety of the preliminary schedule of values.

10.1.6 Once the preliminary schedule of values is approved by the County, this shall become the Schedule of Values. The Schedule of Values shall not be thereafter modified or amended by the Contractor without the prior consent and approval of the County, which may be granted or withheld in the sole discretion of the County.

#### 10.1.7 Preliminary Schedule of Submittals

A preliminary schedule of submittals, including Shop Drawings, Product Data, and Samples submittals. Once approved by County, this shall become the Submittal Schedule. All submittals shall be forwarded to the County by the date indicated on the approved Submittal Schedule unless an earlier date is necessary to maintain the Construction Schedule, in which case those submittals shall be forwarded to the County so as not to delay the Construction Schedule.

#### **10.1.8 Safety Plan**

Contractor's Safety Plan specifically adapted for the Project. Contractor's Safety Plan shall comply with the following requirements:

- 10.1.8.1** All applicable requirements of California Division of Industrial Safety ("CalOSHA") and/or of the United States Occupational Safety and Health Administration ("OSHA").
- 10.1.8.2** All provisions regarding Project safety, including all applicable provisions of these General Conditions.
- 10.1.8.3** All applicable requirements in accordance with Alameda County Health Officer order [construction project safety protocols](#).
- 10.1.8.4** Contractor's Safety Plan shall be in English and in the language(s) of the Contractor's and its Subcontractors' employees.

#### **Complete Subcontractor List**

The name, address, telephone number, facsimile number, California State Contractors License number, classification, and monetary value of all Subcontracts for parties furnishing labor, material, or equipment for completion of the Project.

#### **10.1.9 General Requirements**

- 10.1.9.1** Contractor must provide all schedules both in hard copy and electronically, in a format (e.g., Microsoft Project or Primavera) approved in advance by the County.
- 10.1.9.2** The County will review the schedules submitted, and the Contractor shall make changes and corrections in the schedules as requested by the County and resubmit the schedules until approved by the County.
- 10.1.9.3** The County shall have the right at any time to revise the schedule of values if, in the County's sole opinion, the schedule of values does not accurately reflect the value of the Work performed.
- 10.1.9.4** All submittals and schedules must be approved by the County before Contractor can rely on them as a basis for payment.

#### **10.2 Monthly Progress Schedule(s)**

**10.2.1** Upon request by the County, Contractor shall provide Monthly Progress Schedule(s) to the County. A Monthly Progress Schedule shall update the approved Construction Schedule or the last Monthly Progress Schedule, showing all work completed and to be completed. The monthly Progress Schedule shall be sent within the timeframe requested by the County and shall be in a format acceptable to the County and

contain a written narrative of the progress of work that month and any changes, delays, or events that may affect the work. The process for County approval of the Monthly Progress Schedule shall be the same as the process for approval of the Construction Schedule.

**10.2.2** Contractor shall also submit Monthly Progress Schedule(s) with all payment applications.

**10.3 Material Safety Data Sheets (MSDS)**

Contractor is required to ensure Material Safety Data Sheets are available in a readily accessible place at the Work Site for any material requiring a Material Safety Data Sheet per the Federal "Hazard Communication" standard, or employees right to know law. The Contractor is also required to ensure proper labeling on substance brought onto the job site and that any person working with the material or within the general area of the material is informed of the hazards of the substance and follows proper handling and protection procedures. Two additional copies of the Material Safety Data Sheets shall also be submitted directly to the County.

**11. SITE ACCESS, CONDITIONS, AND REQUIREMENTS**

**11.1 Site Investigation**

Before bidding on this Work, Contractor shall make a careful investigation of the Site and thoroughly familiarize itself with the requirements of the Contract. By the act of submitting a bid for the Work included in this Contract, Contractor shall be deemed to have made a complete study and investigation, and to be familiar with and accepted the existing conditions of the Site.

**11.2 Soils Investigation Report**

**11.2.1** When a soils investigation report obtained from test holes at Site is available, that report shall be available to the Contractor but shall not be a part of this Contract. Any information obtained from that report or any information given on Drawings as to subsurface soil condition or to elevations of existing grades or elevations of underlying rock is approximate only, is not guaranteed, does not form a part of this Contract, and Contractor may not rely thereon. By submitting its bid, Contractor acknowledges that it has made a visual examination of Site and has made whatever tests Contractor deems appropriate to determine underground condition of the soil.

**11.2.2** Contractor agrees that no claim against County will be made by Contractor for damages and hereby waives any rights to damages if, during progress of Work, Contractor encounters subsurface or latent conditions at Site materially differing from those shown on Drawings or indicated in Specifications, or for unknown conditions of an unusual nature that differ materially from those ordinarily encountered in the work of the character provided for in Plans and Specifications, except as indicated in the provisions of these General Conditions regarding trenches, trenching, and/or existing utility lines.

**11.3 Access to Work**

County and its representatives shall at all times have access to Work wherever it is in preparation or progress, including storage and fabrication. Contractor shall provide safe and proper facilities for such access so that County's representatives may perform their functions.

#### **11.4 Layout and Field Engineering**

**11.4.1** All field engineering required for layout of this Work and establishing grades for earthwork operations shall be furnished by Contractor at its expense. This Work shall be done by a qualified, California-registered civil engineer approved in writing by County and Architect. Any required "Record" drawings of Site development shall be prepared by the approved civil engineer.

**11.4.2** The Contractor shall be responsible for having ascertained pertinent local conditions such as location, accessibility, and general character of the Site and for having satisfied itself as to the conditions under which the Work is to be performed. County shall not be liable for any claim for allowances because of Contractor's error or negligence in acquainting itself with the conditions at the Site.

**11.4.3** Contractor shall protect and preserve established benchmarks and monuments and shall make no changes in locations without the prior written approval of County. Contractor shall replace any benchmarks or monuments that are lost or destroyed subsequent to proper notification of County and with County's approval.

#### **11.5 Utilities**

Utilities shall be provided as indicated in the Specifications.

#### **11.6 Sanitary Facilities**

Sanitary facilities shall be provided as indicated in the Specifications.

#### **11.7 Surveys**

Contractor shall provide surveys done by a California-licensed civil engineer surveyor to determine locations of construction, grading, and site work as required to perform the Work.

#### **11.8 Regional Notification Center**

The Contractor, except in an emergency, shall contact the appropriate regional notification center at least two (2) days prior to commencing any excavation if the excavation will be conducted in an area or in a private easement that is known, or reasonably should be known, to contain subsurface installations other than the underground facilities owned or operated by the County, and obtain an inquiry identification number from that notification center. No excavation shall be commenced and/or carried out by the Contractor unless an inquiry identification number has been assigned to the Contractor or any Subcontractor, and the Contractor has given the County the identification number. Any damages arising from Contractor's failure to make appropriate notification shall be at the sole risk and expense of the Contractor. Any delays caused by failure to make appropriate notification shall be at the sole risk of the Contractor and shall not be considered for an extension of the Contract time.

#### **11.9 Existing Utility Lines**

**11.9.1** Pursuant to Government Code § 4215, County assumes the responsibility for removal, relocation, and protection of main or trunk utility lines and facilities located on the Construction Site at the time of commencement of construction under this Contract with respect to any such utility facilities that are not identified in the



Plans and Specifications. Contractor shall not be assessed for liquidated damages for delay in completion of the Project caused by failure of County or the owner of a utility to provide for removal or relocation of such utility facilities.

**11.9.2** Locations of existing utilities provided by County shall not be considered exact, but approximate within reasonable margin and shall not relieve Contractor of responsibilities to exercise reasonable care nor costs of repair due to Contractor's failure to do so. County shall compensate Contractor for the costs of locating, repairing damage, not due to the failure of Contractor to exercise reasonable care, and removing or relocating such utility facilities not indicated in the Plans and Specifications with reasonable accuracy, and for equipment necessarily idle during such work.

**11.9.3** No provision herein shall be construed to preclude assessment against Contractor for any other delays in completion of the Work. Nothing in this Article shall be deemed to require County to indicate the presence of existing service laterals, appurtenances, or other utility lines, with the exception of main or trunk utility lines. Whenever the presence of these utilities on the Site of the construction Project can be inferred from the presence of other visible facilities, such as buildings, meter junction boxes, on or adjacent to the Site of the construction.

**11.9.4** If Contractor, while performing Work under this Contract, discovers utility facilities not identified by County in Contract Plans and Specifications, Contractor shall immediately notify the County and the utility in writing. The cost of repair for damage to above-mentioned visible facilities without prior written notification to the County shall be borne by the Contractor.

#### **11.10 Notification**

Contractor understands, acknowledges and agrees that the purpose for prompt notification to the County pursuant to these provisions is to allow the County to investigate the condition(s) so that the County shall have the opportunity to decide how the County desires to proceed as a result of the condition(s). Accordingly, failure of Contractor to promptly notify the County in writing, including by e-mail, pursuant to these provisions, shall constitute Contractor's waiver of any claim for damages or delay incurred as a result of the condition(s).

#### **11.11 Hazardous Materials**

Contractor shall comply with all provisions and requirements of the Contract Documents related to hazardous materials including, without limitation, Hazardous Materials Procedures, and Requirements.

#### **11.12 No Signs**

Neither the Contractor nor any other person or entity shall display any signs not required by law or the Contract Documents at the Site, fences trailers, offices, or elsewhere on the Site without specific prior written approval of the County.

### **12. TRENCHES**

#### **12.1 Trenches Greater Than Five Feet**

Pursuant to Labor Code § 6705, if the Contract Price exceeds \$25,000 and involves the excavation of any trench or trenches five (5) feet or more in depth, the

Contractor shall, in advance of excavation, promptly submit to the County and/or a registered civil or structural engineer employed by the County or Architect, a detailed plan showing the design of shoring for protection from the hazard of caving ground during the excavation of such trench or trenches.

**12.2 Excavation Safety**

If such plan varies from the Shoring System Standards established by the Construction Safety Orders, the plan shall be prepared by a registered civil or structural engineer, but in no case shall such plan be less effective than that required by the Construction Safety Orders. No excavation of such trench or trenches shall be commenced until said plan has been accepted by the County or by the person to whom authority to accept has been delegated by the County.

**12.3 No Tort Liability of County**

Pursuant to Labor Code § 6705, nothing in this Article shall impose tort liability upon the County or any of its employees.

**12.4 No Excavation Without Permits**

The Contractor shall not commence any excavation Work until it has secured all necessary permits including the required CalOSHA excavation/shoring permit. Any permits shall be prominently displayed on the Site prior to the commencement of any excavation.

**12.5 Discovery of Hazardous Waste and/or Unusual Conditions**

**12.5.1** Pursuant to Public Contract Code § 7104, if the Work involves digging trenches or other excavations that extend deeper than four feet below the Surface, the Contractor shall promptly, and before the following conditions are disturbed, notify the County, in writing, including by e-mail, of any:

**12.5.1.1** Material that the Contractor believes may be material that is hazardous waste, as defined in § 25117 of the Health and Safety Code that is required to be removed to a Class I, Class II, or Class III disposal site in accordance with provisions of existing law.

**12.5.1.2** Subsurface or latent physical conditions at the Site differing from those indicated.

**12.5.1.3** Unknown physical conditions at the Site of any unusual nature, different materially from those ordinarily encountered and generally recognized as inherent in work of the character provided for in the Contract.

**12.5.2** The County shall promptly investigate the conditions, and if it finds that the conditions do materially so differ, or do involve hazardous waste, and cause a decrease or increase in the Contractor's cost of, or the time required for, performance of any part of the Work, shall issue a Change Order under the procedures described herein.

**12.5.3** In the event that a dispute arises between County and the Contractor whether the conditions materially differ, or involve hazardous waste, or cause a decrease or increase in the Contractor's cost of, or time required for, performance of any part of the

Work, the Contractor shall not be excused from any scheduled completion date provided for in the Contract, but shall proceed with all work to be performed under the Contract. The Contractor shall retain any and all rights provided either by Contract or by law that pertains to the resolution of disputes and protests.

### **13. INSURANCE AND BONDS**

#### **13.1 Insurance**

All insurance required of Contractor and/or its Subcontractor(s) shall be in amounts set forth in the Special Conditions and include the provisions as set forth herein.

##### **13.1.1 Commercial General Liability and Automobile Liability Insurance**

**13.1.1.1** Contractor shall procure and maintain, during the life of this Contract, Commercial General Liability Insurance and Automobile Liability Insurance that shall protect Contractor, County, Construction Manager(s), and Architect(s) from all claims for bodily injury, property damage, personal injury, death, advertising injury, and medical payments arising from operations under this Contract. Contractor shall ensure that Products Liability and Completed Operations coverage and Fire Damage Liability is included within the above policies and within the required limits, or Contractor shall procure and maintain these coverages separately.

**13.1.1.2** Subcontractor: Contractor shall require its Subcontractors if any, to procure and maintain similar Commercial General Liability Insurance and Automobile Liability Insurance with minimum limits equal to the amount required of the Contractor. Contractor shall verify Subcontractor's compliance.

##### **13.1.2 Excess Liability Insurance**

**13.1.2.1** Contractor shall procure and maintain, during the life of this Contract, Excess Liability Insurance that shall protect Contractor, County, Construction Manager(s), and Architect(s) in amounts and including the provisions as set forth in the Special Conditions, and that complies with all requirements for Commercial General Liability and Automobile Liability and Employers' Liability Insurance.

**13.1.2.2** Subcontractor: Contractor shall require its Subcontractor(s) if any, to procure and maintain similar Excess Liability Insurance with minimum limits equal to the amount required of the Contractor. Contractor shall verify Subcontractor's compliance.

##### **13.1.3 Workers' Compensation and Employers' Liability Insurance**

**13.1.3.1** In accordance with provisions of § 3700 of the California Labor Code, the Contractor and every Subcontractor shall be required to secure the payment of compensation to its employees.

**13.1.3.2** Contractor shall procure and maintain, during the life of this Contract, Workers' Compensation Insurance and Employers' Liability Insurance for all of its employees engaged in work under this

Contract, on/or at the Site of the Project. This coverage shall cover, at a minimum, medical and surgical treatment, disability benefits, rehabilitation therapy, and survivors' death benefits. Contractor shall require its Subcontractor(s) if any, to procure and maintain Workers' Compensation Insurance and Employers' Liability Insurance for all employees of Subcontractor(s). Any class of employee or employees not covered by a Subcontractor's insurance shall be covered by Contractor's insurance. If any class of employee or employees engaged in Work under this Contract, on or at the Site of the Project, is not protected under the Workers' Compensation Statute, Contractor shall provide, or shall cause a Subcontractor to provide, adequate insurance coverage for the protection of any employee(s) not otherwise protected before any of those employee(s) commence work.

**13.1.4 Builder's Risk Insurance: Builder's Risk "All-Risk" Insurance.**

Contractor shall procure and maintain, during the life of this Contract, Builder's Risk (Course of Construction), or similar first party property coverage acceptable to the County, issued on a replacement cost value basis. The cost shall be consistent with the total replacement cost of all insurable Work of the Project included within the Contract Documents. Coverage is to insure against all risks of accidental physical loss and shall include without limitation the perils of vandalism and/or malicious mischief (both without any limitation regarding vacancy or occupancy), sprinkler leakage, civil authority, sonic disturbance, earthquake, flood, collapse, wind, fire, war, terrorism, lightning, smoke, and rioting. Coverage shall include debris removal, demolition, increased costs due to enforcement of all applicable ordinances and/or laws in the repair and replacement of damaged and undamaged portions of the property, and reasonable costs for the Architect's and engineering services and expenses required as a result of any insured loss upon the Work and Project, including completed Work and Work in Progress, to the full insurable value thereof.

**13.1.5 Proof of Carriage of Insurance and Other Requirements: Endorsements and Certificates.**

**13.1.5.1** Contractor shall not commence Work nor shall it allow any Subcontractor to commence Work under this Contract, until Contractor and its Subcontractor(s) have procured all required insurance and Contractor has delivered in duplicate to the County complete endorsements (or entire insurance policies) and certificates indicating the required coverages have been obtained, and the County has approved these documents.

**13.1.5.2** Endorsements, certificates, and insurance policies shall include the following:

**13.1.5.2.1** A clause stating:

"This policy shall not be amended, canceled or modified and the coverage amounts shall not be reduced until notice has been mailed to County, Architect, and Construction Manager stating date of amendment, modification, cancellation or reduction. Date of

amendment, modification, cancellation or reduction may not be less than thirty (30) days after date of mailing notice.”

**13.1.5.2.2** Language stating, in particular, those insured, extent of insurance, location and operation to which insurance applies, expiration date, to whom cancellation and reduction notice will be sent, and length of notice period.

**13.1.5.3** All endorsements, certificates and insurance policies shall state that County, its Supervisors, employees, and agents, Construction Manager(s), and Architect(s) are named additional insureds under all policies except Workers’ Compensation Insurance and Employers’ Liability Insurance. Contractor’s and Subcontractors’ insurance policy(s) shall be primary and non-contribution to any insurance or self-insurance maintained by County, its Supervisors, employees and/or agents, Construction Manager(s), and/or Architect(s). All endorsements shall waive any right to subrogation against any of the named additional insureds.

**13.1.5.4** All policies shall be written on an occurrence form.

## **13.2 Contract Security - Bonds**

**13.2.1** Contractor shall furnish two surety bonds issued by a California admitted surety insurer as follows:

**13.2.1.1** Performance Bond: A bond in an amount at least equal to one hundred percent (100%) of Contract Price as security for faithful performance of this Contract.

**13.2.1.2** Payment Bond: A bond in an amount at least equal to one hundred percent (100%) of the Contract Price as security for payment of persons performing labor and/or furnishing materials in connection with this Contract.

**13.2.2** Cost of bonds shall be included in the Bid and Contract Price.

**13.2.3** All bonds related to this Project shall be in the forms set forth in these Contract Documents and shall comply with all requirements of the Contract Documents, including, without limitation, the bond forms.

## **14. WARRANTY/GUARANTEE/INDEMNITY**

### **14.1 Warranty/Guarantee**

**14.1.1** The Contractor shall obtain and preserve for the benefit of the County, manufacturer’s warranties on materials, fixtures, and equipment incorporated into the Work.

**14.1.2** In addition to guarantees required elsewhere, Contractor shall, and hereby does guarantee and warrant all Work furnished on the job against all defects for a period of TWO (2) years after the later of the following dates:

**14.1.2.1** The date of completion as defined in Public Contract Code § 7107, subdivision (c),

**14.1.2.2** The commissioning date for the Project, if any.

**14.1.3** At the County's sole option, Contractor shall repair or replace any and all of that Work, together with any other Work that may be displaced in so doing, that may prove defective in workmanship and/or materials within the warranty period specified in § 00 65 36 Warranty Form, from date of completion as defined above without expense whatsoever to County. In the event of failure of Contractor and/or Surety to commence and pursue with diligence said replacements or repairs within ten (10) days after being notified in writing, including by e-mail, Contractor and Surety hereby acknowledge and agree that County is authorized to proceed to have defects repaired and made good at expense of Contractor and/or Surety who hereby agree to pay costs and charges therefore immediately on demand. Said notice period shall be forty-eight (48) hours for components essential to operation of the facility, including without limitation fire alarms, water, heat, security systems, and electrical systems.

**14.1.4** If, in the opinion of County, defective work creates a dangerous condition or requires immediate correction or attention to prevent further loss to County or to prevent interruption of operations of County, County will attempt to give the notice required above. If Contractor or Surety cannot be contacted or does not comply with County's request for correction within a reasonable time as determined by County, County may, notwithstanding the above provision, proceed to make any and all corrections and/or provide attentions the County believes are necessary. The costs of correction or attention shall be charged against Contractor and Surety of the guarantees provided in this Article or elsewhere in this Contract.

**14.1.5** The above provisions do not in any way limit the guarantees on any items for which a longer guarantee is specified or on any items for which a manufacturer gives a guarantee for a longer period. Contractor shall furnish to County all appropriate guarantee or warranty certificates as indicated in the Specifications or upon request by County.

**14.1.6** Nothing herein shall limit any other rights or remedies available to County.

## **14.2 Indemnity**

**14.2.1** To the fullest extent permitted by California law, the Contractor shall indemnify, defend with legal counsel reasonably acceptable to the County, keep and hold harmless the County and its consultants, the Architect and its consultants, the Construction Manager and its consultants, separate contractors, and their respective board members, officers, representatives, contractors, agents, and employees, in both individual and official capacities ("Indemnitees"), against all suits, claims, liabilities, damages, losses, and expenses caused by, arising out of, resulting from, or incidental to, the performance of the Work under this Contract by the Contractor or its Subcontractors to the full extent allowed by the laws of the State of California, and not to any extent that would render these provisions void or unenforceable, including, without limitation, any such suit, claim, damage, loss, or expense attributable to, without limitation, bodily injury, sickness, disease, death, alleged patent violation or copyright infringement, or to injury to or destruction of

tangible property (including damage to the Work itself) including the loss of use resulting therefrom, except to the extent caused solely by the negligence, or willful misconduct of the Indemnitees. The County may participate in the defense of any such claim without relieving Contractor of any obligation hereunder. This agreement and obligation of the Contractor shall not be construed to negate, abridge, or otherwise reduce any right or obligation of indemnity that would otherwise exist as to any party or person described herein. This indemnification, defense, and hold harmless obligation includes any failure or alleged failure by Contractor to comply with any provision of law or the Contract Documents, including, without limitation, any stop notice actions, or liens by the California Department of Labor Standards Enforcement. This indemnity obligation shall be for the full amount of all damage to County, including defense costs, and shall not be limited by any insurance limits.

**14.2.2** The Contractor shall give prompt notice to the County in the event of any injury (including death), loss or damage included herein. Without limitation of the provisions herein, if the Contractor's agreement to indemnify, defend, and hold harmless the Indemnitees as provided herein against liability for damage arising out of bodily injury to persons or damage to property caused by or resulting from the negligence of any of the Indemnitees shall to any extent be or be determined to be void or unenforceable, it is the intention of the parties that these circumstances shall not otherwise affect the validity or enforceability of the Contractor's agreement to indemnify, defend, and hold harmless the rest of the Indemnitees, as provided herein, and in the case of any such suits, claims, damages, losses, or expenses caused in part by the default, negligence, or act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, and in part by any of the Indemnitees, the Contractor shall be and remain fully liable on its agreements and obligations herein to the full extent permitted by law.

**14.2.3** In any and all claims against any of the Indemnitees by any employee of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, the Contractor's indemnification obligation herein shall not be limited in any way by any limitation on the amount or type of damages, compensation, or benefits payable by or for the Contractor or any Subcontractor under workers' compensation acts, disability benefit acts, or other employee benefit acts.

**14.2.4** Contractor shall place in its Subcontractor agreements and cause its Subcontractors to agree to indemnities and insurance obligations in favor of County and other Indemnities in the exact form and substance of those contained in these General Conditions (00 72 13). Contractor shall require all Subcontractors to comply with all indemnification and insurance requirements of this agreement. Contractor shall verify Subcontractor's compliance.

## **15. TIME**

### **15.1 Notice to Proceed**

**15.1.1** County may issue a Notice to Proceed within three (3) months from the date of the Notice of Award. Once Contractor has received the Notice to Proceed,

Contractor shall complete the Work within the period of time indicated in the Contract Documents.

**15.1.2** In the event that the County desires to postpone issuing the Notice to Proceed beyond this 3-month period, it is expressly understood that with reasonable notice to the Contractor, the County may postpone issuing the Notice to Proceed. It is further expressly understood by Contractor that Contractor shall not be entitled to any claim of additional compensation as a result of the postponement of the issuance of the Notice to Proceed.

**15.1.3** If the Contractor believes that a postponement of issuance of the Notice to Proceed will cause a hardship to Contractor, Contractor may terminate the Contract. Contractor's termination due to a postponement shall be by written notice to County within ten (10) days after receipt by Contractor of County's notice of postponement. It is further understood by Contractor that in the event that Contractor terminates the Contract as a result of postponement by the County, the County shall only be obligated to pay Contractor for the Work that Contractor had performed at the time of notification of postponement. Should Contractor terminate the Contract as a result of a notice of postponement, County shall have the authority to award the Contract to the next lowest responsive, responsible bidder.

## **15.2 Computation of Time / Adverse Weather**

**15.2.1** The Contractor will only be allowed a time extension for Adverse Weather conditions if requested by Contractor and only if all of the following conditions are met:

**15.2.1.1** The weather conditions constitute Adverse Weather, as defined herein and further specified in the Special Conditions;

**15.2.1.2** Contractor can verify that the Adverse Weather caused delays in excess of seventy-five percent (75%) for at least five hours, of the normal labor and equipment force toward completion of the day's current controlling item(s) on the latest accepted schedule;

**15.2.1.3** The Contractor's crew is dismissed as a result of the Adverse Weather; and

**15.2.1.4** The number of days of delay for the month exceeds those indicated in the Special Conditions.

**15.2.2** A day-for-day extension will only be allowed for those days in excess of those indicated in the Special Conditions. Weather delay time extensions to the contract period will be non-compensable.

**15.2.3** The Contractor shall work seven (7) days per week, if necessary, irrespective of inclement weather, to maintain access and the Construction Schedule, and to protect the Work under construction from the effects of Adverse Weather, all at no further cost to the County.

**15.2.4** The Contract Time has been determined with consideration given to the average climate weather conditions prevailing in the County in which the Project is located.



**15.3 Hours of Work**

**15.3.1 Sufficient Forces**

Contractor and Subcontractors shall continuously furnish sufficient forces to ensure the prosecution of the Work in accordance with the Construction Schedule.

**15.3.2 Performance During Working Hours**

Work shall be performed during regular working hours as permitted by the appropriate governmental agency except that in the event of an emergency, or when required to complete the Work in accordance with job progress, Work may be performed outside of regular working hours with the advance written consent of the County and approval of any required governmental agencies.

**15.4 Progress and Completion**

**15.4.1 Time of the Essence**

Time limits stated in the Contract Documents are of the essence to the Contract. By executing the Agreement, the Contractor confirms that the Contract Time is a reasonable period for performing the Work.

**15.4.2 No Commencement Without Insurance**

The Contractor shall not commence operations on the Project or elsewhere prior to the effective date of insurance and bonds. The date of commencement of the Work shall not be changed by the effective date of such insurance. If Contractor commences Work without insurance and bonds, all Work is performed at Contractor's peril and shall not be compensable until and unless Contractor secures bonds and insurance pursuant to the terms of the Contract Documents and subject to County claim for damages.

**15.5 Expeditious Completion**

The Contractor shall proceed expeditiously with adequate forces and shall achieve Completion within the Contract Time.

**16. EXTENSIONS OF TIME – LIQUIDATED DAMAGES**

**16.1 Liquidated Damages**

Contractor and County hereby agree that the exact amount of damages for failure to complete the Work within the time specified is extremely difficult or impossible to determine. If the Work is not completed within the time specified in the Contract Documents, it is understood that the County will suffer damage. It being impractical and unfeasible to determine the amount of actual damage, it is agreed the Contractor shall pay to County as fixed and liquidated damages, and not as a penalty, the amount set forth in the Agreement for each calendar day of delay in completion. Contractor and its Surety shall be liable for the amount thereof pursuant to Government Code § 53069.85.

**16.2 Excusable Delay**

**16.2.1** Contractor shall not be charged for liquidated damages because of any delays in completion of Work which are not the fault of Contractor or its Subcontractors, including acts of God as defined in Public Contract Code § 7105, acts of enemy, epidemics, and quarantine restrictions. Contractor shall, within five (5) calendar

days of beginning of any delay, notify County in writing of causes of delay including documentation and facts explaining the delay. County shall review the facts and extent of any delay and shall grant extension(s) of time for completing Work when, in its judgment, the findings of fact justify an extension. Extension(s) of time shall apply only to that portion of Work affected by delay, and shall not apply to other portions of Work not so affected. An extension of time may only be granted if Contractor has timely submitted the Construction Schedule as required herein.

**16.2.2** Contractor shall notify the County pursuant to the claims provisions in these General Conditions of any anticipated delay and its cause. Following submission of a claim, the County may determine whether the delay is to be considered avoidable or unavoidable, how long it continues, and to what extent the prosecution and completion of the Work might be delayed thereby.

**16.2.3** In the event the Contractor requests an extension of Contract Time for unavoidable delay, such request shall be submitted in accordance with the provisions in the Contract Documents governing changes in Work. When requesting time, requests must be submitted with full justification and documentation. If the Contractor fails to submit justification, it waives its right to a time extension at a later date. Such justification must be based on the official Construction Schedule as updated at the time of occurrence of the delay or execution of Work related to any changes to the Scope of Work. Any claim for delay must include the following information as support, without limitation:

**16.2.3.1** The duration of the activity relating to the changes in the Work and the resources (manpower, equipment, material, etc.) required to perform the activities within the stated duration.

**16.2.3.2** Specific logical ties to the Contract Schedule for the proposed changes and/or delay showing the activity/activities in the Construction Schedule that are affected by the change and/or delay.

**16.2.3.3** A recovery schedule must be submitted.

**16.3 No Additional Compensation for Delays Within Contractor's Control**

**16.3.1** Contractor is aware that governmental agencies, including, without limitation, the Department of General Services, gas companies, electrical utility companies, water companies, and other agencies may have to approve Contractor-prepared drawings or approve a proposed installation. Accordingly, Contractor shall include in its bid, time for possible review of its drawings and for reasonable delays and damages that may be caused by such agencies. Thus, Contractor is not entitled to make a claim for damages or delays arising from the review of Contractor's drawings.

**16.3.2** Contractor shall only be entitled to compensation for delay when all of the following conditions are met:

**16.3.2.1** The County is responsible for the delay;

**16.3.2.2** The delay is unreasonable under the circumstances involved;

**16.3.2.3** The delay was not within the contemplation of County and Contractor; and

**16.3.2.4** Contractor complies with the claims procedure of the Contract Documents.

**16.4 Float or Slack in the Schedule**

Float or slack is the amount of time between the early start date and the late start date, or the early finish date and the late finish date, of any of the activities in the schedule. Float or slack is not for the exclusive use of or benefit of either the County or the Contractor, but its use shall be determined solely by the County.

**17. CHANGES IN THE WORK**

**17.1 No Changes Without Authorization**

**17.1.1** There shall be no change whatsoever in the Drawings, Specifications, or in the Work without an executed Change Order or a written Construction Change Directive authorized by the County as herein provided. County shall not be liable for the cost of any extra work or any substitutions, changes, additions, omissions, or deviations from the Drawings and Specifications unless the County's governing board has authorized the same and the cost thereof has been approved in writing by Change Order or Construction Change Directive. No extension of time for performance of the Work shall be allowed hereunder unless claim for such extension is made at the time changes in the Work are ordered, and such time duly adjusted in writing in the Change Order or Construction Change Directive. The provisions of the Contract Documents shall apply to all such changes, additions, and omissions with the same effect as if originally embodied in the Drawings and Specifications.

**17.1.2** Contractor shall perform immediately all work that has been authorized by a fully executed Change Order or Construction Change Directive. Contractor shall be fully responsible for any and all delays and/or expenses caused by Contractor's failure to expeditiously perform this Work.

**17.1.3** Should any Change Order result in an increase in the Contract Price, the cost of that Change Order shall be agreed to, in writing, in advance by Contractor and County and be subject to the monetary limitations set forth in Public Contract Code § 20137. In the event that Contractor proceeds with any change in Work without a Change Order executed by the County or Construction Change Directive, Contractor waives any claim for additional compensation or time for that additional work.

**17.1.4** Contractor understands, acknowledges, and agrees that the reason for County authorization is so that County may have an opportunity to analyze the Work and decide whether the County shall proceed with the Change Order or alter the Project so that a change in Work becomes unnecessary.

**17.2 Architect Authority to Order Minor Changes**

The Architect will have authority to order minor changes in the Work not involving any adjustment in the Contract Price, or an extension of the Contract Time, or a change that is inconsistent with the intent of the Contract Documents. These changes shall be effected by written Change Order, Construction Change Directive, or by Architect's response(s) to RFI(s).

**17.3 Change Orders**

**17.3.1** A Change Order is a written instrument prepared and issued by the County and/or the Architect and signed by the County (as authorized by the County's Board of Supervisors), the Contractor, and the Architect, stating their agreement regarding all of the following:

**17.3.1.1** A description of a change in the Work;

**17.3.1.2** The amount of the adjustment in the Contract Price, if any; and

**17.3.1.3** The extent of the adjustment in the Contract Time, if any.

**17.4 Construction Change Directives**

**17.4.1** A Construction Change Directive is a written order prepared and issued by the County, the Construction Manager, and/or the Architect and signed by the County and the Architect, directing a change in the Work. The County may as provided by law, by Construction Change Directive and without invalidating the Contract, order changes in the Work consisting of additions, deletions, or other revisions. Any dispute as to the sum of the Construction Change Directive or timing of payment shall be resolved pursuant to the Payment and Claims and Disputes provisions herein.

**17.4.2** The County may issue a Construction Change Directive in the absence of agreement on the terms of a Change Order.

**17.5 Force Account Directives**

**17.5.1** When work, for which a definite price has not been agreed upon in advance, is to be paid for on a force account basis, all direct costs necessarily incurred and paid by the Contractor for labor, material, and equipment used in the performance of that Work, shall be subject to the approval of the County and compensation will be determined as set forth herein.

**17.5.2** The County will issue a Force Account Directive to proceed with the Work on a force account basis, and a not-to-exceed budget will be established by the County.

**17.5.3** All requirements regarding direct cost for labor, labor burden, material, equipment, and markups on direct costs for overhead and profit described in this section shall apply to Force Account Directives. However, the County will only pay for actual costs verified in the field by the County or its authorized representative(s) on a daily basis.

**17.5.4** The Contractor shall be responsible for all cost related to the administration of Force Account Directive. The markup for overhead and profit for Contractor modifications shall be full compensation to the Contractor to administer Force Account Directive.

**17.5.5** The Contractor shall notify the County or its authorized representative(s) at least twenty-four (24) hours prior to proceeding with any of the force account work. Furthermore, the Contractor shall notify the County when it has consumed eighty percent (80%) of the budget and shall not exceed the budget unless specifically authorized in writing by the County. The Contractor will not be compensated for force account work in the event that the Contractor fails to timely notify the County regarding the commencement of force account work, or exceeding the force account budget.

**17.5.6** The Contractor shall diligently proceed with the work, and on a daily basis, submit a daily force account report on a form supplied by the County no later than 5:00 p.m. each day. The report shall contain a detailed itemization of the daily labor, material, and equipment used on the force account work only. The names of the individuals performing the force account work shall be included in the daily force account reports. The type and model of equipment shall be identified and listed. The County will review the information contained in the reports, and sign the reports no later than the next work day, and return a copy of the report to the Contractor for their records. The County will not sign, nor will the Contractor receive compensation for work the County cannot verify. The Contractor will provide a weekly force account summary indicating the status of each Force Account Directive in terms of percent complete of the not-to-exceed budget and the estimated percent complete of the work.

**17.5.7** In the event the Contractor and the County reach a written agreement on a set cost for the work while the work is proceeding based on a Force Account Directive, the Contractor's signed daily force account reports shall be discontinued, and all previously signed reports shall be invalid.

## **17.6 Price Request**

### **17.6.1 Definition of Price Request**

A Price Request ("PR") is a written request prepared by the Architect requesting the Contractor to submit to the County and the Architect an estimate of the effect of a proposed change in the Work on the Contract Price and the Contract Time.

### **17.6.2 Scope of Price Request**

A Price Request shall contain adequate information, including any necessary Drawings and Specifications, to enable Contractor to provide the cost breakdowns required herein. The Contractor shall not be entitled to any additional compensation for preparing a response to a Price Request, whether ultimately accepted or not.

## **17.7 Proposed Change Order**

### **17.7.1 Definition of Proposed Change Order**

A Proposed Change Order ("PCO") is a written request prepared by the Contractor requesting that the County and the Architect issue a Change Order based upon a proposed change to the Work.

### **17.7.2 Changes in Contract Price**

A PCO shall include breakdowns pursuant to the revisions herein to validate any change in Contract Price.

### **17.7.3 Changes in Time**

A PCO shall also include any changes in time required to complete the Project. Any additional time requested shall not be the number of days to make the proposed change, but must be based upon the impact to the Construction Schedule as defined in the Contract Documents. If Contractor fails to request a time extension in a PCO, then the Contractor is thereafter precluded from requesting time and/or claiming a delay.

### **17.7.4 Unknown and/or Unforeseen Conditions**

If Contractor submits a PCO requesting an increase in Contract Price and/or Contract Time that is based at least partially on Contractor's assertion that Contractor has encountered unknown and/or unforeseen condition(s) on the Project, then Contractor shall base the PCO on provable information that, beyond a reasonable doubt and to the County's satisfaction, demonstrates that the unknown and/or unforeseen condition(s) were actually unknown and/or unforeseen and that the condition(s) were reasonably unknown and/or unforeseen. If not, the County shall deny the PCO and the Contractor shall complete the Project without any increase in Contract Price and/or Contract Time based on that PCO.

## 17.8 Format for Proposed Change

**17.8.1** The following format shall be used as applicable by the County and the Contractor (e.g. Change Orders, PCO's) to communicate proposed additions and deductions to the Contract, supported by attached documentation. In no case shall the Contractor's total mark-up exceed 26.5%.

	<u>SUBCONTRACTOR PERFORMED WORK</u>	<u>ADD</u>	<u>DEDUCT</u>
a)	<u>Material</u> (attach itemized quantity and unit cost plus sales tax)		
b)	<u>Add Labor</u> (attach itemized hours and rates, fully encumbered)		
c)	<u>Add Equipment</u> (attach suppliers' invoice)		
d)	<u>Subtotal</u>		
e)	<u>Add Subcontractor's overhead and profit</u> , not to exceed ten percent (10%) of item (d)		
f)	<u>Subtotal</u>		
g)	<u>Add Contractor's overhead and profit</u> , not to exceed ten percent (10%) of Item (f)		
h)	<u>Subtotal</u>		
i)	<u>Add Bond and Insurance</u> , not to exceed one percent (1%) of Item (h)		
j)	<u>TOTAL</u>		
k)	<u>Time</u>	<u>Days</u>	
	<u>CONTRACTOR PERFORMED WORK</u>	<u>ADD</u>	<u>DEDUCT</u>
a)	<u>Material</u> (attach itemized quantity and unit cost plus sales tax)		
b)	<u>Add Labor</u> (attach itemized hours and rates, fully encumbered)		
c)	<u>Add Equipment</u> (attach suppliers' invoice)		

d)	<u>Subtotal</u>		
e)	<u>Add Contractor's overhead and profit</u> , not to exceed ten percent (10%) of item (d)		
f)	<u>Subtotal</u>		
g)	<u>Add Bond and Insurance</u> , not to exceed one percent (1%) of Item (f)		
h)	<u>TOTAL</u>		
i)	<u>Time</u>	<u>Days</u>	

## 17.9 Change Order Certification

**17.9.1** All Change Orders and PCOs must include the following certification by the Contractor:

**17.9.1.1** The undersigned Contractor approves the foregoing as to the changes, if any, and the Contract Price specified for each item and as to the extension of time allowed, if any, for completion of the entire Work as stated herein, and agrees to furnish all labor, materials, and service, and perform all work necessary to complete any additional work specified for the consideration stated herein. Submission of sums which have no basis in fact or which Contractor knows are false are at the sole risk of Contractor and may be a violation of the False Claims Act set forth under Government Code § 12650 et seq. It is understood that the changes herein to the Contract shall only be effective when approved by the Board of Supervisors.

**17.9.1.2** It is expressly understood that the value of the extra Work or changes expressly includes any and all of the Contractor's costs and expenses, both direct and indirect, resulting from additional time required on the Project or resulting from delay to the Project. Any costs, expenses, damages, or time extensions not included are deemed waived.

## 17.10 Determination of Change Order Cost

The amount of the increase or decrease in the Contract Price from a Change Order, if any, shall be determined by one or more of the following ways as applicable to a specific situation and at the County's discretion:

**17.10.1** County acceptance of a PCO;

**17.10.2** By unit prices contained in Contractor's original bid;

**17.10.3** By agreement between County and Contractor.

## 17.11 Allowable Costs

Allowable costs for any change order shall be limited to the following:

**17.11.1** Costs of labor, including social security, Medicare, and unemployment insurance, fringe benefits required workers' compensation insurance.

**17.11.2** Costs of first line supervision labor, including labor burden as described in paragraph 1. "First-Line Supervision" shall mean a working foreman or lead craft worker other than the project superintendent;

**17.11.3** Actual costs of the project superintendent associated with any period of compensable delay caused by issuance of the change order. In the absence of a compensable delay, all of the project superintendent's time is considered to have been paid for as part of the overhead;

**17.11.4** Actual costs of materials, including sales tax and delivery;

**17.11.5** Rental costs of machinery and equipment, exclusive of small tools, whether rented from the Contractor or others. For Contractor and Subcontractor-owned equipment, payment will be made at rental rates listed for equipment in California Department of Transportation official equipment rental rate schedule. For rental equipment, payment will be made based on actual rental invoices. Rental rates paid shall be deemed to cover cost of fuel, oil, lubrication, supplies, small tools, necessary attachments, repairs and maintenance of any kind, depreciation, storage, insurance and all incidentals;

**17.11.6** Overhead and Profit as specified below. "Overhead" shall include the following:

**17.11.6.1** Preparation of all paperwork related to changes in the Work, including field review, estimating and cost breakdown; coordination and supervision, both office and field, including the project superintendent; vehicles including has and maintenance; small tools, incidentals and consumables; engineering, detailing, and revisions to shop drawings and as-built drawings; general office expense; extended and unabsorbed home office overhead; warranty, all taxes; and all other expenses not specifically described in items 17.11.1 through 17.11.5.

**17.11.6.2** The actual costs of insurance premiums required by this contract and associated with the change order work will be reimbursed by the County

**17.11.7** Upon receipt of a PCO/Change Directive, the Contractor shall promptly proceed with the change in the Work involved and advise the Construction Manager within seven (7) calendar days of the Contractor's agreement or disagreement with the method, if any, provided in the PCO/Change Directive for determining the proposed adjustment in the Contract Sum or Contract Time.

**17.11.8** Failure to respond to and return a PCO/Change Directive to the County within (7) days indicates the Contractor's agreement therewith, including adjustment in Contract Sum and Contract Time or the method for determining them. Such agreement shall be effective immediately and shall be recorded as a Change Order.

## **17.12 Deductive Change Orders**

All deductive Change Order(s) must be prepared pursuant to the provisions herein. If Contractor offers a proposed amount for a Deductive Change Order(s),



Contractor shall include a minimum of five percent (5%) total profit and overhead to be deducted with the amount of the work of the Change Order(s). If Subcontractor work is involved, Subcontractors shall also include a minimum of five percent (5%) profit and overhead to be deducted with the amount of its deducted work. Any deviation from this provision shall not be allowed.

**17.13 Discounts, Rebates, and Refunds**

For purposes of determining the cost, if any, of any change, addition, or omission to the Work hereunder, all trade discounts, rebates, refunds, and all returns from the sale of surplus materials and equipment shall accrue and be credited to the Contractor, and the Contractor shall make provisions so that such discounts, rebates, refunds, and returns may be secured, and the amount thereof shall be allowed as a reduction in the Contractor's cost in determining the actual cost of construction for purposes of any change, addition, or omission in the Work as provided herein.

**17.14 Accounting Records**

With respect to portions of the Work performed by Change Orders and Construction Change Directives, the Contractor shall keep and maintain cost-accounting records satisfactory to the County, which shall be available to the County on the same terms as any other books and records the Contractor is required to maintain under the Contract Documents.

**17.15 Notice Required**

If the Contractor desires to make a claim for an increase in the Contract Price or any extension of the Contract Time for completion, it shall notify the County pursuant to the provisions herein. No claim shall be considered unless made in accordance with this subparagraph. Contractor shall proceed to execute the Work, even though, the adjustment may not have been agreed upon. Any change in the Contract Price or extension of the Contract Time resulting from such claim shall be authorized by a Change Order.

**17.16 Applicability to Subcontractors**

Any requirements under this Article shall be equally applicable to Change Orders, or Construction Change Directives issued to Subcontractors by the Contractor to the extent as required by the Contract Documents.

**17.17 Alteration to Change Order Language**

Contractor shall not alter Change Orders or reserve time in Change Orders. Contractor shall execute finalized Change Orders and proceed under the provisions herein with proper notice.

**17.18 Failure of Contractor to Execute Change Order**

Contractor shall be in default of the Contract if Contractor fails to execute a Change Order when the Contractor agrees with the addition and/or deletion of the Work in that Change Order.

**18. REQUEST FOR INFORMATION**

**18.1** The Contractor shall coordinate the Work so that dimensions are verified, and clarifications that may affect the work are identified to allow for resolution without

delaying the Work. The Contractor is responsible to submit a Request for Information as soon as the issue requiring clarification is identified. The Contractor shall be responsible for any delay in the construction progress due to any untimely submission of a Request for Information for A/E's review. Non-receipt of a Request for Information, or proceeding with Work pertaining to the Request for Information shall be construed as relieving the County of any Claim for added cost or extension of time.

## **18.2 Reference Contract Documents**

Any Request for Information shall reference all applicable Contract Document(s), including Specification section(s), detail(s), page number(s), drawing number(s), and sheet number(s), etc. The Contractor shall make suggestions and interpretations of the issue raised by each Request for Information. A Request for Information cannot modify the Contract Price, Contract Time, or the Contract Documents.

## **18.3 Contractor Responsible For Costs**

Contractor shall be responsible for any costs incurred for professional services which County may deduct from any amounts owing to the Contractor if a Request for Information requests an interpretation or decision of a matter where the information sought is equally available to the party making the request. County, at its sole discretion, shall deduct from and/or invoice Contractor for all the professional services arising herein.

# **19. PAYMENTS**

## **19.1 Contract Price**

The Contract Price is stated in the Agreement and, including authorized adjustments, is the total amount payable by the County to the Contractor for performance of the Work under the Contract Documents.

## **19.2 Applications for Progress Payments**

### **19.2.1 Procedures for Applications for Progress Payments**

**19.2.1.1** Not before the fifth (5th) day of each calendar month during the progress of the Work, Contractor shall submit to the County and the Architect an itemized Application for Payment for operations completed in accordance with the Schedule of Values. Such application shall be notarized, if required and supported by the following or each portion thereof unless waived by the County in writing:

**19.2.1.1.1** The amount paid to the date of the Application to the Contractor, to all its Subcontractors, and all others furnishing labor, material, or equipment for its Contract;

**19.2.1.1.2** The amount being requested under the Application for Payment by the Contractor on its own behalf and separately stating the amount requested on behalf of each of the Subcontractors and all others furnishing labor, material, and equipment under the Contract;

**19.2.1.1.3** The balance that will be due to each of such entities after said payment is made;

**19.2.1.1.4** A certification that the Record Drawings and annotated Specifications are current;

**19.2.1.1.5** Itemized breakdown of work done for the purpose of requesting partial payment;

**19.2.1.1.6** An updated and acceptable construction schedule in conformance with § 10.1 above;

**19.2.1.1.7** The additions to and subtractions from the Contract Price and Contract Time;

**19.2.1.1.8** A total of the retentions held;

**19.2.1.1.9** Material invoices, evidence of equipment purchases, rentals, and other support and details of cost as the County may require from time to time;

**19.2.1.1.10** The percentage of completion of the Contractor's Work by line item;

**19.2.1.1.11** Schedule of Values updated from the preceding Application for Payment;

**19.2.1.1.12** A duly completed and executed conditional waiver and release upon progress payment compliant with Civil Code § 8132 from the Contractor and each subcontractor of any tier and supplier to be paid from the current progress payment;

**19.2.1.1.13** A duly completed and executed unconditional waiver and release upon progress payment compliant with Civil Code § 8134 from the Contractor and each subcontractor of any tier and supplier that was paid from the previous progress payment; and

**19.2.1.1.14** A certification by the Contractor of the following:

The Contractor warrants title to all Work performed as of the date of this payment application. The Contractor further warrants that all Work performed as of the date of this payment application is free and clear of liens, claims, security interests, or encumbrances in favor of the Contractor, Subcontractors, material and equipment suppliers, workers, or other persons or entities making a claim by reason of having provided labor, materials, and equipment relating to the Work, except those of which the County has been informed.

**19.2.2** The Contractor shall be subject to the False Claims Act set forth under Government Code § 12650 et seq., for information provided with any Application for Progress Payment.

**19.2.3 Prerequisites for Progress Payments**

**19.2.3.1** First Payment Request: The following items, if applicable, must be completed before the County will accept and/or process the Contractor's first payment request:

- 19.2.3.1.1 Installation of the Project sign;
- 19.2.3.1.2 Installation of field office;
- 19.2.3.1.3 Installation of temporary facilities and fencing;
- 19.2.3.1.4 Schedule of Values;
- 19.2.3.1.5 Contractor's Construction Schedule in conformance with § 10.1.1.1 above;
- 19.2.3.1.6 Schedule of unit prices, if applicable;
- 19.2.3.1.7 Submittal Schedule;
- 19.2.3.1.8 Receipt by Architect of all submittals due as of the date of the payment application;
- 19.2.3.1.9 Copies of necessary permits;
- 19.2.3.1.10 Copies of authorizations and licenses from governing authorities;
- 19.2.3.1.11 Initial progress report;
- 19.2.3.1.12 Surveyor qualifications;
- 19.2.3.1.13 Written acceptance of County's survey of rough grading, if applicable;
- 19.2.3.1.14 List of all Subcontractors, with names, license numbers, telephone numbers, and Scope of Work;
- 19.2.3.1.15 All bonds and insurance endorsements;
- 19.2.3.1.16 Resumes of Contractor's project manager, and if applicable, job site secretary, record documents recorder, and job site superintendent; and
- 19.2.3.1.17 Safety plan.
- 19.2.3.2 Second Payment Request. The County will not process the second payment request until and unless all submittals and Shop Drawings have been accepted for review by the Architect, and Contractor's Schedule has been accepted as in compliance with § 10.1.1.1 above.
- 19.2.3.3 No Waiver of Criteria. Any payments made to Contractor where criteria set forth herein have not been met shall not constitute a waiver of said criteria by County. Instead, such payment shall be construed as a good faith effort by County to resolve differences so Contractor may pay its Subcontractors and suppliers. Contractor agrees that failure to submit such items may constitute a breach of contract by Contractor and may subject Contractor to termination.

### **19.3 Progress Payments**

#### **19.3.1 County's Approval of Application for Payment**

- 19.3.1.1** Upon receipt of an Application for Payment, the County shall act in accordance with both of the following:
- 19.3.1.1.1** Each Application for Payment shall be reviewed by the County as soon as practicable after receipt for the purpose of determining that the Application for Payment is a proper Application for Payment.
- 19.3.1.1.2** Any Application for Payment determined not to be a proper Application for Payment suitable for payment shall be returned to the Contractor as soon as practicable, but not later than seven (7) calendar days, after receipt. An Application for Payment returned pursuant to this paragraph shall be accompanied by a document setting forth in writing, including by e-mail, the reasons why the Application for Payment is not proper. The number of days available to the County to make a payment without incurring interest pursuant to this section shall be reduced by the number of days by which the County exceeds this seven-day return requirement.
- 19.3.1.1.3** An Application for Payment shall be considered properly executed if funds are available for payment of the Application for Payment, and payment is not delayed due to an audit inquiry by the financial officer of the County.
- 19.3.1.2** The County's review of the Contractor's Application for Payment will be based on the County's and the Architect's observations at the Site and the data comprising the Application for Payment that the Work has progressed to the point indicated and that, to the best of the County's and the Architect's knowledge, information, and belief, the quality of the Work is in accordance with the Contract Documents. The foregoing representations are subject to:
- 19.3.1.2.1** Observation of the Work for general conformance with the Contract Documents,
- 19.3.1.2.2** Results of subsequent tests and inspections,
- 19.3.1.2.3** Minor deviations from the Contract Documents correctable prior to completion, and
- 19.3.1.2.4** Specific qualifications expressed by the Architect.
- 19.3.1.3** County's approval of the certified Application for Payment shall be based on Contractor complying with all requirements for a fully complete and valid certified Application for Payment.
- 19.3.2 Payments to Contractor**
- 19.3.2.1** Within thirty (30) days after approval of the Application for Payment, Contractor shall be paid a sum equal to ninety percent (90%) of the value of the Work performed (as verified by Architect and certified by Contractor) up to the last day of the previous month, less the aggregate of previous payments and amount to be withheld. The

value of the Work completed shall be Contractor's best estimate. No inaccuracy or error in said estimate shall operate to release the Contractor, or any Surety upon any bond, from damages arising from such Work, or from the County's right to enforce each and every provision of this Contract, and the County shall have the right subsequently to correct any error made in any estimate for payment.

**19.3.2.2** The Contractor shall not be entitled to have any payment requests processed, or be entitled to have any payment made for Work performed, so long as any lawful or proper direction given by the County concerning the Work or any portion thereof remains incomplete.

**19.3.2.3** If the County fails to make any progress payment within thirty (30) days after receipt of an undisputed and properly submitted Application for Payment by the Contractor, the County shall pay interest to the Contractor equivalent to the legal rate set forth in subdivision (a) of § 685.010 of the Code of Civil Procedure.

**19.3.3 No Waiver**

No payment by County hereunder shall be interpreted so as to imply that County has inspected, approved, or accepted any part of the Work. Notwithstanding any payment, the County may enforce each and every provision of this Contract. The County may correct or require correction of any error subsequent to any payment.

**19.3.4 Removal of Liens**

**19.3.4.1** If a lien or a claim based on a stop notice of any nature should at any time be filed against the Work or any County property, by any entity that has supplied material or services at the request of the Contractor, Contractor and Contractor's Surety shall promptly, on demand by County and at Contractor's and Surety's own expense, take any and all action necessary to cause any such lien or a claim based on a stop notice to be released or discharged immediately therefrom.

**19.3.4.2** If the Contractor fails to furnish to the County within ten (10) calendar days after demand by the County, satisfactory evidence that a lien or a claim based on a stop notice has been so released, discharged, or secured, the County may discharge such indebtedness and deduct the amount required therefor, together with any and all losses, costs, damages, and attorney's fees and expense incurred or suffered by County from any sum payable to Contractor under the Contract.

**19.4 Decisions to Withhold Payment**

**19.4.1 Reasons to Withhold Payment**

The County may withhold payment in whole, or in part, to the extent reasonably necessary to protect the County if, in the County's opinion, the representations to the County required herein cannot be made. The County may withhold payment, in

whole, or in part, to such extent as may be necessary to protect the County from loss because of, but not limited to:

- 19.4.1.1** Defective Work not remedied within the time frames noted in § 14 hereof of written notice to Contractor;
- 19.4.1.2** Stop Notices, or other liens served upon the County as a result of the Contract;
- 19.4.1.3** Liquidated damages assessed against the Contractor;
- 19.4.1.4** The cost of completion of the Contract, if there exists reasonable doubt that the Work can be completed for the unpaid balance of the Contract Price or by the completion date;
- 19.4.1.5** Damage to the County or other contractor(s);
- 19.4.1.6** Unsatisfactory prosecution of the Work by the Contractor;
- 19.4.1.7** Failure to store and properly secure materials;
- 19.4.1.8** Failure of the Contractor to submit, on a timely basis, proper, sufficient, and acceptable documentation required by the Contract Documents, including, without limitation, a Construction Schedule, Schedule of Submittals, Schedule of Values, Monthly Progress Schedules, Shop Drawings, Product Data and Samples, Proposed product lists, executed Change Orders, and/or properly completed Elation updates;
- 19.4.1.9** Failure of the Contractor to maintain Record Drawings;
- 19.4.1.10** Erroneous estimates by the Contractor of the value of the Work performed, or other false statements in an Application for Payment;
- 19.4.1.11** Unauthorized deviations from the Contract Documents;
- 19.4.1.12** Failure of the Contractor to prosecute the Work in a timely manner in compliance with the Construction Schedule established progress schedules, and/or completion dates;
- 19.4.1.13** Failure to properly pay prevailing wages as defined in Labor Code § 1720 et seq., and/or failure to comply with any other Labor Code requirements,
- 19.4.1.14** Failure to properly maintain or clean up the Site;
- 19.4.1.15** Payments to indemnify, defend, or hold harmless the County;
- 19.4.1.16** Any payments due to the County, including but not limited to payments for failed tests, utility changes or permits;
- 19.4.1.17** Failure to pay Subcontractor(s) or supplier(s) as required by law and by the Contract Documents;
- 19.4.1.18** Contractor is otherwise in breach, default, or in substantial violation of any provision of this Contract.

**19.4.2 Reallocation of Withheld Amounts**

**19.4.2.1** County may, at its discretion, apply any withheld amount to pay outstanding claims or obligations as defined herein. In so doing, County shall make such payments on behalf of Contractor. If any payment is so made by County, then that amount shall be considered a payment made under Contract by County to Contractor and County shall not be liable to Contractor for any payment made in good faith. These payments may be made without prior judicial determination of claim or obligation. County will render Contractor an accounting of funds disbursed on behalf of Contractor.

**19.4.2.2** If Contractor defaults or neglects to carry out the Work in accordance with the Contract Documents or fails to perform any provision thereof, County may, after FORTY-EIGHT (48) hours written notice to the Contractor and, without prejudice to any other remedy, make good such deficiencies. The County shall adjust the total Contract Price by reducing the amount thereof by the cost of making good such deficiencies. If County deems it inexpedient to correct Work that is damaged, defective, or not done in accordance with Contract provisions, an equitable reduction in the Contract Price (of at least one hundred twenty-five percent (125%) of the estimated reasonable value of the nonconforming Work) shall be made therefor.

**19.4.3 Payment After Cure**

When Contractor removes the grounds for declining approval, payment shall be made for amounts withheld because of them. No interest shall be paid on any retainage or amounts withheld due to the failure of the Contractor to perform in accordance with the terms and conditions of the Contract Documents.

**19.5 Subcontractor Payments**

**19.5.1 Payments to Subcontractors**

No later than seven (7) days after receipt, or pursuant to Business and Professions Code § 7108.5 and Public Contract Code § 7107, the Contractor shall pay to each Subcontractor, out of the amount paid to the Contractor on account of such Subcontractor's portion of the Work, the amount to which said Subcontractor is entitled. The Contractor shall, by appropriate agreement with each Subcontractor, require each Subcontractor to make payments to its Sub-subcontractors in a similar manner.

**19.5.2 No Obligation of County for Subcontractor Payment**

The County shall have no obligation to pay or to see to the payment of, money to a Subcontractor except as may otherwise be required by law.

**19.5.3 Joint Checks**

County shall have the right in its sole discretion if necessary for the protection of the County, to issue joint checks made payable to the Contractor and Subcontractors and material or equipment suppliers. The joint check payees shall be responsible for the allocation and disbursement of funds included as part of any such joint payment. In no



event shall any joint check payment be construed to create any contract between the County and a Subcontractor of any tier, any obligation from the County to such Subcontractor, or rights in such Subcontractor against the County.

## **20. COMPLETION OF THE WORK**

### **20.1 Completion**

**20.1.1** County will accept completion of the Contract and have the Notice of Completion recorded when the entire Work shall have been completed to the satisfaction of County.

**20.1.2** The Work may only be accepted as complete by action of the County Board of Supervisors.

**20.1.3** County, at its sole option, may accept completion of Contract and have the Notice of Completion recorded when the entire Work shall have been completed to the satisfaction of County, except for minor corrective items, as distinguished from incomplete items. If Contractor fails to complete all minor corrective items within thirty (30) days after the date of the County's acceptance of completion, County shall withhold from the final payment one hundred fifty percent (150%) of an estimate of the amount sufficient to complete the corrective items, as determined by County, until the item(s) are completed.

**20.1.4** At the end of the thirty-five (35) day period, if there are any items remaining to be corrected, County may elect to proceed as provided herein related to adjustments to Contract Price, and/or County's right to perform the Work of the Contractor.

### **20.2 Close-Out Procedures**

#### **20.2.1 Punch List**

The Contractor shall notify the Architect when Contractor considers the Work complete. Upon notification, Architect will prepare a list of minor items to be completed or corrected ("Punch List"). The Contractor and/or its Subcontractors shall proceed promptly to complete and correct items on the Punch List. Failure to include an item on Punch List does not alter the responsibility of the Contractor to complete all Work in accordance with the Contract Documents.

#### **20.2.2 Close-Out Requirements**

##### **20.2.2.1 Utility Connections**

Buildings shall be connected to water, gas, sewer, and electric services, complete and ready for use. Service connections shall be made, and existing services reconnected.

##### **20.2.2.2 Record Drawings**

**20.2.2.2.1** Contractor shall provide exact "as-built" Record Drawings of the Work upon completion of the Project as indicated in the Specifications.

- 20.2.2.2.2** Contractor is liable and responsible for any and all inaccuracies in as-built Record Drawings, even if inaccuracies become evident at a future date.
- 20.2.2.2.3** Upon completion of the Work and as a condition precedent to approval of final payment, Contractor shall obtain the Architect's approval of the corrected prints and employ a competent draftsman to transfer the "as-built" information to the most current version of Autocad that is, at that time, currently utilized for plan check submission by either the County, the Construction Manager and/or the Architect, and submit electronic files. When completed, Contractor shall deliver corrected electronic files acceptable to County with Autocad file to the County.
- 20.2.2.2.4** Maintenance Manuals: Contractor shall prepare all operation and maintenance manuals and date as indicated in the Specifications.

### **20.3 Final Inspection**

**20.3.1** Contractor shall comply with Punch List procedures as provided herein, and maintain the presence of a Project Superintendent and Project Manager until the Punch List is complete to ensure proper and timely completion of the Punch List. Under no circumstances shall Contractor demobilize its forces prior to completion of the Punch List. Upon receipt of Contractor's written notice that all of the Punch List items have been fully completed, and the Work is ready for final inspection and acceptance, Architect and Construction Manager will inspect the Work and shall submit to Contractor and County a final inspection report noting the Work, if any, required in order to complete in accordance with the Contract Documents. Absent unusual circumstances, this report shall consist of the Punch List items not yet satisfactorily completed.

**20.3.2** Upon Contractor's completion of all items on the Punch List and any other uncompleted portions of the Work, the Contractor shall notify the County and Architect, who shall again inspect such Work. If the Architect finds the Work complete and acceptable under the Contract Documents, the Architect will notify Contractor, who shall then jointly submit to the Architect and the County its final Application for Payment.

#### **20.3.3 Final Inspection Requirements**

Before calling for final inspection, Contractor shall determine that the following have been performed:

- 20.3.3.1** The Work has been completed.
- 20.3.3.2** All life-safety items are completed and in working order.
- 20.3.3.3** Mechanical and Electrical Work are complete and tested, fixtures are in place, connected, and ready for tryout.
- 20.3.3.4** Electrical circuits scheduled in panels and disconnect switches labeled.

- 20.3.3.5 Painting and special finishes complete.
- 20.3.3.6 Doors complete with hardware, cleaned of protective film, relieved of sticking or binding, and in working order.
- 20.3.3.7 Tops and bottoms of doors sealed.
- 20.3.3.8 Floors waxed and polished as specified.
- 20.3.3.9 Broken glass replaced and glass cleaned.
- 20.3.3.10 Grounds cleared of Contractor's equipment, raked clean of debris, and trash removed from Site.
- 20.3.3.11 Work cleaned, free of stains, scratches, and other foreign matter, of damaged and broken material, replaced.
- 20.3.3.12 Finished and decorative work shall have marks, dirt, and superfluous labels removed.
- 20.3.3.13 Final cleanup, as provided herein.

#### **20.4 Costs of Multiple Inspections**

More than two (2) requests of the County to make a final inspection shall be considered an additional service of County, Architect, and/or Construction Manager, and all subsequent costs will be invoiced to Contractor and if funds are available, withheld from remaining payments.

#### **20.5 Partial Occupancy or Use Prior to Completion**

##### **20.5.1 County's Rights**

The County may occupy or use any completed or partially completed portion of the Work at any stage. The County and the Contractor shall agree in writing to the responsibilities assigned to each of them for payments, security, maintenance, heat, utilities, damage to the Work, insurance, the period for correction of the Work, and the commencement of warranties required by the Contract Documents. Any dispute as to responsibilities shall be resolved pursuant to the Claims and Disputes provisions herein, with the added provision that during the dispute process, the County shall have the right to occupy or use any portion of the Work that it needs or desires to use.

##### **20.5.2 Inspection Prior to Occupancy or Use**

Immediately prior to partial occupancy or use, the County, the Contractor, and the Architect shall jointly inspect the area to be occupied or portion of the Work to be used in order to determine and record the condition of the Work.

##### **20.5.3 No Waiver**

Unless otherwise agreed upon, partial or entire occupancy or use of a portion or portions of the Work shall not constitute beneficial occupancy or acceptance of the Work not complying with the requirements of the Contract Documents.

#### **21. FINAL PAYMENT AND RETENTION**

## **21.1 Final Payment**

Upon receipt and approval of a valid and final Application for Payment, the Architect will issue a final Certificate of Payment. The County shall thereupon jointly inspect the Work and either accept the Work as complete or notify the Architect and the Contractor in writing of reasons why the Work is not complete. Upon acceptance of the Work of the Contractor as fully complete (that, absent unusual circumstances, will occur when the Punch List items have been satisfactorily completed), the County shall record a Notice of Completion with the County Recorder, and the Contractor shall, upon receipt of final payment from the County, pay the amount, due Subcontractors.

## **21.2 Prerequisites for Final Payment**

The following conditions must be fulfilled prior to Final Payment:

**21.2.1** A full and final waiver or release of all Stop Notices in connection with the Work shall be submitted by Contractor, including a release of Stop Notice in recordable form, together with (to the extent permitted by law) a copy of the full and final release of all Stop Notice rights.

**21.2.1.1** A duly completed and executed conditional waiver and release upon final payment compliant with Civil Code § 8136 from the Contractor and each subcontractor of any tier and supplier to be paid from the current progress payment;

**21.2.1.2** A duly completed and executed unconditional waiver and release upon final payment compliant with Civil Code § 8138 from the Contractor and each subcontractor of any tier and supplier that was paid from the previous progress payment; and

**21.2.1.3** The Contractor shall have made all corrections to the Work that are required to remedy any defects therein, to obtain compliance with the Contract Documents or any requirements of applicable codes and ordinances, or to fulfill any of the orders or directions of County required under the Contract Documents.

**21.2.2** Each Subcontractor shall have delivered to the Contractor all written guarantees, warranties, applications, and bonds required by the Contract Documents for its portion of the Work.

**21.2.3** Contractor must have completed all requirements set forth under "Close-Out Procedures," Including, without limitation, an approved set of complete "as-built" Record Drawings.

**21.2.4** Architect shall have issued its written approval that final payment can be made.

**21.2.5** The Contractor shall have delivered to the County all manuals and materials required by the Contract Documents.

**21.2.6** The Contractor shall have completed final clean up as provided herein.

## **21.3 Retention**

**21.3.1** The retention, less any amounts disputed by the County or that the County has the right to withhold pursuant to provisions herein, shall be paid:

**21.3.1.1** After approval of the County by the Architect's Certificate of Payment,

**21.3.1.2** After the satisfaction of the conditions set forth herein, and

**21.3.1.3** After thirty-five (35) days after the recording of the Notice of Completion by County.

**21.3.2** No interest shall be paid on any retention, or on any amounts withheld due to a failure of the Contractor to perform, in accordance with the terms and conditions of the Contract Documents, except as provided to the contrary in any Escrow Agreement between the County and the Contractor pursuant to Public Contract Code § 22300.

**21.4 Substitution of Securities**

The County will permit the substitution of securities in accordance with the provisions of Public Contract Code § 22300.

**22. UNCOVERING OF WORK**

If a portion of the Work is covered without Architect approval or not in compliance with the Contract Documents, it must, if required in writing, including by email, by the County or the Architect, be uncovered for the Architect's observation and be replaced at the Contractor's expense without change in the Contract Price or Contract Time.

If a portion of the Work has been covered, which the Project Inspector or the Architect has not specifically requested to observe prior to its being covered, the County, Project Inspector, or the Architect may request to see that Work, and it shall be uncovered by the Contractor. If that Work is in accordance with the Contract Documents, costs of uncover and replacement shall, by appropriate Change Order, be charged to the County. If that Work is not in accordance with Contract Documents, the Contractor shall pay these costs unless the condition was caused by the County or a separate contractor, in which event the County shall be responsible for payment of such costs to the Contractor.

**23. NONCONFORMING WORK, CORRECTION OF WORK AND COUNTY'S RIGHT TO PERFORM WORK**

**23.1 Nonconforming Work**

**23.1.1** Contractor shall promptly remove from Premises all Work identified by County as failing to conform to the Contract Documents whether incorporated or not. Contractor shall promptly replace and re-execute its own Work to comply with the Contract Documents without additional expense to the County and shall bear the expense of making good all work of other contractors destroyed or damaged by any removal or replacement pursuant hereto and/or any delays to the County or other Contractors caused thereby.

**23.1.2** If Contractor does not remove Work that County has identified as failing to conform to the Contract Documents within a reasonable time, not to exceed

FORTY-EIGHT (48) hours, County may remove it and may store any material at Contractor's expense. If Contractor does not pay expense(s) of that removal within ten (10) days' time thereafter, County may, upon ten (10) days' written notice, sell any material at auction or at private sale and shall deduct all costs and expenses incurred by the County and/or County may withhold those amounts from payment(s) to Contractor.

## **23.2 Correction of Work**

### **23.2.1 Correction of Rejected Work**

Pursuant to the notice provisions herein, the Contractor shall promptly correct the Work rejected by the County or the Architect as failing to conform to the requirements of the Contract Documents, whether observed before or after Completion and whether or not fabricated, installed, or completed. The Contractor shall bear costs of correcting the rejected Work, including additional testing, inspections, and compensation for the Architect's services and expenses made necessary thereby.

### **23.2.2 Warranty Corrections**

If, within the warranty period specified in 00 65 36 Warranty Form, after the date of Completion of the Work or a designated portion thereof, or after the date of commencement of warranties established hereunder, or by the terms of an applicable special warranty required by the Contract Documents, any of the Work is found to be not in accordance with the requirements of the Contract Documents, the Contractor shall correct it promptly after receipt of written notice from the County to do so. This period of two (2) years shall be extended with respect to portions of the Work first performed after Completion by the period of time between Completion and the actual performance of the Work. This obligation hereunder shall survive acceptance of the Work under the Contract and termination of the Contract. The County shall give such notice promptly after discovery of the condition.

## **23.3 County's Right to Perform Work**

**23.3.1** If the Contractor should neglect to prosecute the Work properly or fail to perform any provisions of this contract, the County, after FORTY-EIGHT (48) hours written notice to the Contractor, may, without prejudice to any other remedy it may have, make good such deficiencies and may deduct the cost thereof from the payment then or thereafter due the Contractor.

**23.3.2** If it is found at any time, before or after completion of the Work, that Contractor has varied from the Drawings and/or Specifications, including, but not limited to, variation in material, quality, form, or finish, or in the amount or value of the materials and labor used, County may require at its option:

**23.3.2.1** That all such improper Work be removed, remade or replaced, and all work disturbed by these changes be made good by Contractor at no additional cost to the County;

**23.3.2.2** That the County deduct from any amount due Contractor the sum of money equivalent to the difference in value between the work performed and that called for by the Drawings and Specifications; or

- 23.3.2.3** That the County exercise any other remedy it may have at law or under the Contract Documents, including but not limited to the County hiring its own forces or another contractor to replace the Contractor's nonconforming Work, in which case the County shall either issue a Deductive Change Order, a Construction Change Directive or invoice the Contractor for the cost of that work. Contractor shall pay any invoices within thirty (30) days of receipt of same or County may withhold those amounts from payment(s) to Contractor.

## **24. TERMINATION AND SUSPENSION**

### **24.1 County's Right to Terminate Contractor for Cause**

#### **24.1.1 Grounds for Termination.**

The County, in its sole discretion, may terminate the Contract and/or terminate the Contractor's right to perform the work of the Contract based upon the following:

- 24.1.1.1** Contractor refuses or fails to execute the Work or any separable part thereof with sufficient diligence as will ensure its completion within the time specified or any extension thereof, or
- 24.1.1.2** Contractor fails to complete said Work within the time specified or any extension thereof, or
- 24.1.1.3** Contractor persistently fails or refused to perform Work or provide material of sufficient quality as to be in compliance with Contract Documents; or
- 24.1.1.4** Contractor files a petition for relief as a debtor, or a petition is filed against the Contractor without its consent, and the petition not dismissed within sixty (60) days; or
- 24.1.1.5** Contractor makes a general assignment for the benefit of its creditors, or a receiver is appointed on account of its insolvency; or
- 24.1.1.6** Contractor persistently or repeatedly refuses or fails, except in cases for which extension of time is provided, to supply enough properly skilled workers or proper materials to complete the Work in the time specified; or
- 24.1.1.7** Contractor fails to make prompt payment to Subcontractors, or for material, or for labor; or
- 24.1.1.8** Contractor persistently disregards laws or ordinances, or instructions of County; or

**24.1.1.9** Contractor fails to supply labor, including that of Subcontractors, that can work in harmony with all other elements of labor employed or to be employed on the Work; or

**24.1.1.10** Contractor or its Subcontractor(s) is/are otherwise in breach, default, or in substantial violation of any provision of this Contract.

**24.1.2 Notification of Termination**

**24.1.2.1** Upon the occurrence of County's sole determination of any of the above conditions, County may, without prejudice to any other right or remedy, serve written notice upon Contractor and its Surety of County's termination of this Contract and/or the Contractor's right to perform the work of the Contract. This notice will contain the reasons for termination. Unless, within three (3) days after the service of the notice, any and all condition(s) shall cease, and any and all violation(s) shall cease, or arrangement satisfactory to County for the correction of the condition(s) and/or violation(s) be made, this Contract shall cease and terminate. Upon Determination, Contractor shall not be entitled to receive any further payment until the entire Work is finished.

**24.1.2.2** Upon Termination, County may immediately serve written notice of tender upon Surety whereby Surety shall have the right to take over and perform this Contract only if Surety:

**24.1.2.2.1** Within three (3) days after service upon it of the notice of tender, gives County written notice of Surety's intention to take over and perform this Contract; and

**24.1.2.2.2** Commences performance of this Contract within (three (3) days from the date of serving of its notice to County.

**24.1.2.3** If Surety fails to notify County or begin performance as indicated herein, County may take over the Work and execute the Work to completion by any method it may deem advisable at the expense of Contractor and/or its Surety. Contractor and/or its Surety shall be liable to County for any excess cost or other damages the County incurs thereby. Time is of the essence in this Contract. If the County takes over the Work as herein provided, County may, without liability for so doing, take possession of and utilize in completing the Work such materials, appliances, plan, and other property belonging to Contractor as may be on the Site of the Work, in bonded storage, or previously paid for.

**24.1.3 Effect of Termination**

**24.1.3.1** Contractor shall, only if ordered to do so by the County, immediately remove from the Site all or any materials and personal property belonging to Contractor that have not been incorporated in the



construction of the Work, or which are not in place in the Work. The County retains the right, but not the obligation, to keep and use any materials and personal property belonging to Contractor that have not been incorporated in the construction of the Work, or which are not in place in the Work. The Contractor and its Surety shall be liable upon the performance bond for all damages caused the County by reason of the Contractor's failure to complete the Contract.

- 24.1.3.2** In the event that the County shall perform any portion of, or the whole of the Work, pursuant to the provisions of the General Conditions, the County shall not be liable nor account to the Contractor in any way for the time within which, or the manner in which, the Work is performed by the County or for any changes the County may make in the Work or for the money expended by the County in satisfying claims and/or suits and/or other obligations in connection with the Work.
- 24.1.3.3** In the event, that the Contract is terminated for any reason, no allowances or compensation will be granted for the loss of any anticipated profit by the Contractor.
- 24.1.3.4** If the expense to the County to finish the Work exceeds the unpaid Contract Price, Contractor and Surety shall pay the difference to County within twenty-one (21) days of County's request.
- 24.1.3.5** The County shall have the right (but shall have no obligation) to assume and/or assign to a general contractor or construction manager or other third party who is qualified and has sufficient resources to complete the Work, the rights of the Contractor under its subcontracts with any or all Subcontractors. In the event of an assumption or assignment by the County, no Subcontractor shall have any claim against the County or third party for Work performed by Subcontractor or other matters arising prior to termination of the Contract. The County or any third party, as the case may be, shall be liable only for obligations to the Subcontractor arising after assumption or assignment. Should the County so elect, the Contractor shall execute and deliver all documents and take all steps, including the legal assignment of its contractual rights, as the County may require, for the purpose of fully vesting in the County the rights and benefits of it Subcontractor under Subcontracts or other obligations or commitments. All payments due the Contractor hereunder shall be subject to a right of offset by the County for expenses and damages suffered by the County as a result of any default, acts, or omissions of the Contractor. Contractor must include this assignment provision in all of its contracts with its Subcontractors.
- 24.1.3.6** The foregoing provisions are in addition to and not in limitation of any other rights or remedies available to County.

## **24.2 Termination of Contractor for Convenience**

**24.2.1** County in its sole discretion may terminate the Contract upon three (3) days written notice to the Contractor. Under a termination for convenience, the County retains the right to all the options available to the County if there is a termination for cause. In case of a termination for convenience, the Contractor shall have no claims against the County except:

**24.2.1.1** The actual cost of labor, materials, and services performed that is unpaid and can be documented through timesheets, invoices, receipts, or otherwise, and

**24.2.1.2** Five percent (5%) of the total cost of work performed as of the date of termination, or five percent (5%) of the value of the Work yet to be performed, whichever is less. This five percent (5%) amount shall be full compensation for all Contractor's and its Subcontractor(s)' mobilization and/or demobilization costs and any anticipated loss profits resulting from termination of the Contractor for convenience.

**24.3 Emergency Termination of Public Contracts Act of 1949**

**24.3.1** This Contract is subject to termination as provided by §§4410 and 4411 of the Government Code of the State of California, being a portion of the Emergency Termination of Public Contracts Act of 1949.

**24.3.1.1** § 4410 of the Government Code states:

In the event a national emergency occurs, and public work, being performed by contract, is stopped, directly or indirectly, because of the freezing or diversion of materials, equipment or labor, as the result of an order or a proclamation of the President of the United States, or of an order of any federal authority, and the circumstances or conditions are such that it is impracticable within a reasonable time to proceed with a substantial portion of the work, then the public agency and the contractor may, by written agreement, terminate said contract.

**24.3.1.2** § 4411 of the Government Code states:

Such an agreement shall include the terms and conditions of the termination of the contract and provision for the payment of compensation or money, if any, which either party shall pay to the other or any other person, under the facts and circumstances in the case.

**24.3.1.3** Compensation to the Contractor shall be determined at the sole discretion of County on the basis of the reasonable value of the Work done, including preparatory work. As an exception to the foregoing and at the County's discretion, in the case of any fully completed separate item or portion of the Work for which there is a separate previously submitted unit price or item on the accepted schedule of values, that price shall control. The County, at its sole discretion, may adopt the Contract Price as the reasonable value of the work done or any portion thereof.

**25. CLAIMS AND DISPUTES**

**25.1 Performance During Claim Process**

The Contractor shall continue to perform its Work under the Contract and shall not cause a delay in the Work during any dispute, claims definition, negotiation, mediation, or arbitration proceeding, except by written agreement by the County.

**25.2 Definition of Claim**

**25.2.1** For purposes of this section, a “Claim” means a separate demand by the Contractor for:

**25.2.1.1** A time extension,

**25.2.1.2** Payment of money or damages arising from Work done by or on behalf of the Contractor pursuant to the Contract and payment of which is not otherwise expressly provided for or the claimant is not otherwise entitled to, or

**25.2.1.3** Payment of money that the County disputes is owing.

**25.3 Claim Presentations**

**25.3.1** The attention of the Contractor is drawn to Government Code § 12650, et seq. regarding penalties for false claims.

**25.3.2** Contractor shall file with the County any written Claim, including the documents necessary to substantiate it, on or before the day of final payment on the Contract.

**25.3.3** The Contractor shall not cause a delay in the Work during any dispute, claims definition, negotiation, mediation, or arbitration proceeding, except by written agreement by the County.

**25.3.4** The Contractor shall bind all its Subcontractors, material persons, and suppliers to the provisions of this section on mediation and arbitration and will hold the County harmless against disputes and claims by Subcontractors, material persons, or suppliers.

**25.4 Claim Resolution**

**25.4.1** In the event of a dispute between the parties as to performance of the Work, the interpretation of this Contract, or payment or nonpayment for Work performed or not performed, the parties shall attempt to resolve the dispute by those procedures set forth in Public Contract Code § 9204, if applicable. Pending resolution of the dispute, if the dispute is not resolved, Contractor agrees it will neither rescind the Contract nor stop the progress of the Work but will allow determination by a court of the State of California having competent jurisdiction of the dispute, after the Project has been completed, and not before.

**25.4.2** For all Claims which arise between a Contractor and a local agency, the procedure set forth in Public Contract Code § 9204 shall apply:

**25.4.2.1** The County shall respond in writing within forty-five (45) days of receipt of the Claim identifying what portion of the Claim is disputed and what portion is undisputed.

- 25.4.2.1.1** Upon receipt of a Claim, County, and Contractor may, by mutual agreement, extend the time period for County to respond.
- 25.4.2.1.2** Any payment due on an undisputed portion of the Claim shall be processed and made within sixty (60) days after the County issues its written response to the Claim.
- 25.4.3** If Contractor disputes County's written response, or if County fails to respond to a Claim issued pursuant to this § 25 within the time prescribed, Contractor may demand in writing an informal conference to meet and confer for settlement of the issues in dispute.
  - 25.4.3.1** Upon receipt of a demand in writing sent by registered mail or certified mail, return receipt requested, County shall schedule a meet and confer conference within thirty (30) days for settlement of the dispute.
- 25.4.4** Within ten (10) business days following the conclusion of the meet and confer conference, if the Claim or any portion of the Claim remains in dispute, the County shall provide Contractor a written statement identifying the portion of the Claim that remains in dispute and the portion that is undisputed.
  - 25.4.4.1** Any payment due on an undisputed portion of the Claim shall be processed and made within sixty (60) days after the County issues its written statement.
- 25.4.5** Any disputed portion of the Claim, as identified by the statement referenced in § 25.2 shall be submitted to nonbinding mediation, with the County and Contractor sharing the associated costs equally.
  - 25.4.5.1** County and Contractor shall mutually agree to a mediator within ten (10) business days after the disputed portion of the claim has been identified in writing.
  - 25.4.5.2** If County and Contractor cannot agree to a mediator, each party shall select a mediator, and those mediators shall select a qualified neutral third party to mediate with regard to the disputed portion of the claim.
  - 25.4.5.3** County and Contractor shall each bear the fees and costs charged by its respective mediator in connection with the selection of the neutral mediator.
  - 25.4.5.4** If mediation is unsuccessful and the Claim is less than or equal to \$375,000, the parts of the claim remaining in dispute shall be submitted to judicial arbitration pursuant to Chapter 2.5 (commencing with § 1141.10) of the Title 3 of Part 3 of the Code of Civil Procedure, notwithstanding § 1141.11 of that code. The Civil

Discovery Act of 1986, (Article 3 (commencing with § 2016) of Chapter 3 of Title 3 of part 4 of the Code of Civil Procedure) shall apply to any proceeding brought under this subdivision consistent with the rules pertaining to judicial arbitration.

**25.4.5.4** The arbitrator presiding over the judicial arbitration under subpart 25.4.5.4 must be experienced in construction law, and must be paid necessary and reasonable hourly rates not exceeding his or her customary rate, paid equally by County and Contractor, unless the arbitrator, for good cause, determines a different division.

**25.4.6** The County shall not fail to pay money as to any portion of a claim which is undisputed except as otherwise provided in the Contract Documents. Unpaid claim amounts not paid in a timely manner will accrue interest at seven percent (7%) per annum. In any suit filed pursuant to this section, the County shall pay interest at the legal rate on any arbitration award or judgment. Interest shall begin to accrue on the date the suit is filed in a court of law.

**25.4.7** If a Subcontractor or lower-tier subcontractor lacks legal standing to assert a Claim against County because privity of contract does not exist, Contractor may present County a Claim on behalf of a Subcontractor or lower-tier Subcontractor. A Subcontractor may request, in writing, either on his or her own behalf or that of a lower-tier Subcontractor, that Contractor present a Claim for work which was performed by Subcontractor, or by a lower-tier Subcontractor on behalf of Subcontractor. Subcontractor requesting that the claim be presented to County must furnish reasonable documentation to support the Claim. Within forty-five (45) days of receipt of this written request, Contractor must notify Subcontractor in writing as to whether Contractor presented the Claim to County, and, if Contractor did not present the Claim, provide Subcontractor with a written statement of the reasons for not having done so.

## **26. LABOR, WAGE & HOUR, APPRENTICE, AND RELATED PROVISIONS**

**26.1 Wage Rates, Travel, and Subsistence – (For Projects over \$1M see also PROJECT STABILIZATION/ COMMUNITY BENEFITS AGREEMENT of the COUNTY OF ALAMEDA Document 00 73 49).**

**26.1.1** Pursuant to the provisions of Article 2 (commencing with § 1770), chapter 1, part 7, division 2, of the Labor Code of California, the general prevailing rate of per diem wages and the general prevailing rate for holiday and overtime work in the locality in which this public work is to be performed for each craft, classification or type of worker needed to execute this Contract is on file at the County's principal office, and copies will be made available to any interested party on request. Contractor shall obtain and post a copy of these wage rates at the job site.

**26.1.2** Holiday and overtime work, when permitted by law, shall be paid for at a rate of at least one and one-half times the above-specified rate of per diem wages unless otherwise specified. The holidays upon which those rates shall be paid need not be specified by the County but shall be all holidays recognized in the applicable collective bargaining agreement. If the prevailing rate is not based on a collectively bargained rate, the holidays upon which the prevailing rate shall be paid shall be as provided in § 6700 of the Government Code.

**26.1.3** Contractor shall pay and shall cause to be paid each worker engaged in Work on the Project not less than the general prevailing rate of per diem wages determined by the Director of the Department of Industrial Relations (“DIR”) (“Director”), regardless of any contractual relationship which may be alleged to exist between Contractor or any Subcontractor and such workers.

**26.1.4** Contractor shall pay and shall cause to be paid to each worker needed to execute the Work on the Project travel and subsistence payments, as such travel and subsistence payments are defined in the applicable Collective Bargaining Agreements filed with the Department of Industrial Relations in accordance with Labor Code § 1773 et seq.

**26.1.5** If during the period this bid is required to remain open, the Director determines that there has been a change in any prevailing rate of per diem wages in the locality in which the Work under the Contract is to be performed, such change shall not alter the wage rates in the Notice to Bidders or the Contract subsequently awarded.

**26.1.6** Pursuant to Labor Code § 1775, Contractor shall, as a penalty to County, forfeit the statutory amount for each calendar day, or portion thereof, for each worker paid less than the prevailing rates, determined by the County and/or the Director, for the work or craft in which that worker is employed for any public work done under Contract by Contractor or by any Subcontractor under it. The difference between such prevailing wage rates and the amount paid to each worker for each calendar day or portion thereof for which each worker was paid less than the prevailing wage rate, shall be paid to each worker by Contractor.

**26.1.7** Any worker employed to perform Work on the Project, which Work is not covered by any classification listed in the general prevailing wage rate of per diem wages determined by the Director, shall be paid not less than the minimum rate of wages specified therein for the classification which most nearly corresponds to Work to be performed by him, and such minimum wage rate shall be retroactive to time of initial employment of such person in such classification.

**26.1.8** Pursuant to Labor Code § 1773.1, per diem wages, are deemed to include employer payments for health and welfare, pension, vacation, travel time, subsistence pay, and apprenticeship or other training programs authorized by § 3093, and similar purposes.

**26.1.9** Contractor shall post at appropriate conspicuous points on the Site of Project, a schedule showing all determined minimum wage rates and all authorized deductions if any, from unpaid wages, actually earned. In addition, Contractor shall post a sign-in log for all workers and visitors to the Site, a list of all subcontractors of any tier on the Site, and the required Equal Employment Opportunity poster(s).

**26.1.10** Contractor stipulates that it shall comply with all requirements of PROJECT STABILIZATION/COMMUNITY BENEFITS AGREEMENT (**For projects over \$1M**) of the COUNTY OF ALAMEDA, and shall pay to persons performing labor in and about the Work provided for in the Contract an amount equal to or more than the following:

**26.1.10.1** Wage rate and fringe benefit payments and classification for that person's corresponding labor classification as required by the Department of Industrial Relations;

**26.1.10.2** Wage rate and fringe benefit payments and classification for that person's corresponding labor classification as required under the PROJECT STABILIZATION/COMMUNITY BENEFITS AGREEMENT of the COUNTY OF ALAMEDA (**For projects over \$1M**) and California Labor Code.

**26.1.11** If there are conflicts between the Wage rate and fringe benefit payments and classification between the Department of Industrial Relations and the PROJECT STABILIZATION/COMMUNITY BENEFITS AGREEMENT of the COUNTY OF ALAMEDA (**For projects over \$1M**), Contractor shall pay the higher wage rate and fringe benefits.

## **26.2 Hours of Work**

**26.2.1** As provided in Article 3 (commencing with § 1810), chapter 1, part 7, division 2, of the Labor Code, eight (8) hours of labor shall constitute a legal days work. The time of service of any worker employed at any time by Contractor or by any Subcontractor on any subcontract under this Contract upon the Work or upon any part of the Work contemplated by this Contract shall be limited and restricted by Contractor to eight (8) hours per day, and forty (40) hours during any one week, except as hereinafter provided. Notwithstanding the provisions hereinabove set forth, Work performed by employees of Contractor in excess of eight (8) hours per day and forty (40) hours during any one week, shall be permitted upon this public work upon compensation for all hours worked in excess of eight (8) hours per day at not less than one and one-half times the basic rate of pay.

**26.2.2** Contractor shall keep and shall cause each Subcontractor to keep an accurate record showing the name of and actual hours worked each calendar day and each calendar week by each worker employed by Contractor in connection with the Work or any part of the Work contemplated by this Contract. The record shall be kept open at all reasonable hours to the inspection of County and to the Division of Labor Standards Enforcement of the DIR.

**26.2.3** Pursuant to Labor Code § 1813, Contractor shall as a penalty to the County forfeit the statutory amount for each worker employed in the execution of this Contract by Contractor or by any Subcontractor for each calendar day during which such worker is required or permitted to work more than eight (8) hours in any one calendar day and forty (40) hours in any one calendar week in violation of the provisions of Article 3 (commencing with § 1810), chapter 1, part 7, division 2, of the Labor Code.

**26.2.4** Any Work necessary to be performed after regular working hours, or on Sundays or other holidays shall be performed without additional expense to the County.

**26.3 Payroll Records**

**26.3.1** County will use the Alameda County Contract Compliance System, including the Elation Systems, Inc. program, to monitor contract and labor compliance. Contractor shall use the Compliance System to meet County's requirements, and shall participate in training as directed by County in order to become and remain competent in the use of the Compliance System.

**26.3.2** Pursuant to the provisions of § 1776 of the Labor Code, notice is hereby given that Contractor shall prepare and provide to the County and shall cause each Subcontractor performing any portion of the Work under this Contract to prepare and provide to the County an accurate and certified payroll record ("CPR(s)"), showing the name, address, social security number, work classification, straight time, and overtime hours worked each day and week, and the actual per diem wages paid to each journeyman, apprentice, worker, or other employee employed by the Contractor and/or each Subcontractor in connection with the Work.

**26.3.3** The CPRs enumerated hereunder shall be certified and shall be provided to the County on a weekly basis. The CPRs from the Contractor and each Subcontractor for each week shall be provided on or before Wednesday of the week following the week covered by the CPRs. County shall not make any payment to Contractor until:

**26.3.3.1** Contractor and/or its Subcontractor(s) provide CPRs acceptable to the County, and

**26.3.3.2** The County is given sufficient time to review and/or audit the CPRs to determine their acceptability. Any delay in Contractor and/or its Subcontractor(s) providing CPRs to the County in a timely manner will directly delay the County's review and/or audit of the CPRs and Contractor's payment.

**26.3.4** All CPRs shall be available for inspection at all reasonable hours at the principal office of Contractor on the following basis:

**26.3.4.1** A certified copy of an employee's CPR shall be made available for inspection or furnished to the employee or his/her authorized representative on request.

**26.3.4.2** CPRs shall be made available for inspection or furnished upon request to a representative of County, Division of Labor Standards Enforcement, Division of Apprenticeship Standards, and/or the Department of Industrial Relations.

**26.3.4.3** CPRs shall be made available upon request by the public for inspection or copies thereof made; provided, however, that a request by the public shall be made through either the County, Division of Apprenticeship Standards or the Division of Labor Standards



Enforcement. If the requested CPRs have not been provided pursuant to the provisions herein, the requesting party shall, prior to being provided the records reimburse the costs of preparation by Contractor, Subcontractors, and the entity through which the request was made. The public shall not be given access to the records at the principal office of Contractor.

**26.3.5** The form of certification for the CPRs shall be as follows:

I, (Name-Print), the undersigned, am the (Position in business) with the authority to act for and on behalf of (Name of business and/or Contractor), certify under penalty of perjury that the records or copies thereof submitted and consisting of (Description, number of pages) are the originals or true, full, and correct copies of the originals which depict the payroll record(s) of actual disbursements by way of cash, check, or whatever form to the individual or individual named, and (b) we have complied with the requirements of §§1771, 1811, and 1815 for any work performed by our employees on the Project.

Date:

Signature:

(§ 16401 of the California Code of Regulations)

**26.3.6** Each Contractor shall file a certified copy of the CPRs with the entity that requested the records within ten (10) days after receipt of a written request.

**26.3.7** Any copy of records made available for inspection as copies and furnished upon request to the public or any public agency by County, Division of Apprenticeship Standards, or Division of Labor Standards Enforcement shall be marked or obliterated in such a manner as to prevent disclosure of an individual's name, address, and social security number. The name and address of Contractor awarded Contract or performing Contract shall not be marked or obliterated.

**26.3.8** Contractor shall inform County of the location of the records enumerated hereunder, including the street address, city, and county, and shall, within five (5) working days, provide a notice of change of location and address.

**26.3.9** In the event of noncompliance with the requirements of this section, Contractor shall have ten (10) days in which to comply subsequent to receipt of written notice specifying in what respects Contractor must comply with this section. Should noncompliance still be evident after the ten (10) day period, Contractor shall, as a penalty to County, forfeit twenty-five dollars (\$25) for each calendar day, or portion thereof, for each worker, until strict compliance is effectuated. Upon the request of Division of Apprenticeship Standards or Division of Labor Standards Enforcement, these penalties shall be withheld from progress payments then due.

**26.3.10** It shall be the responsibility of Contractor to ensure compliance with the provisions of Labor Code § 1776.

## **26.4 Apprentices**

**26.4.1** Contractor acknowledges and agrees that, if this Contract involves a dollar amount greater than or a number of working days greater than that specified in Labor

Code § 1777.5, then this Contract is governed by the provisions of Labor Code § 1777.5. It shall be the responsibility of Contractor to ensure compliance with this Article and with Labor Code § 1777.5 for all apprenticeship occupations.

**26.4.2** Apprentices of any crafts or trades may be employed and, when required by Labor Code § 1777.5, shall be employed provided they are properly registered in full compliance with the provisions of the Labor Code.

**26.4.3** Every such apprentice shall be paid the standard wage paid to apprentices under the regulations of the craft or trade at which he/she is employed, and shall be employed only in the work of the craft or trade to which she/he is registered.

**26.4.4** Only apprentices, as defined in § 3077 of the Labor Code, who are in training under apprenticeship standards and written apprentice agreements under Chapter 4 (commencing at § 3070), Division 3, of the Labor Code, are eligible to be employed. The employment and training of each apprentice shall be in accordance with the provisions of the apprenticeship standards and apprentice agreements under which he/she is training.

**26.4.5** Pursuant to Labor Code § 1777.5, if that § applies to this Contract as indicated above, Contractor and any Subcontractors employing workers in any apprentice able craft or trade in performing any Work under this Contract shall apply to the applicable joint apprenticeship committee for a certificate approving the Contractor or Subcontractor under the applicable apprenticeship standards and fixing the ratio of apprentices to journeymen employed in performing the Work.

**26.4.6** Pursuant to Labor Code § 1777.5, if that § applies to this Contract as indicated above, Contractor and any Subcontractor may be required to make contributions to the apprenticeship program.

**26.4.7** If Contractor or Subcontractor willfully fails to comply with Labor Code § 1777.5, then, upon a determination of noncompliance by the Administrator of Apprenticeship, it shall:

**26.4.7.1** Be denied the right to bid on any subsequent project for one (1) year from the date of such determination;

**26.4.7.2** Forfeit as a penalty to County the full amount as stated in Labor Code § 1777.7. Interpretation and enforcement of these provisions shall be in accordance with the rules and procedures of the California Apprenticeship Council and under the authority of the Chief of the Division of Apprenticeship Standards.

**26.4.8** Contractor and all Subcontractors shall comply with Labor Code § 3073.9, which § forbids certain discriminatory practices in the employment of apprentices.

**26.4.9** Contractor shall become fully acquainted with the law regarding apprentices prior to commencement of the Work. Special attention is directed to Article 2 (commencing with §3075) of Division 4, Chapter 4 of the Labor Code, and §§1777.5, 1777.6, and 1777.7 of the Labor Code, and title 8, California Code of Regulations, §200 et seq. Questions may be directed to the State Division of Apprenticeship Standards, 455 Golden Gate Avenue, San Francisco, California 94102.

**26.5 Non-Discrimination**

**26.5.1** Contractor herein agrees not to discriminate in its recruiting, hiring, promotion, demotion, or termination practices on the basis of race, religious creed, national origin, ancestry, sex, age, or physical handicap in the performance of this Contract and to comply with the provisions of the California Fair Employment and Housing Act as set forth in part 2.8 of Division 3 of the California Government Code, commencing at §12900; the Federal Civil Rights Act of 1964, as set forth in Public Law 88-352, and all amendments thereto; Executive Order 11246, and all administrative rules and regulations found to be applicable to Contractor and Subcontractor.

**26.5.2** Special requirements for Federally Assisted Construction Contracts: During the performance of this Contract, Contractor agrees to incorporate in all subcontracts the provisions set forth in Chapter 60-1.4(b) of Title 41 published in Volume 33 No. 104 of the Federal Register dated May 28, 1968.

**26.6 Labor First Aid**

Contractor shall maintain emergency first aid treatment for Contractor's workers on the Project which complies with the Federal Occupational Safety and Health Act of 1970 (29 U.S.C. § 651 et seq.) and the California Occupational Safety and Health Act of 1973 (8 Cal. Code of Regs., §1 et seq. 33400 of Article 10, Group 2, Subchapter 7).

**27. MISCELLANEOUS**

**27.1 Assignment of Antitrust Actions**

**27.1.1** §7103.5(b) of the Public Contract Code states:

In entering into a public works contract or subcontract to supply goods, services, or materials pursuant to a public works contract, the Contractor or subcontractor offers and agrees to assign to the awarding body all rights, title, and interest in and to all causes of action it may have under § 4 of the Clayton Act (15 U.S.C. Sec. 15) or under the Cartwright Act (Chapter 2 (commencing with § 16700) of Part 2 of Division 7 of the Business and Professions Code), arising from purchases of goods, made and become effective at the time the awarding body tenders final payment to the Contractor, without further acknowledgment by the parties.

**27.1.2** § 4552 of the Government Code states:

In submitting a bid to a public purchasing body, the bidder offers and agrees that if the bid is accepted, it will assign to the purchasing body all rights, title, and interest in and to all causes of action it may have under § 4 of the Clayton Act (15 U.S.C. Sec. 15) or under the Cartwright Act (Chapter 2 (commencing with § 16700) of Part 2 of Division 7 of the Business and Professions Code), arising from purchases of goods, materials, or services by the bidder for sale to the purchasing body pursuant to the bid. Such assignment shall be made and become effective at the time the purchasing body tenders final payment to the bidder.

**27.1.3** § 4553 of the Government Code states:

If an awarding body or public purchasing body receives, either through judgment or settlement, a monetary recovery for a cause of action assigned under this

chapter, the assignor shall be entitled to receive reimbursement for actual legal costs incurred and may, upon demand, recover from the public body any portion of the recovery, including treble damages, attributable to overcharges that were paid by the assignor but were not paid by the public body as part of the bid price, less the expenses incurred in obtaining that portion of the recovery.

**27.1.4** § 4554 of the Government Code states:

Upon demand in writing by the assignor, the assignee shall, within one year from such demand, reassign the cause of action assigned under this part if the assignor has been or may have been injured by the violation of law for which the cause of action arose and (a) the assignee has not been injured thereby, or (b) the assignee declines to file a court action for the cause of action.

**27.1.5** Under this Article, “public purchasing body” is County and “bidder is Contractor.

**27.2 Excise Taxes**

If, under Federal Excise Tax Law, any transaction hereunder constitutes a sale on which a Federal Excise Tax is imposed, and the sale is exempt from such Federal Excise Tax because it is a sale to a State or Local Government for its exclusive use, County, upon request, will execute documents necessary to show (1) that County is a political subdivision of the State for the purposes of such exemption, and (2) that the sale is for the exclusive use of County. No Federal Excise Tax for such materials shall be included in any Contract Price.

**27.3 Taxes**

Contract Price is to include any and all applicable sales taxes or other taxes that may be due in accordance with § 7051 of the Revenue and Taxation Code; Regulation 1521 of the State Board of Equalization or any other tax code that may be applicable.

**27.4 Shipments**

All shipments must be F.O.B. destination to Site or sites, as indicated in the Contract Documents. There must be no charge for containers, packing, unpacking, drayage or insurance. The total Contract Price shall be all inclusive (including sales tax), and no additional costs of any type will be considered.

**END OF DOCUMENT**

DOCUMENT 00 73 13

**SPECIAL CONDITIONS**

**1. Mitigation Measures**

Contractor shall comply with all applicable mitigation measures, if any, adopted by any public agency with respect to this Project pursuant to the California Environmental Quality Act. (Public Resources Code section 21000 et. seq.)

**2. Substitution for Specified Items**

- 2.2. Requests for substitutions prior to award of the Contract shall be done within the time period indicated in the Instructions to Bidders.

**AND/OR**

Requests for substitutions after award of the Contract shall be within **THIRTY-FIVE (35)** days of the date of the Notice of Award.

- 2.3. Whenever in the Specifications any materials, process, or article is indicated or specified by grade, patent, or proprietary name, or by name of manufacturer, that Specification shall be deemed to be followed by the words "or equal." Contractor may, unless otherwise stated, offer any material, process, or article that shall be substantially equal or better in every respect to that so indicated or specified.

2.3.1. If the material, process, or article offered by Contractor is not, in the opinion of the County, substantially equal or better in every respect to that specified, then Contractor shall furnish the material, process, or article specified in the Specifications without any additional compensation or change order.

2.3.2. This provision shall not be applicable with respect to any material, product, thing or service for which County made findings and gave notice in accordance with Public Contract Code section 3400(b); therefore, Contractor shall not be entitled to request a substitution with respect to those materials, products or services.

- 2.4. A request for a substitution shall be in writing and shall include:

2.4.1. All variations of the proposed substitute from the material specified including, but not limited to, principles of operation, materials, or construction finish, thickness or gauge of materials, dimensions, weight, and tolerances;

- 2.4.2. Available maintenance, repair or replacement services;
  - 2.4.3. Increases or decreases in operating, maintenance, repair, replacement, and spare parts costs;
  - 2.4.4. Whether or not acceptance of the substitute will require other changes in the Work (or in work performed by the County or others under Contract with the County); and
  - 2.4.5. The time impact on any part of the Work resulting directly or indirectly from acceptance of the proposed substitute.
- 2.5.** No substitutions shall be made until approved, in writing, by the County. The burden of proof as to equality of any material, process, or article shall rest with Contractor. The Contractor warrants that if substitutes are approved:
- 2.5.1. The proposed substitute is equal or superior in all respects to that specified, and that such proposed substitute is suitable and fit for the intended purpose and will perform adequately the function and achieve the results called for by the general design and the Contract Documents;
  - 2.5.2. The Contractor provides the same warranties and guarantees for the substitute that would be provided for that specified;
  - 2.5.3. The Contractor shall be fully responsible for the installation of the substitute and any changes in the Work required, either directly or indirectly, because of the acceptance of such substitute, with no increase in Contract Price or Contract Time. Incidental changes or extra component parts required to accommodate the substitute will be made by the Contractor without a change in the Contract Price or Contract Time;
  - 2.5.4. The Contractor shall be responsible for any re-design costs occasioned by County's acceptance and/or approval of any substitute; and
  - 2.5.5. The Contractor shall, in the event that a substitute is less costly than that specified, credit the County with one hundred percent (100%) of the net difference between the substitute and the originally specified material. In this event, the Contractor agrees to execute a deductive Change Order to reflect that credit.
- 2.6.** In the event Contractor furnishes a material, process, or article more expensive than that specified, the difference in the cost of that material, process, or article so furnished shall be borne by Contractor.

- 2.7. In no event shall the County be liable for any increase in Contract Price or Contract Time due to any claimed delay in the evaluation of any proposed substitute or in the acceptance or rejection of any proposed substitute.

3. **Weather Days**

- 3.1 Delays due to adverse weather conditions will only be permitted in compliance with the provisions in the General Conditions and only if the number of days of adverse weather exceeds the following parameters and only if Contractor can verify that adverse weather caused delays exceeded the following number of days:

January	<u>[11]</u>	July	<u>[0]</u>
February	<u>[10]</u>	August	<u>[0]</u>
March	<u>[10]</u>	September	<u>[1]</u>
April	<u>[6]</u>	October	<u>[4]</u>
May	<u>[3]</u>	November	<u>[7]</u>
June	<u>[1]</u>	December	<u>[10]</u>

4. **Insurance Policy Limits.** All of Contractor's insurance shall be with insurance companies with an A.M. Best rating of no less than A: XI.

The limits of insurance shall not be less than:

<b>Commercial General Liability</b>	Each Occurrence	[\$2,000,000]
	General Aggregate	[\$2,000,000]
	Product Liability and Completed Operations	[\$1,000,000]
<b>Automobile Liability – Any Auto</b>	Combined Single Limit	[\$2,000,000]
<b>Excess Liability</b>		[\$4,000,000]
<b>Workers Compensation</b>		Statutory limits pursuant to state law
<b>Employers' Liability</b>		[\$1,000,000]
<b>Builders Risk (Course of Construction)</b>		Issued for the value of the Contract

**5. Permits, Certificates, Licenses, Fees, Approval**

- 5.1 Payment for Permits, Certificates, Licenses, and Fees.** As required in the General Conditions, the Contractor shall secure and pay for all permits, licenses and certificates necessary for the prosecution of the Work with the exception of the following:

2.7.1. E.g. (water connection fees)

2.7.2. E.g. (sewer connection fees)

With respect to the above listed items, Contractor shall be responsible for securing such items, however, County will be responsible for payment of these charges or fees. Contractor shall notify the County of the amount due with respect to such items and to whom the amount is payable. Contractor shall provide the County with an invoice and receipt with respect to such charges or fees.

**6. Administration of Task Orders**

- 6.1** The County may award an individual Task Order, up to a maximum value not-to-exceed- \$125,000, to any selected Contractor. Selection of the Contractor and award of the Task order will be in based on one or more of the following criteria:
- 6.1.1 Rotational selection among all Contractors.
  - 6.1.2 Evaluation of past and current performance on task orders of a similar nature and type of work, project size, construction management challenges, and/or schedule performance.
  - 6.1.3 Balancing of workload (task order dollar volume and construction) among Contractors.
  - 6.1.4 Contractors responsiveness to task orders.
  - 6.1.5 Other appropriate criteria as deemed in best interest of the County.
- 6.2** The scope of required work will be set forth in each Task Order issued. The County is not obligated to issue any Task Order(s). All costs incurred in the preparation of the Task Order proposals are the sole responsibility of the Contractor.
- 6.3** The Contractor must provide all pricing, management, stamped or unstamped design drawings, shop drawings, documents, labor, materials, parts (to include



system components), transportation, plant, supervision, and equipment needed to perform each Task Order.

- 6.4** As Directed by the County, the Contractor will provide incidental architectural or engineering design services in accordance with applicable State laws and the County's insurance and indemnification requirements. All documents are subject to review and approval of the County. The County may require that design documents be prepared and provided in Computer Aided Design (CAD) format.
- 6.5** Contractor will perform Work only as authorized by the Task Order issued by the County. The Contractor must perform all Task Orders assigned to it during the Contract Term.
- 6.6** Issuance of Task Orders
  - 6.6.1** Task Orders for projects estimated to be under \$50,000 or urgent work, will be issued on a rotational basis.
  - 6.6.2** The County will ask the awarded pool of Contractors to provide proposals for projects estimated to be over \$50,000 or non-urgent work and will issue a task order to the lowest responsive bidder.
  - 6.6.3** The County may direct the Contractor to undertake and possibly complete urgent work prior to the issuance of a Task Order. The Contractor will be compensated in accordance with the provisions of this Contract.
  - 6.6.4** The County does not guarantee the issuance of any volume of Task Orders as part of this Contract. The County may award other construction contracts for the same or similar Work during the term of any or all of these Contracts.
  - 6.6.5** Task Orders issued under this contract shall not exceed \$125,000.
  - 6.6.6** Unforeseen work that exceeds the Task Order amount and scope will require an approved Change Order before the performance of any additional work.

7. **Work Restrictions**

Hours of Work

1. **Normal Business Hours:** Monday through Friday, 7:00 AM to 5:00 PM.
  - a. Non-urgent calls for service shall be completed within five (5) working days after the issuance of the fully executed Task Order.
  - b. Authorized County staff will notify the contractor by telephone or email of the work to be done. The Contractor's shall be available for non-emergency services during the hours of 7:00 A.M. and 5:00 P.M., Monday through Friday, except holidays.
  - c. Without the prior approval of the County authorized staff, the Contractor shall only perform the work authorized in a Task Order. If non-contemplated work is required to accomplish the intent of the Task Order, an additional authorization must be obtained from the Authorized County staff before said work is begun. Any additional work or change in the work to be performed must be approved, in advance, by the County authorized staff.
2. **After-Hours/Urgent:** Monday through Friday, 5:00 PM to 7:00 AM. Weekends and holidays, all day (24/7).
  - a. The Contractor shall be at the site to begin work in response to urgent service calls within two (2) hours after receipt of the call, and work will be completed within twenty-four (24) hours of the call or as specified and authorized by the County authorized staff.
  - b. Contractor shall provide a cell phone number which will be answered 24/7 in case of emergency.

Access to Site

1. **Site Clearance:** Contractor's personnel who perform any work in County detention facilities must successfully pass and maintain to the satisfaction of the Alameda County Sheriff's Office (ACSO) a security and background check performed by ACSO ("Clearance"). This is an individual clearance. Once obtained, this clearance must be renewed on an annual basis.
  - a. Failure to pass, divulge information, or comply with the background process will prohibit an individual from entry into ACSO facilities on behalf of or to perform work for Contractor. If a Clearance is refused for

any individual, Contractor shall be notified, and Contractor shall provide a replacement suitable to ACSO.

- b. Contractor shall submit the County Security Site Clearance forms for each of its employee prior to working on any Alameda County detention facility.

**END OF DOCUMENT**

DOCUMENT 00 73 56

**HAZARDOUS MATERIALS**  
**PROCEDURES & REQUIREMENTS**

**1. Summary**

This document includes information applicable to hazardous materials and hazard waste abatement.

**2. Notice of Hazardous Waste or Materials Conditions**

- 2.1. Contractor shall give notice in writing, including by e-mail, to the County, the Construction Manager, and the Architect promptly, before any of the following conditions are disturbed, and in no event later than twenty-four (24) hours after first observance, of any:
  - 2.1.1. Material that Contractor believes may be material that is hazardous waste or hazardous material, as defined in section 25117 or 25260 of the Health and Safety Code, that is required to be removed to a Class I, Class II, or Class III disposal site in accordance with provisions of existing law;
  - 2.1.2. Other material that may present a substantial danger to persons or property exposed thereto in connection with Work at the site.
- 2.2. Contractor's written notice shall indicate whether the hazardous waste or material was shown or indicated in the Contract Documents to be within the scope of Work, and whether the materials were brought to the site by Contractor, its Subcontractors, suppliers, or anyone else for whom Contractor is responsible. As used in this section the term "hazardous materials" shall include, without limitation, asbestos, lead, mercury, Polychlorinated biphenyl (PCB), petroleum and related hydrocarbons, and radioactive material.
- 2.3. In response to Contractor's written notice, the County shall investigate the identified conditions.
- 2.4. If the County determines that conditions do not involve hazardous materials or that no change in terms of Contract is justified, the County shall so notify Contractor in writing, stating reasons. If the County and Contractor cannot agree on whether conditions justify an adjustment in Contract Price or Contract Times, or on the extent of any adjustment, Contractor shall proceed with the Work as directed by the County.
- 2.5. If after receipt of notice from the County, Contractor does not agree to resume Work based on a reasonable belief it is unsafe, or does not agree to resume Work under special

conditions, then County may order such portion of Work that is in connection with such hazardous condition or such affected area to be deleted from the Work, or performed by others, or County may invoke its rights to terminate the Contract in whole or in part. County will determine entitlement to or the amount or extent of an adjustment, if any, in Contract Price or Contract Times as a result of deleting such portion of Work, or performing the Work by others.

- 2.6. If Contractor stops Work in connection with any hazardous condition and in any area affected thereby, Contractor shall immediately redeploy its workers, equipment, and materials, as necessary, to other portions of the Work to minimize delay and disruption.

### **3. Additional Warranties and Representations**

- 3.1. Contractor represents and warrants that it, its employees, and its subcontractors and their employees, shall at all times have the required levels of familiarity with the Site and the Work, training, and ability to comply fully with all applicable law and contract requirements for safe and expeditious performance of the Work, including whatever training is or may be required regarding the activities to be performed (including, but not limited to, all training required to address adequately the actual or potential dangers of Contract performance).
- 3.2. Contractor represents and warrants that it, its employees, and its subcontractors and their employees, shall at all times have and maintain in good standing any and all certifications and licenses required by applicable federal, state, and other governmental and quasi-governmental requirements applicable to the Work.
- 3.3. Contractor represents and warrants that it has studied carefully all requirements of the Specifications regarding procedures for demolition, hazardous waste abatement, or safety practices, specified in the Contract, and prior to submitting its bid, has either (a) verified to its satisfaction that the specified procedures are adequate and sufficient to achieve the results intended by the Contract Documents, or (b) by way of approved "or equal" request or request for clarification and written Addenda, secured changes to the specified procedures sufficient to achieve the results intended by the Contract Documents. Contractor accepts the risk that any specified procedure will result in a completed Project in full compliance with the Contract Documents.

### **4. Monitoring and Testing**

- 4.1. County reserves the right, in its sole discretion, to conduct air monitoring, earth monitoring, Work monitoring, and any other tests (in addition to testing required under the agreement or applicable law), to monitor Contract requirements of safe and statutorily compliant work methods and (where applicable) safe re-entry level air standards under state and federal law upon completion of the job, and compliance of the

work with periodic and final inspection by public and quasi-public entities having jurisdiction.

- 4.2. Contractor acknowledges that County has the right to perform, or cause to be performed, various activities and tests including, but not limited to, pre-abatement, during abatement, and post-abatement air monitoring, that County shall have no obligation to perform said activities and tests, and that a portion of said activities and tests may take place prior to the completion of the Work by Contractor. In the event County elects to perform these activities and tests, Contractor shall afford County ample access to the Site and all areas of the Work as may be necessary for the performance of these activities and tests. Contractor will include the potential impact of these activities or tests by County in the Contract Price and the Scheduled Completion Date.
- 4.3. Notwithstanding County's rights granted by this paragraph, Contractor may retain its own industrial hygiene consultant at Contractor's own expense and may collect samples and may perform tests including, but not limited to, pre-abatement, during abatement, and post-abatement personal air monitoring, and County reserves the right to request documentation of all such activities and tests performed by Contractor relating to the Work and Contractor shall immediately provide that documentation upon request.

## **5. Compliance with Laws**

- 5.1. Contractor shall perform safe, expeditious, and orderly work in accordance with the best practices and the highest standards in the hazardous waste abatement, removal, and disposal industry, the applicable law, and the Contract Documents, including, but not limited to, all responsibilities relating to the preparation and return of waste shipment records, all requirements of the law, delivering of all requisite notices, and obtaining all necessary governmental and quasi-governmental approvals.
- 5.2. Contractor represents that it is familiar with and shall comply with all laws applicable to the Work or completed Work including, but not limited to, all federal, state, and local laws, statutes, standards, rules, regulations, and ordinances applicable to the Work relating to:
  - 5.2.1. The protection of the public health, welfare and environment;
  - 5.2.2. Storage, handling, or use of asbestos, PCB, lead, petroleum based products or other hazardous materials;
  - 5.2.3. The generation, processing, treatment, storage, transport, disposal, destruction, or other management of asbestos, PCB, lead, petroleum, or hazardous waste materials or other waste materials of any kind; and

- 5.2.4. The protection of environmentally sensitive areas such as wetlands and coastal areas.

## **6. Disposal**

- 6.1. Contractor has the sole responsibility for determining current waste storage, handling, transportation, and disposal regulations for the job Site and for each waste disposal facility. Contractor must comply fully at its sole cost and expense with these regulations and any applicable law. County may, but is not obligated to, require submittals with this information for it to review consistent with the Contract Documents.
- 6.2. Contractor shall develop and implement a system acceptable to County to track hazardous waste from the Site to disposal, including appropriate "Hazardous Waste Manifests" on the EPA form, so that County may track the volume of waste it put in each landfill and receive from each landfill a certificate of receipt.
- 6.3. Contractor shall provide County with the name and address of each waste disposal facility prior to any disposal, and County shall have the express right to reject any proposed disposal facility. Contractor shall not use any disposal facility to which County has objected. Contractor shall document actual disposal or destruction of waste at a designated facility by completing a disposal certificate or certificate of destruction forwarding the original to the County.

## **7. Permits**

- 7.1. Before performing any of the Work, and at such other times as may be required by applicable law, Contractor shall deliver all requisite notices and obtain the approval of all governmental and quasi-governmental authorities having jurisdiction over the Work. Contractor shall submit evidence satisfactory to County that it and any disposal facility
- 7.1.1. have obtained all required permits, approvals, and the like in a timely manner both prior to commencement of the Work and thereafter as and when required by applicable law, and
- 7.1.2. are in compliance with all such permits, approvals and the regulations.

For example, before commencing any work in connection with the Work involving asbestos-containing materials, or PCBs, or other hazardous materials subject to regulation, Contractor agrees to provide the required notice of intent to renovate or demolish to the appropriate state or federal agency having jurisdiction, by certified mail, return receipt requested, or by some other method of transmittal for which a return receipt is obtained, and to send a copy of that notice to County. Contractor shall not conduct any Work involving asbestos-containing materials or PCBs unless Contractor has first confirmed that the

appropriate agency having jurisdiction is in receipt of the required notification. All permits, licenses, and bonds that are required by governmental or quasi-governmental authorities, and all fees, deposits, tap fees, offsite easements, and asbestos and PCB disposal facilities expenses necessary for the prosecution of the Work, shall be procured and paid for by Contractor. Contractor shall give all notices and comply with the all applicable laws bearing on the conduct of the Work as drawn and specified. If Contractor observes or reasonably should have observed that Plans and Specifications and other Contract Documents are at variance therewith, it shall be responsible for promptly notifying County in writing, including by e-mail, of such fact. If Contractor performs any Work contrary to applicable laws, it shall bear all costs arising therefrom.

- 7.2. In the case of any permits or notices held in County's name or of necessity to be made in County's name, County shall cooperate with Contractor in securing the permit or giving the notice, but the Contractor shall prepare for County review and execution upon approval, all necessary applications, notices, and other materials.

## **8. Indemnification**

- 8.1. To the extent permitted by law, the indemnities and limitations of liability expressed throughout the Contract Documents apply with equal force and effect to any claims or liabilities imposed or existing by virtue of the removal, abatement, and disposal of hazardous waste. This includes, but is not limited to, liabilities connected to the selection and use of a waste disposal facility, personal injury, property damage, loss of use of property, damage to the environment or natural resources, or "disposal" and "release" of materials associated with the Work (as defined in 42 U.S.C. § 9601 et seq.).

## **9. Termination**

- 9.1. County shall have an absolute right to terminate for default immediately without notice and without an opportunity to cure should Contractor knowingly or recklessly commit a material breach of the terms of the Contract Documents, or any applicable law, on any matter involving the exposure of persons or property to hazardous waste. However, if the breach of contract exposing persons or property to hazardous waste is due solely to an ordinary, unintentional, and non-reckless failure to exercise reasonable care, then the procedures for termination for cause shall apply without modification.

END OF DOCUMENT



DOCUMENT 01 10 00

**SUMMARY OF WORK**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions
- B. Special Conditions.
- C. Construction Waste Management Document 01 74 19
- D. LEED™ Requirements 01 35 13.23
- E. General Commissioning Requirements 01 91 13

**1.02 SUMMARY OF WORK COVERED BY CONTRACT DOCUMENTS**

- A. The Work of this Contract will be defined by the Scope of Work as set forth in each individual Task Order.
- B. The Scope of Work for each Task Order of this Contract may consist of the following:
  - (1) Contractor shall furnish all labor, materials, parts, equipment, and incidentals necessary to provide miscellaneous on-call, as-needed, urgent, and/or routine Heating, Ventilation, and Air Conditioning (HVAC) installation and repairs. The services shall be performed at various County of Alameda facilities. The contractor must be able to work at all facilities located within the County borders.
  - (2) On an on-call basis, the authorized County staff will notify the Contractor(s), through the issuance of Task Order(s), of the location, nature, and extent of the work to be done. All work requested shall be limited to the type of work specified in this document, and/or any individual Task Order, **Description of Work** below.
  - (3) Each Task Order will specify the location, nature, start and end dates and extent of the work to be done. This notification shall be the complete instruction and authorization for the proposed work and the Contractor shall fully comply with all particulars thereof. The County will pay only for work requested by the authorized County staff. In no case shall the Contractor accept service requests directly from tenants, lessees, or other Contractors.

- (4) Service calls: The Authorized County staff will notify the contractor by telephone or email of the work to be done.
- (5) Without the prior approval of the County authorized staff, the Contractor shall only perform the work authorized in a Task Order. If non-contemplated work is required to accomplish the intent of the Task Order, an additional authorization must be obtained from the Authorized County staff **before** said work is begun. Any additional work or change in the work to be performed must be approved, in advance, by the County authorized staff.
- (6) Non-urgent Services: Each Task Order within this contract shall be completed within five (5) working days after receipt of the Task Order, unless otherwise stated.
- (7) Urgent Services: The Contractor shall be at the site to begin work in response to urgent service calls within two (2) hours after receipt of the call, and work will be completed within twenty-four (24) hours of the call or as specified and authorized by the County authorized staff. Contractor shall provide a cell phone number which will be answered 24/7 in case of urgent work.
- (8) Authorized County staff must approve all finish materials in advance of purchase. All materials used are typically medium grade quality products, unless otherwise specified by the County authorized staff.

**C. Description of Work:**

- (1) The Contractor shall furnish all labor, materials, parts, equipment, licenses, and any other items or expenses necessary to perform routine or urgent maintenance and repair of Heating, Ventilation, and Air Conditioning (HVAC). Services shall include, but are not limited to, general repair, maintenance, replacement, upgrading, installation, diagnosing, testing, and troubleshooting of all aspects of the County's HVAC systems, equipment, devices, components, and parts.
- (2) The Contractor shall have and maintain a thorough knowledge of general commercial HVAC systems, equipment, devices, and components.
- (3) The Contractor shall perform installation, maintenance, repair, and replacement services per the Original Equipment Manufacturers (OEM) and or the County's specifications.
- (4) The Contractor shall be certified and capable of working on all major brands of commercial HVAC equipment and related components. The

Contractor shall also be capable of providing factory recommended or OEM parts for all major brands.

- (5) Contractor shall charge the actual cost of parts, materials, supplies, equipment, software, and hardware licenses approved by the County without additional allowance for mark-up.
- (6) Preventative Maintenance: Maintenance activities shall strictly adhere to the Manufacturer's recommendations. The type of maintenance includes inspecting functional operations of equipment to assure long term operating condition. Preventive maintenance services may consist of the following:
  - (a) Calibrating Direct Digital Control systems
  - (b) Visually and audibly inspect all equipment for proper operation
  - (c) Test for the correct refrigerant charge, superheat, oil and gas pressures
  - (d) Test safety, temperature, and pressure controls for appropriate operation
  - (e) Inspect fan impellers, blades, and inspect finned surfaces
  - (f) Run equipment through the proper sequence of operation
  - (g) Safety inspections for corrosion and damage
  - (h) Inspect for oil and refrigerant leaks
  - (i) Check for appropriate running voltages and amps
  - (j) Inspect contactors and tighten all connections
  - (k) Clean all drain pans and coils
  - (l) Lubricate motors, bearings, and damper linkages
  - (m) Condenser coil cleaning with a brush and CO2
  - (n) Furnish filter replacements using pleated disposable filters
  - (o) Inspect all belts, align belt drives, drive couplings, air fins and replace as required

- (p) Calibrating safety controls and temperature and pressure controls  
Inspecting and tightening electrical connections
  - (q) Lubricating motors, fan, and damper bearings, valve stems, and  
damper linkages
- (7) Corrective Maintenance: Corrective maintenance entails repairs to equipment/systems that have deteriorated, broken, or worn out and cannot be used for their intended purpose. Corrective maintenance services may consist of the following:
  - (a) Maintenance on components of air-conditioning and heating systems and any related items or small equipment (pumps, valves, thermostats, etc.) used to maintain HVAC functionality to achieve a proper climate-controlled environment.
  - (b) Replacing factory-installed controls, motors, compressors, bearings and shafts, repairing leaks, and painting equipment. Contractor shall repair and or replace broken, worn, and or defective components and or parts.
- (8) Inspections: The Contractor shall provide inspection services on HVAC systems, per manufacturer specifications. These services may consist of the following:
  - (a) Operation of factory-installed HVAC controls
  - (b) Inspecting of worn, failed, or doubtful parts, mountings, drive couplings, oil level, rotation, soot, flame composition and shape, pilot and igniter, steam, oil, and refrigerant levels.
- (9) Reports: The Contractor shall provide a service report for each assigned task order, and each report shall provide the following information at a minimum:
  - (a) Preventative maintenance performed citing specific equipment.
  - (b) The detail on all repairs or replacement completed.
  - (c) The detail on all repair or replacement in progress.
  - (d) Parts were replaced, including the Manufacturer's name, model number, and serial number for each piece of equipment serviced.

- (10) The types of equipment covered under this Description of Work may include the following:
- (a) Rooftop HVAC package units
  - (b) Split HVAC systems
  - (c) Mini-split HVAC units
  - (d) Computer room HVAC units
  - (e) VRF (Variable Refrigerant Flow) systems
  - (f) Heat pumps
  - (g) Furnaces
  - (h) Pressurization fans
  - (i) Negative air fans
  - (j) Variable Frequency Drives
  - (k) Air Compressors
  - (l) Boilers
  - (m) Chillers
  - (n) Cooling Towers
  - (o) Pumps/Pump Stations
  - (p) Ductwork
  - (q) Insulation
  - (r) Variable air volume, check valve, and other terminal boxes
  - (s) Electronic and Pneumatic actuators
  - (t) Dampers
  - (u) Exhaust fans

(v) HVAC motors up to 480 volts

(w) HVAC controls including:

(i) Pneumatics

(ii) Electronic Direct Digital Controls (DDC)

(iii) Networked Building Automation Systems (BAS) including the following:

i. Delta Controls

ii. CSI I/NET

iii. Automation Direct

iv. Unity

(iv) Safety controls (i.e., smoke detectors, static-pressure sensors, flow-switches, electronic actuators).

(v) Ability to troubleshoot control outputs, either binary or analog, CO2 sensors, or Differential Pressure (DP) switches.

(x) Condenser water return, cold water riser,

(11) The Contractor shall provide as-needed/requested HVAC commissioning, Testing, Adjusting, and Balancing (TAB) services. TAB firm(s) and technician(s) must possess a TABB, NEBB, and or an AABC certification

### **1.03 CONTRACTS**

- A. Perform the Work of each Task Order based on the hourly rates provided in the Bid Sheet. Materials will be charged at actual cost.
- B. Any bid item may be deleted in total or in part prior to or after award of Contract without compensation in any form or adjustment of other bid items or prices.

### **1.05 CODES, REGULATIONS, AND STANDARDS**

- A. The codes, regulations, and standards adopted by the state and federal agencies having jurisdiction shall govern minimum requirements for this project. Where

codes, regulations, and standards conflict with the Contract Documents, these conflicts shall be brought to the immediate attention of the County and the Architect.

- B. Codes, regulations, and standards shall be as published effective as of date of bid opening, unless otherwise specified or indicated.

**1.06 PROJECT RECORD DOCUMENTS:**

- A. Contractor shall maintain on Site one set of the following record documents; Contractor shall record actual revisions to the Work:
  - (1) Contract Drawings.
  - (2) Specifications.
  - (3) Addenda.
  - (4) Change Orders and other modifications to the Contract.
  - (5) Reviewed shop drawings, product data, and samples.
  - (6) Field test records.
  - (7) Inspection certificates.
  - (8) Manufacturer's certificates.
- B. Contractor shall store Record Documents separate from documents used for construction. Provide files, racks, and secure storage for Record Documents and samples.
- C. Contractor shall record information concurrent with construction progress.
- D. Specifications: Contractor shall legibly mark and record at each product section of the Specifications the description of the actual product(s) installed, including the following:
  - (1) Manufacturer's name and product model and number.
  - (2) Product substitutions or alternates utilized.
  - (3) Changes made by Addenda and Change Orders and written directives.

**1.07 EXAMINATION OF EXISTING CONDITIONS**

- A. The Contractor shall be held to have examined the Project Site and acquainted itself with the conditions of the Site or of the streets or roads approaching the Site.
- B. Prior to commencement of Work, Contractor shall survey the Site and existing buildings and improvements to observe existing damage and defects such as cracks, sags, broken, missing or damaged glazing, other building elements and Site improvements, and other damage.
- C. Should Contractor observe cracks, sags, and other damage to and defects of the Site and adjacent buildings, paving, and other items not indicated in the Contract Documents, Contractor shall immediately report same to the County and the Architect.

#### **1.08 CONTRACTOR'S USE OF PREMISES**

- A. If unoccupied and only with County's prior written approval, Contractor may use the building(s) at the Project Site without limitation for its operations, storage, and office facilities for the performance of the Work. If the County chooses to beneficially occupy any building(s), Contractor must obtain the County's written approval for Contractor's use of spaces and types of operations to be performed within the building(s) while so occupied. Contractor's access to the building(s) shall be limited to the areas indicated.
- B. If the space at the Project Site is not sufficient for Contractor's operations, storage, office facilities and/or parking, Contractor shall arrange and pay for any additional facilities needed by Contractor.
- C. Contractor shall not interfere with use of or access to occupied portions of the building(s) or adjacent property.
- D. Contractor shall maintain corridors, stairs, halls, and other exit-ways of building clear and free of debris and obstructions at all times.
- E. No one other than those directly involved in the demolition and construction, or specifically designated by the County or the Architect shall be permitted in the areas of work during demolition and construction activities.
- F. The Contractor shall install the construction security fence and maintain that it will be locked when not in use. Keys to this fencing will be provided to the County.

#### **1.09 PROTECTION OF EXISTING STRUCTURES AND UTILITIES**



- A. The Drawings show above-grade and below-grade structures, utility lines, and other installations that are known or believed to exist in the area of the Work. Contractor shall locate these existing installations before proceeding with excavation and other operations that could damage same; maintain them in service, where appropriate; and repair damage to them caused by the performance of the Work. Should damage occur to these existing installations, the costs of repair shall be at the Contractor's expense and made to the County's satisfaction.
- B. Contractor shall be alert to the possibility of the existence of additional structures and utilities. If Contractor encounters additional structures and utilities, Contractor will immediately report to the County for disposition of same as indicated in the General Conditions.
- C. Contract shall employ utility locating services to locate any underground utilities within the limits of work prior to the start of any excavating work. Contractor shall subsequently be responsible for repairs of any located underground utilities damaged by construction activities.

#### **1.10 UTILITY SHUTDOWNS AND INTERRUPTIONS**

- A. Contractor shall give the County a minimum of three (3) days written notice in advance of any need to shut off existing utility services or to effect equipment interruptions. The County will set exact time and duration for shutdown, and will assist Contractor with shutdown. Work required to re-establish utility services shall be performed by the Contractor.
- B. Contractor shall obtain County's written approval as indicated in the General Conditions in advance of deliveries of material or equipment or other activities that may conflict with County's use of the building(s) or adjacent facilities.

#### **1.11 STRUCTURAL INTEGRITY**

- A. Contractor shall be responsible for and supervise each operation and work that could affect structural integrity of various building elements, both permanent and temporary.
- B. Contractor shall include structural connections and fastenings as indicated or required for complete performance of the Work.

#### **1.12 WORK SEQUENCE**

- A. Contractor shall be responsible for compliance with all requirements outlined in the hazardous materials sections of the Contract Documents.

- B. Construct Work in stages and at times to accommodate County operation requirements during the construction period; coordinate construction schedule and operations with the County.
- C. Phasing Schedule included in item 1.13 must be adhered to. Moving dates are included in the Phasing Schedule to show planned windows for relocation of building occupants. Liquidated damages may be assessed as described in the Contract Documents for failure to achieve milestone dates.
- D. This facility may be occupied during construction. In that case: County will provide contractor with schedule of uses; at the site during the construction period; Contractor is to coordinate work with the County and maintain safe access to all buildings at all times and to not disrupt ongoing uses. Contractor must comply with the following requirements:
  - (1) If Contractor must shut down power to any part of the site, Contractor must provide temporary power for that section of the site.
  - (2) Scope of work includes utility and systems upgrade and replacement that may impact the entire site. Work must be coordinated so that site-wide systems remain functional at all times until new systems work is complete and tested.

### **1.13 PHASING SCHEDULE**

- A. The “Start” dates included in the phasing schedule indicate the date that work is to begin on the identified milestone scope of work.
- B. The “Complete” dates included in the phasing schedule indicates that the following must be complete:
  - (1) The entire scope of work for the milestone work must be complete, including all utility work up to the building and all final termination and operation of all building systems.
  - (2) Fire alarm, telephone, data, public address and all other systems final connections must be complete and systems programmed and tested so that fully functional systems are provided.
  - (3) All punch list work must be complete.
  - (4) Maintenance and Operations Manuals must be submitted to the County.
  - (5) All required testing must be complete.
  - (6) All training for all building systems must be complete.
- C. Record Documents for the scope of work of each Milestone included in the Phasing Schedule must be submitted within one week after completion of the Milestone. AutoCAD files to be provided at the completion of each Task Order.

- D. Notice to proceed date is the anticipated date of issuance of the Notice to Proceed. If the Notice to Proceed is issued after the date indicated in the Phasing schedule, the start and completion dates of Milestone No. 1 and No. 8 will be adjusted by the number of days that the Notice to Proceed is delayed.

**PART 2 – PRODUCTS** Not Used.

**PART 3 – EXECUTION** Not Used.

END OF DOCUMENT

DOCUMENT 01 22 00

**UNIT PRICES AND ALTERNATES**

**PART I – ALTERNATES**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions;
- B. Special Conditions;
- C. Bid Form;
- D. Instruction to Bidders.

**1.02 DESCRIPTION**

The items of work indicated below propose modifications to, substitutions for, additions to and/or deletions from the various parts of the Work specified in other Sections of the Specifications. The acceptance or rejection of any of the alternates is strictly at the option of the County subject to County's acceptance of Contractor's stated prices contained in this Proposal.

**1.03 GENERAL**

Where an item is omitted, or scope of Work is decreased, all Work pertaining to the item whether specifically stated or not, shall be omitted and where an item is added or modified or where scope of Work is increased, all Work pertaining to that required to render same ready for use on the Project in accordance with the intention of the Drawings and Specifications shall be included in an agreed upon price amount.

**1.04 BASE BID**

The Base Bid includes all work required to construct the Project completely and in accordance with the Contract Documents.

**PART 2 - UNIT PRICING**

**2.01 GENERAL**

Contractor shall completely state all required figures based on Unit Prices listed below. Where scope of Work is decreased, all Work pertaining to the item, whether specifically stated or not, shall be omitted and where scope of Work is increased, all work pertaining to that item required to render same ready for use on the Project in accordance with intention of Drawings and Specifications shall be included in an agreed upon price amount.

**2.02 UNIT PRICES**

Furnish unit prices for each of the named items on a square foot, lineal foot, or per each basis, as applies. Unit prices shall include all labor, materials, services, profit, overhead, insurance, bonds, taxes, and all other incidental costs of Contractor, subcontractors, and supplier(s).

END OF DOCUMENT

DOCUMENT 01 29 00

**PAYMENT PROCEDURES**

1. County will use its best efforts to make payment to Contractor upon successful completion and acceptance of the performed services within thirty (30) days upon receipt and approval of invoice.

END OF DOCUMENT

DOCUMENT 01 31 19

**PROJECT MEETINGS**

**PART I – GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions
- B. Special Conditions

**1.02 PRECONSTRUCTION CONFERENCE:**

The contractor shall attend a conference at the Project Site prior to the start of construction for the purpose of determining Contractor's access to, and use of the site, verifying utilities, review construction administrative procedures, and such other items as may be pertinent to the start of construction.

**1.03 PROGRESS MEETINGS:**

- A. Construction Manager shall schedule and hold regular weekly progress meetings after a minimum of one week's prior written notice of the meeting date and time to all Invitees as indicated below.
- B. Location: Contractor's field office.
- C. The Contractor shall notify and invite the following entities ("Invitees"):
  - (1) County Representative(s).
  - (2) Contractor.
  - (3) Contractor's Project Manager.
  - (4) Contractor's Superintendent.
  - (5) Subcontractors/suppliers, as appropriate to the agenda of the meeting.
  - (6) Inspector of record.
  - (7) Construction Manager, if any.

- (8) Project Manager
  - (9) Architect
  - (10) Engineer(s), if any and as appropriate to the agenda of the meeting.
  - (11) Others, as appropriate to the agenda of the meeting.
- D. The County's, the Architect's, and/or an engineer's Consultants will attend at their discretion, in response to the agenda.
- E. The County representative, the Construction Manager, and/or another County Agent shall take and distribute meeting notes to attendees and other concerned parties. If exceptions are taken to anything in the meeting notes, those exceptions shall be stated in writing to the County within five (5) working days following County's distribution of the meeting notes.

**1.04 PRE-INSTALLATION/PERFORMANCE MEETING:**

- A. Contractor shall schedule a meeting prior to the start of each of the following portions of the Work: cutting and patching of plaster and roofing, and other weather-exposed and moisture-resistant products. Contractor shall invite all Invitees to this meeting, and others whose work may affect or be affected by the quality of the cutting and patching work.
- B. Contractor shall review in detail prior to this meeting, the manufacturer's requirements and specifications, applicable portions of the Contract Documents, Shop Drawings, and other submittals, and other related work. At this meeting, invitees shall review and resolve conflicts, incompatibilities, or inadequacies discovered or anticipated.
- C. Contractor shall review in detail Project conditions, schedule, requirements for performance, application, installation, and quality of completed Work, and protection of adjacent Work and property.
- D. Contractor shall review in detail means of protecting the completed Work during the remainder of the construction period.

**1.05 SPECIAL MEETINGS:**

Special meetings may be requested by the County. Contractor, subcontractors, material suppliers and any other members of the project team may be required to attend.

END OF DOCUMENT



DOCUMENT 01 33 00

**SUBMITTAL PROCEDURES**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Contractor's Submittals and Schedules, Drawings and Specifications;
- B. Special Conditions.

**1.02 SECTION INCLUDES:**

- A. Definitions:
  - (1) Shop Drawings and Product Data are as indicated in the General Conditions and include, but are not limited to, fabrication, erection, layout and setting drawings, formwork and falsework drawings, manufacturers' standard drawings, descriptive literature, catalogues, brochures, performance and test data, wiring and control diagrams. In addition, there are other drawings and descriptive data pertaining to materials, equipment, piping, duct and conduit systems, and methods of construction as may be required to show that the materials, equipment or systems and all positions conform to the requirement of the Contract Documents, including, without limitation, the Drawings.
  - (2) "Manufactured" applies to standard units usually mass-produced; "fabricated" means specifically assembled or made out of selected materials to meet design requirements. Shop Drawings shall establish the actual detail of manufactured or fabricated items, indicate proper relation to adjoining work and amplify design details of mechanical and electrical equipment in proper relation to physical spaces in the structure.
  - (3) Manufacturer's Instructions: Where any item of Work is required by the Contract Documents to be furnished, installed, or performed, at a minimum, in accordance with a specified product manufacturer's instructions, the Contractor shall procure and distribute copies of these to the County, the Architect, and all other concerned parties and shall furnish, install, or perform the work, at a minimum, in accordance with those instructions.

- B. Samples, Shop Drawings, Product Data, and other items as specified, in accordance with the following requirements:
- (1) Contractor shall submit all Shop Drawings, Product Data, and Samples to the County, the Architect, and the Construction Manager.
  - (2) Contractor shall comply with all time frames herein and in the General Conditions and, in any case, shall submit required information in sufficient time to permit proper consideration and action before ordering any materials or items represented by such Shop Drawings, Product Data, and/or Samples.
  - (3) Contractor shall comply with all time frames herein and in the General Conditions and, in any case, shall allow sufficient time so that no delay occurs due to required lead time in ordering or delivery of any item to the Site. Contractor shall be responsible for any delay in progress of Work due to its failure to observe these requirements.
  - (4) Time for completion of Work shall not be extended on account of Contractor's failure to promptly submit Shop Drawings, Product Data, and/or Samples.
  - (5) Reference numbers on Shop Drawings shall have Architectural and/or Engineering Contract Drawings reference numbers for details, sections, and "cuts" shown on Shop Drawings. These reference numbers shall be in addition to any numbering system that Contractor chooses to use or has adopted as standard.
  - (6) When the magnitude or complexity of submittal material prevents a complete review within the stated time frame, Contractor shall make this submittal in increments to avoid extended delays.
  - (7) Contractor shall certify on submittals for review that submittals conform to Contract requirements. In event of any variance, Contractor shall specifically state in transmittal and on Shop Drawings, portions vary and require approval of a substitute. Also certify that Contractor-furnished equipment can be installed in allocated space.
  - (8) Unless specified otherwise, sampling, preparation of samples, and tests shall be in accordance with the latest standard of the American Society for Testing and Materials.

- (9) Upon demand by Architect or County, Contractor shall submit samples of materials and/or articles for tests or examinations and consideration before Contractor incorporates same in Work. Contractor shall be solely responsible for delays due to sample(s) not being submitted in time to allow for tests. Acceptance or rejection will be expressed in writing. Work shall be equal to approved samples in every respect. Samples that are of value after testing will remain the property of Contractor.

**C. Submittal Schedule:**

- (1) Contractor shall prepare its proposed submittal schedule that is coordinated with its proposed construction schedule and submit both to the County within ten (10) days after the date of the Notice to Proceed. Contractor's proposed schedules shall become the Project Construction Schedule and the Project Submittal Schedule after each is approved by the County.
- (2) Contractor is responsible for all lost time should the initial submittal be rejected, marked "revised and resubmit", etc.
- (3) All Submittals shall be forwarded to the County by the date indicated on the approved Submittal Schedule, unless an earlier date is necessary to maintain the Construction Schedule, in which case those Submittals shall be forwarded to the County so as not to delay the Construction Schedule.

**1.03 SHOP DRAWINGS:**

- A. Contractor shall submit one reproducible transparency and six (6) opaque reproductions. The County will review and return the reproducible copy and one (1) opaque reproduction to Contractor.
- B. Before commencing installation of any Work, the Contractor shall submit and receive approval of all drawings, descriptive data, and material list(s) as required to accomplish Work.
- C. Review of Shop Drawings is regarded as a service to assist Contractor and in all cases original Contract Documents shall take precedence as outlined under General Conditions.
- D. No claim for extra time or payment shall be based on work shown on Shop Drawings unless the claim is (1) noted on Contractor's transmittal letter accompanying Shop Drawings and (2) Contractor has complied with all applicable provisions of the General Conditions, including, without limitation, provisions regarding changes and payment, and all required written approvals.

- E. County shall not review Shop Drawings for quantities of materials or number of items supplied.
- F. County's and/or Architect's review of Shop Drawings will be general. County and/or Architect review does not relieve Contractor of responsibility for accuracy, proper fitting, construction of Work, furnishing of materials, or Work required by Contract Documents and not indicated on Shop Drawings. Shop Drawings reviewed by County and/or Architect is not to be construed as approving departures from Contract Documents.
- G. Review of Shop Drawings and Schedules does not relieve Contractor from responsibility for any aspect of those Drawings or Schedules that is a violation of local, County, State, or Federal laws, rules, ordinances, or rules and regulations of commissions, boards, or other authorities or utilities having jurisdiction.
- H. Before submitting Shop Drawings for review, Contractor shall check Shop Drawings of its subcontractors for accuracy, and confirm that all Work contiguous with and having bearing on other work shown on Shop Drawings is accurately drawn and in conformance with Contract Documents.
- I. Submitted drawings and details must bear stamp of approval of Contractor:
  - (1) Stamp and signature shall clearly certify that Contractor has checked Shop Drawings for compliance with Drawings.
  - (2) If Contractor submits a Shop Drawing without an executed stamp of approval, or whenever it is evident (despite stamp) that Drawings have not been checked, the County and/or Architect will not consider them and will return them to the Contractor for revision and resubmission. In that event, it will be deemed that Contractor has not complied with this provision and Contractor shall bear risk of all delays to same extent as if it had not submitted any Shop Drawings or details.
- J. Submission of Shop Drawings (in either original submission or when resubmitted with correction) constitutes evidence that Contractor has checked all information thereon and that it accepts and is willing to perform Work as shown.
- K. Contractor shall pay for cost of any changes in construction due to improper checking and coordination. Contractor shall be responsible for all additional costs, including coordination. Contractor shall be responsible for costs incurred by itself, the County, the Architect, the Construction Manager, any other Subcontractor or contractor, etc., due to improperly checked and/or coordination of submittals.

- L. Shop Drawings must clearly delineate the following information:
- (1) Project name and address.
  - (2) Architect's name and project number.
  - (3) Shop Drawing title, number, date, and scale.
  - (4) Names of Contractor, Subcontractor(s) and fabricator.
  - (5) Working and erection dimensions.
  - (6) Arrangements and sectional views.
  - (7) Necessary details, including complete information for making connections with other Work.
  - (8) Kinds of materials and finishes.
  - (9) Descriptive names of materials and equipment, classified item numbers, and locations at which materials or equipment are to be installed in the Work. Contractor shall use same reference identification(s) as shown on Contract Drawings.
- M. Contractor shall prepare composite drawings and installation layouts when required to solve tight field conditions.
- (1) Shop Drawings shall consist of dimensioned plans and elevations and must give complete information, particularly as to size and location of sleeves, inserts, attachments, openings, conduits, ducts, boxes, structural interferences, etc.
  - (2) Contractor shall coordinate these composite Shop Drawings and installation layouts in the field between itself and its Subcontractor(s) for proper relationship to the Work, the work of other trades, and the field conditions. The Contractor shall check and approve the submittal(s) before submission for final review.

**1.04 PRODUCT DATA OR NON REPRODUCIBLE SUBMITTALS:**

- A. Contractor shall submit manufacturer's printed literature in original form. Any fading type of reproduction will not be accepted. Contractor must submit a minimum of six (6) each, to the County. County shall return one (1) to the

Contractor, who shall reproduce whatever additional copies it requires for distribution.

- B. Contractor shall submit six (6) copies of a complete list of all major items of mechanical, plumbing, and electrical equipment and materials in accordance with the approved Submittal Schedule, except as required earlier to comply with the approved Construction Schedule. Other items specified are to be submitted prior to commencing Work. Contractor shall submit items of like kind at one time in a neat and orderly manner. Partial lists will not be acceptable.
- C. Submittals shall include manufacturer's specifications, physical dimensions, and ratings of all equipment. Contractor shall furnish performance curves for all pumps and fans. Where printed literature describes items in addition to that item being submitted, submitted item shall be clearly marked on sheet and superfluous information shall be crossed out. If highlighting is used, Contractor shall mark all copies.
- D. Equipment submittals shall be complete and include space requirements, weight, electrical and mechanical requirements, performance data, and supplemental information that may be requested.

**1.05 SAMPLES:**

- A. Contractor shall submit for approval Samples as required and within the time frame in the Contract Documents. Materials such as concrete, mortar, etc., which require on-site testing will be obtained from Project Site.
- B. Contractor shall submit six (6) samples except where greater or lesser number is specifically required by Contract Documents including, without limitation, the Specifications.
  - (1) Samples must be of sufficient size and quality to clearly illustrate functional characteristics, with integrally related parts and attachment devices.
  - (2) Samples must show full range of texture, color, and pattern.
- C. Contractor shall make all Submittals, unless it has authorized Subcontractor(s) to submit and Contractor has notified the County in writing to this effect.
- D. Samples to be shipped prepaid or hand-delivered to the County.
- E. Contractor shall mark samples to show name of Project, name of Contractor submitting, Contract number and segment of Work where representative Sample

will be used, all applicable Specifications Sections and documents, Contract Drawing Number and detail, and ASTM or FS reference, if applicable.

- F. Contractor shall not deliver any material to Site prior to receipt of County's and/or Architect's completed written review and approval. Contractor shall furnish materials equal in every respect to approved Samples and execute Work in conformance therewith.
- G. County's and/or Architect's review, acceptance, and/or approval of Sample(s) will not preclude rejections of any material upon discovery of defects in same prior to final acceptance of completed Work.
- H. After a material has been approved, no change in brand or make will be permitted.
- I. Contractor shall prepare its Submittal Schedule and submit Samples of materials requiring laboratory tests to specified laboratory for testing not less than ninety (90) days before such materials are required to be used in Work.
- J. Samples which are rejected must be resubmitted promptly after notification of rejection and be marked "Resubmitted Sample" in addition to other information required.
- K. Field Samples and Mock-Ups are to be removed by Contractor at County's direction:
  - (1) Size: As Specified.
  - (2) Furnish catalog numbers and similar data, as requested.

**1.06 REVIEW AND RESUBMISSION REQUIREMENTS:**

- A. The County will arrange for review of Sample(s), Shop Drawing(s), Product Data, and other submittal(s) by appropriate reviewer and return to Contractor as provided below within twenty one (21) days after receipt or within twenty one (21) days after receipt of all related information necessary for such review, whichever is later.
- B. One (1) copy of product or materials data will be returned to Contractor with the review status.
- C. Samples to be incorporated into the Work will be returned to Contractor, together with a written notice designating the Sample with the appropriate review status and indicating errors discovered on review, if any. Other Samples will not be

returned, but the same notice will be given with respect thereto, and that notice shall be considered a return of the Sample.

- D. Contractor shall revise and resubmit any Sample(s), Shop Drawing(s), Product Data, and other submittal(s) as required by the reviewer. Such resubmittals will be reviewed and returned in the same manner as original Sample(s), Shop Drawing(s), Product Data, and other submittal(s), within fourteen (14) days after receipt thereof or within fourteen (14) days after receipt of all related information necessary for such review.
- E. Contractor may proceed with any of the Work covered by Sample(s), Shop Drawing(s), Product Data, and other submittal(s) upon its return if designated as no exception taken, or revise as noted, provided the Contractor proceeds in accordance with the County's and/or the Architect's notes and comments.
- F. Contractor shall not begin any of the work covered by a Sample(s), Shop Drawing(s), Product Data, and other submittal(s), designated as revise and resubmit or rejected, until a revision or correction thereof has been reviewed and returned to Contractor.
- G. Sample(s), Shop Drawing(s), Product Data, and other submittal(s) designated as revise and resubmit or rejected and requiring resubmittal, shall be revised or corrected and resubmitted to the County no later than fourteen (14) days or a shorter period as required to comply with the approved Construction Schedule, after its return to Contractor.
- H. Neither the review nor the lack of review of any Sample(s), Shop Drawing(s), Product Data, and other submittal(s) shall waive any of the requirements of the Contract Documents, or relieve Contractor of any obligation thereunder.
- I. County's and/or Architect's review of Shop Drawings does not relieve the Contractor of responsibility for any errors that may exist. Contractor is responsible for the dimensions and design of adequate connections and details and for satisfactory construction of all the Work.

END OF DOCUMENT



**DOCUMENT 01 35 23**

**CONSTRUCTION INDOOR AIR QUALITY MANAGEMENT**

**PART 1 GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions 00 72 13
- B. Special Conditions 00 73 13
- C. Summary of Work 01 10 00 (Work Covered by Contract)

**1.02 CONSTRUCTION IAQ MANAGEMENT REQUIREMENT**

- A. The Work of this Project shall minimize the detrimental impacts on Indoor Air Quality (IAQ) resulting from construction activities. Minimize factors that contaminate indoor air, such as, but not limited to: Dust entering HVAC systems and ductwork, improper storage of materials on-site, and poor housekeeping.
- B. Design Builder shall develop an Indoor Air Quality (IAQ) Management Plan that is based on the minimum requirements of the Sheet Metal and Air Conditioning National Design Builders Association (SMACNA) IAQ Guidelines for Occupied Buildings under Construction.
- C. Permanent heating, ventilation, and air conditioning equipment shall not be used for to heat, cool, or ventilate zones, areas, and sites that are under construction. Design Builder shall include measures to provide temporary ventilation, heating, and cooling as necessary.

**1.03 SUMMARY**

- A. This Section includes Design Builder requirements for the development and implementation of a Construction Indoor Air Quality Management Plan (IAQ Plan). Develop the IAQ Plan for

review and approval by Owner. The IAQ Plan shall be implemented throughout the duration of the project construction, and shall be documented as outlined in the SUBMITTALS Article below.

- B. The IAQ Management plan shall be submitted to Owner for review and approval must prior to the commencement of construction.

#### **1.04 DEFINITIONS**

- A. Volatile Organic Compounds (VOC's): Chemical compounds common in and emitted by many building products, including solvents in paints, coatings, adhesives and sealants, wood preservatives; composite wood binder, and foam insulations. Not all VOC's are harmful, but many of those contained within building products contribute to the formation of smog and irritate (at best) building occupants by their smell and/or health impact.
- B. Materials that act as "sinks" for VOC contamination: Absorptive materials, typically dry and soft (such as textiles, carpeting, acoustical ceiling tiles and gypsum board) that readily absorb VOC's emitted by "source" materials and release them over a prolonged period of time.
- C. Materials that act as "sources" for VOC contamination: Products with high VOC contents that emit VOC's either rapidly during application and curing (typically "wet" products, such as paints, sealants, adhesives, caulks and sealers) or over a prolonged period (typically "dry" products such flooring coverings with plasticizers and engineered wood with formaldehyde).
- D. MERV: Minimum Efficiency Reporting Value.
- E. SMACNA: Sheet Metal and Air Conditioning National Design Builder's Association.

#### **1.05 REFERENCES, RESOURCES**

- A. "IAQ Guidelines for Occupied Buildings Under Construction", 2nd Edition, November 2007, The Sheet Metal and Air Conditioner Design Builders National Association (SMACNA), [www.smacna.org](http://www.smacna.org).

- B. ANSI/ASHRAE 52.2-1999, "Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size", [www.ashrae.org](http://www.ashrae.org).

#### **1.06 CONSTRUCTION IAQ MANAGEMENT PLAN**

- A. Prepare, submit, and implement a Construction IAQ Management Plan to the Owner for review and approval for each floor during the duration on construction. The Construction IAQ Management Plan shall meet the following criteria:
1. Construction activities shall be planned to meet or exceed the minimum requirements of the Sheet Metal and Air Conditioning National Design Builders' Association (SMACNA) "IAQ Guidelines for Occupied Buildings under Construction", First Edition, 1995.
  2. Identify and implement IAQ controls, sources of dust, odors, other contaminants.
  3. Upon periodic inspections during construction, if the ducts become contaminated due to inadequate protection, the ducts will be cleaned professionally. This activity is the responsibility of the Design Builder.
  4. Furnish and install plastic barriers for dust or fumes and dirt containment, and special covers for equipment, cover any furniture and electronic equipment, and isolate from distribution system for IDF and MDF rooms.
  5. Identify and implement procedures and implement necessary measures to protect any smoke detector heads from dust or fumes and potential false alarms during the demolition work. Design Builder shall provide fire watch as required by the construction activities.
  6. Identify and implement construction activities likely to produce DETECTABLE odors, vapor, and dust
  7. Identify and implement measures to protect the ventilation system components and air pathways against contamination during construction.

8. Identify and implement measures to positively pressurize occupied floors and negatively pressurize construction zones and areas.
9. Plans shall include cleaning procedure to be used prior to floor being occupied in the event that the ventilation system components and air pathways are not adequately protected. All areas are to be cleaned prior to a certificate to occupy the space by Owner.
10. Indicate the location, type, amount, sequence, and timing of the various control measure, including emergency procedures, and the labor, materials and the time required to implement them.
11. Absorptive materials shall be protected from moisture damage when stored on-site and after installation.
12. Identify and implement measures to protect carpet and flooring from dust and debris with heavy-duty, water-resistant Flexboard. Flexboard shall be securely fastened with tape. Tack mats shall be included when leaving a construction zone and entering occupied area.
13. Identify and implement modified work practices such as vacuum assisted saws or working weekends for extreme odor and dust generating activities.
14. Identify and implement measures for sealing and protecting all shafts, chases, and all penetrations openings that are pathways between floors in the building.
15. Plan and install temporary full-height walls from floor to floor to isolate lobbies and access pathways to either of the floors. Temporary walls or curtains shall be full-height walls from floor to floor containment for vapor and dust.
16. Identify and implement measures to protect all workstations and office equipment that is stored in the construction area.
17. Design Builder shall photograph and document all IAQ controls that were installed with a brief description of the

SMACNA approach employed, such as protection of ducts, and on-site installed floor, wall, and absorptive materials.

18. For air handlers that are to be used for the occupied floors, filtration with a Minimum Efficiency Reporting Value (MERV) of 8 must be at each return air grill, as determined by ASHRAE 52.2-1999.
19. Filtration media shall be replaced immediately prior to occupancy. Filtration media shall have a Minimum Efficiency Reporting Value (MERV) of 13 as determined by ASHRAE 52.2-1999. Confirm that all air filters, casing, coils, fans and ducts are clean, before testing and balancing (TAB) the system, and air quality testing.
20. A "Sequence of Finish Installation Plan" shall be developed, highlighting measures to reduce the absorption of VOCs by materials that act as "sinks".

**B. Upon approval of the IAQ Plan by the Owner, it shall be implemented by the Design Builder through the duration of the construction process for both floors of this phased construction project, and documented in accordance with the SUBMITTALS Article below. The IAQ controls will be field verified by Owner prior to the commencement of work. Owner will issue a notice to commence construction when all IAQ requirements have been met.**

C. Further description of the Construction IAQ Management Plan requirements is as follows:

1. SMACNA Guidelines: Chapter 3 of the referenced "IAQ Guidelines for Occupied Buildings Under Construction", outline IAQ measures in five categories as listed below. The Construction IAQ Management Plan shall be organized in accordance with the SMACNA format, and shall address measures to be implemented in each of the five categories (including subsections). All subsections shall be listed in the Plan; items that are not applicable for this project should be listed as such.
  - a. HVAC Protection:
    - 1) Return Side.
    - 2) Central Filtration.
    - 3) Supply Side.
    - 4) Duct Cleaning.
  - b. Source Control:
    - 1) Product Substitution.

- 2) Modifying Equipment Operation.
  - 3) Changing Work Practices.
  - 4) Local Exhaust.
  - 5) Air Cleaning.
  - 6) Cover or Seal
- c. Pathway Interruption:
- 1) Depressurize Work Area.
  - 2) Pressurize Occupied Space.
  - 3) Erect full-height Barriers to Contain Construction Areas.
  - 4) Relocate Pollutant Sources.
  - 5) Temporarily Seal the Building.
  - 6) Sealing air intakes and return systems
- d. Housekeeping
- 1) Cleaning to reduce migration of dust or odor
  - 2) Covering and protecting
- e. Scheduling:
- 1) Protect of Materials from Moisture Damage: As part of the “Housekeeping” section of the Construction IAQ Management Plan, measures to prevent installed materials or material stored on-site from moisture damage shall be described. This section should also describe measures to be taken if moisture damage does occur to absorptive materials during the course of construction.
  - 2) Replacement of Filtration Media: Under the “HVAC Protection” section of the Construction IAQ Management Plan, a description of the filtration media in all ventilation equipment shall be provided. The description shall include replacement criteria for filtration media during construction, and confirmation of filtration media replacement for all equipment immediately prior to occupancy.
  - 3) Sequence of Finish Installation for Materials: Where feasible, absorptive materials shall be installed after the installation of materials or finishes which have high short-term emissions of VOC’s, formaldehyde, particulates, or other air-borne compounds. Absorptive materials include, but are not limited to: carpets; acoustical ceiling panels; fabric wall coverings; insulations (exposed to the airstream); upholstered furnishings; and other woven, fibrous or porous materials. Materials with high short-term emissions

include, but are not limited to: adhesives, sealants and glazing compounds (specifically those with petrochemical vehicles or carriers); paints, wood preservatives and finishes; control and/or expansion joint fillers; hard finishes requiring adhesive installation; gypsum board (with associated finish processes and products); and composite or engineered wood products with formaldehyde binders.

- 4) Develop a separate sequencing plan that identifies feasible opportunities to meet the above-stated goals for the project. The plan shall be submitted to Owner or Owner's Representative in accordance with the SUBMITTALS Article below.
- 5) Implementation and Coordination: Implement the Construction IAQ Management Plan, and coordinate the Plan with all affected trades. Include provisions in the Construction IAQ Management Plan for addressing conditions in the field that do not adhere to the Plan, including provisions to implement a stop work order, or to rectify non-compliant conditions.
- 6) Designate one individual as the Construction IAQ Representative, who will be responsible for communicating the progress and any issues implementing the IAQ Management Plan with the Owner or Owner's Representative.

#### **1.07 SUBMITTALS**

- A. Submit the following records and documents:
  1. A copy of the Construction IAQ Management Plan and the Sequence Installation Plan, as defined in CONSTRUCTION IAQ MANAGEMENT PLAN Article above.
  2. Product cut-sheets for all filtration media used during construction and installed immediately prior to occupancy, with MERV values highlighted.
  3. Provide the Owner or Owner's Representative with a minimum of 18 photographs comprising of at least six photographs taken on three different occasions during construction. The photographs shall document the implementation of the Construction IAQ Management Plan throughout the course of the project construction. Examples include photographs of ductwork sealing and protection, temporary ventilation

measures, and conditions of on-site materials storage (to prevent moisture damage). Photographs shall include integral date stamping, and shall be submitted with brief descriptions of the Construction IAQ Management Plan measure documented, or be referenced to project meeting minutes or similar project documents which reference to the Construction IAQ Management Plan measure documented.

**PART 2 PRODUCTS (Not Used)**

**PART 3 EXECUTION**

- A. Procedures during construction shall use all elements of the IAQ management plan.
- B. Meet or exceed the minimum requirements of the Sheet Metal and Air Conditioning National Design Builders Association (SMACNA) IAQ Guidelines for Occupied Buildings Under Construction, as applicable to new buildings. As a minimum, but not limited to, this means:
  - 1. Protect the ventilation system components from contamination:
    - a. Store HVAC equipment in a clean, dry location.
    - b. Seal all HVAC inlets and outlets.
    - c. Seal HVAC components during installation.
    - d. Use a temporary ventilation system during construction.
    - e. Use temporary filtration media.
      - 1) Filtration media shall have a Minimum Efficiency Reporting Value (MERV) of 8 as determined by ASHRAE 52.2-1999) on any return air systems operational during construction. For air intakes into rooms that are very sensitive to dust contamination, such as computer rooms, filtration media should be the best that the HVAC systems fans can handle, up to an MERV rating of 17.
      - 2) Replace all filtration media immediately prior to occupancy.
    - f. Clean air plenums before closing them in.
    - g. Inspect filters regularly.
  - 2. Provide pollution source control:
    - a. Protect on-site stored and installed absorptive materials (such as insulation, drywall, and wood) from moisture damage and from contamination by construction dust, debris, and fumes during all phases of construction, both before and after installation.
    - b. Do not install moisture-damaged materials.
    - c. Ensure that construction detailing will not result in moisture intrusion.



- d. Use low-emitting products (specified in appropriate sections).
  - e. Provide strategies to avoid tracking pollutants into the work areas.
  - e. Allow high-VOC materials to off-gas prior to installation. For example, all dry furnishing and materials (such as carpet, floor tile, acoustical tile, textiles, office furniture, wood shelving, etc.) shall be allowed to “air-out” in clean environments prior to installation in a building.
  - f. Use the least amount of "wet" materials (such as adhesives, sealants, glazes, caulks, paints, etc.) during construction and product applications while still maintaining installation protocol required to meeting for manufacturer’s warrantee requirements.
- 3. Provide interruption of pollutant pathways:
  - a. Provide temporary barriers to seal and isolate areas of the work to prevent contamination of clean or occupied spaces.
  - b. Depressurize the work area to prevent contamination of adjacent areas.
  - c. During installation of VOC emitting materials, maximize ventilation of work areas with outside air. Exhaust directly to the exterior. Do not cross contaminate.
- 4. Practice Healthy Housekeeping.
  - a. Minimize accumulation of dust and other contaminants.
  - b. Confine dust-generating activities.
  - c. Suppress dust. Dry sanding allowed subject to owner approval.
  - d. Clean up dust.
  - e. Clean up spills.
  - f. Keep work area dry.
  - g. Seal containers of volatile liquids.
- 5. Schedule construction activities to reduce exposure to VOCs.
  - a. Install porous materials only after closing in the building.
  - b. Account for curing time and off-gassing when scheduling construction activities.
  - c. Allow wet-spray cellulose to dry before covering.
  - d. Install carpeting, acoustical panels, and furnishings after interior finishes have been allowed time to cure/dry in accordance with other good building practice.
  - e. Provide adequate ventilation during curing period.
    - 1) Provide supplemental (spot) ventilation for at least 72 hours after work is completed. Preferred HVAC system operation uses supply air fans and ducts only; exhaust provided through windows. Use exhaust fans to pull exhaust air from deep interior locations. Stair towers and other paths to exterior can be useful during this process.
- C. Use safety meetings and signage, to communicate the goals of the construction indoor air quality management construction plan.

- D. Conduct regular inspection and maintenance of indoor air quality measures including ventilation system protection, and ventilation rate.
- E. Require VOC-safe masks for interior and exterior workers installing VOC-emitting products (products that contain 150 g/L or more VOCs).
- F. Use low-toxic cleaning supplies for surfaces, equipment, and worker's personal use. Options include several soybean-based solvents and cleaning options and citrus-based cleaners. (SoySolv provides several soy-based solvents and cleaning options. Phone 1-800-231-4274 or [www.soysoolv.com](http://www.soysoolv.com).)
- G. Smoking is prohibited on site and within 50 feet of the building during and after construction

**END OF DOCUMENT**

DOCUMENT 01 41 00

**REGULATORY REQUIREMENTS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Obtaining of Permits and Licenses and Work To Comply With All Applicable Regulations;
- B. Special Conditions;
- C. Quality Control.

**1.02 DESCRIPTION:**

- A. This section covers the general requirements for regulatory requirements pertaining to the Work and is supplementary to all other regulatory requirements mentioned or referenced elsewhere in the Contract Documents.

**1.03 REQUIREMENTS OF REGULATORY AGENCIES:**

- A. All statutes, ordinances, laws, rules, codes, regulations, standards, and the lawful orders of all public authorities having jurisdiction of the Work, are hereby incorporated into these Contract Documents as if repeated in full herein and are intended to be included in any reference to Code or Building Code, unless otherwise specified, including, without limitation, the references in the list below. Contractor shall make available at the Site copies of all the listed documents applicable to the Work as the County and/or Architect may request, including, without limitation, applicable portions of the California Code of Regulations ("CCR").
- B. Items of deferred approval shall be clearly marked on the first sheet of the Architect's and/or Engineer's approved Drawings.
  - (1) Building Standards Administrative Code, Part 1, Title 24, CCR
  - (2) California Building Code (CBC), Part 2, Title 24, CCR; (Uniform Building code volumes 1-3 and California Amendments).

- (3) California Electrical Code (CEC), Part 3, Title 24, CCR; (National Electrical Code and California Amendments).
- (4) California Mechanical Code (CMC), Part 4, Title 24, CCR; (Uniform Mechanical Code and California Amendments).
- (5) California Plumbing Code (CPC), Part 5, Title 24, CCR; (Uniform Plumbing Code and California Amendments).
- (6) California Fire Code (CFC), Part 9, Title 24, CCR; (Fire Plumbing Code and California Amendments).
- (7) California Referenced Standards Code, Part 12, Title 24, CCR
- (8) Title 19, CCR, Public Safety, State Fire Marshal Regulations.
- (9) Partial List of Applicable NFPA Standards:
  - (a) NFPA 13 - Automatic Sprinkler System.
  - (b) NFPA 14 - Standpipes Systems.
  - (c) NFPA 17A - Wet Chemical System
  - (d) NFPA 24 - Private Fire Mains.
  - (e) NFPA 70 - National Electrical Code, Chapter 8, Communications Systems, Article 800, General Requirements for Communications Systems.
  - (f) (California Amended) NFPA 72 - National Fire Alarm Codes.
  - (g) NFPA 253 - Critical Radiant Flux of Floor Covering System.
  - (h) NFPA 2001 - Clean Agent Fire Extinguishing Systems.

**END OF DOCUMENT**

DOCUMENT 01 42 13

**ABBREVIATIONS AND ACRONYMS**

**PART 1 – GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions including without limitation, Definitions
- B. Special Conditions

**1.02 DOCUMENT INCLUDES:**

- A. Abbreviations used throughout the Contract Documents.
- B. Reference to a technical society, organization, or body is by abbreviation, as follows:

1.	AA	Aluminum Association
2.	AAMA	Architectural Aluminum Manufacturers Association
3.	AASHTO	American Association of State Highway and Transportation Officials
4.	ABPA	Acoustical and Board Products Association
5.	ACI	American Concrete Institute
6.	AGA	American Gas Association
7.	AGC	Associated General Contractors
8.	AHC	Architectural Hardware Consultant
9.	AI	Asphalt Institute
10.	AIA	American Institute of Architects
11.	AIEE	American Institute of Electrical Engineers
12.	AISC	American Institute of Steel Construction
13.	AISI	American Iron and Steel Institute
14.	AMCA	Air Moving and Conditioning Association
15.	ANSI	American National Standards Institute
16.	APA	American Plywood Association
17.	ARI	Air Conditioning and Refrigeration Institute
18.	ASHRAE	American Society of Heating, Refrigeration and Air Conditioning Engineers
19.	ASME	American Society of Mechanical Engineers

20.	ASSE	American Society of Structural Engineers
21.	ASTM	American Society of Testing and Materials
22.	AWPB	American Wood Preservers Bureau
23.	AWPI	American Wood preservers Institute
24.	AWS	American Welding Society
25.	AWSC	American Welding Society Code
26.	AWI	Architectural Woodwork Institute
27.	AWWA	American Water Works Association
28.	BIA	Brick Institute of America
29.	CCR	California Code of Regulations
30.	CLFMI	Chain Link Fence Manufacturers Institute
31.	CMG	California Masonry Guild
32.	CRA	California Redwood Association
33.	CRSI	Concrete Reinforcing Steel Institute
34.	CS	Commercial Standards
35.	CSI	Construction Specifications Institute
36.	CTI	Cooling Tower Institute
37.	FGMA	Flat Glass Manufacturer's Association
38.	FIA	Factory Insurance Association
39.	FM	Factory Mutual
40.	FS	Federal Specification
41.	FTI	Facing Title Institute
42.	GA	Gypsum Association
43.	ICBO	International Conference of Building Officials
44.	IEEE	Institute of Electrical and Electronic Engineers
45.	IES	Illumination Engineering Society
46.	LIA	Lead Industries Association
47.	MIA	Marble Institute of America
48.	MLMA	Metal Lath Manufacturers Association
49.	MS	Military Specifications
50.	NAAMM	National Association of Architectural Metal Manufacturers
51.	NBHA	National Builders Hardware Association
52.	NBFU	National Board of Fire Underwriters
53.	NBS	National Bureau of Standards
54.	NCMA	National Concrete Masonry Association
55.	NEC	National Electrical Code
56.	NEMA	National Electrical Manufacturers Association
57.	NFPA	National Fire Protection Association/National Forest Products Association
58.	NMWIA	National Mineral Wool Insulation Association
59.	NTMA	National Terrazzo and Mosaic Association
60.	NWMA	National Woodwork Manufacturer's Association
61.	ORS	Office of Regulatory Services (California)

62.	OSHA	Occupational Safety and Health Act
63.	PCI	Precast Concrete Institute
64.	PCA	Portland Cement Association
65.	PDCA	Painting and Decorating Contractors of America
66.	PDI	Plumbing Drainage Institute
67.	PEI	Porcelain Enamel Institute
68.	PG&E	Pacific Gas & Electric Company
69.	PS	Product Standards
70.	SDI	Steel Door Institute; Steel Deck Institute
71.	SJI	Steel Joist Institute
72.	SSPC	Steel Structures Painting Council
73.	TCA	Tile Council of America
74.	TPI	Truss Plate Institute
75.	UBC	Uniform Building Code
76.	UL	Underwriters Laboratories Code
77.	UMC	Uniform Mechanical Code
78.	USDA	United States Department of Agriculture
79.	VI	Vermiculite Institute
80.	WCLA	West Coast Lumberman's Association
81.	WCLB	West Coast Lumber Bureau
82.	WEUSER	Western Electric Utilities Service Engineering Requirements
83.	WIC	Woodwork Institute of California
84.	WPOA	Western Plumbing Officials Association

END OF DOCUMENT

DOCUMENT 01 42 16

**DEFINITIONS AND REFERENCE STANDARDS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISION**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions including without limitation, Definitions;
- B. Special Conditions;

**1.02 QUALITY ASSURANCE:**

- A. For products or workmanship specified by association, trade, or Federal Standards, Contractor shall comply with requirements of the standard, except when more rigid requirements are specified in the Contract Documents, or are required by applicable codes.
- B. Contractor shall conform to current reference standard publication date in effect on the date of bid opening.
- C. Contractor shall obtain copies of standards unless specifically required not to by the Contract Documents.
- D. Contractor shall maintain a copy of all standards at jobsite during submittals, planning, and progress of the specific Work, until final completion, unless specifically required not to by the Contract Documents.
- E. Should specified reference standards conflict with Contract Documents, Contractor shall request clarification from the County and./or the Architect before proceeding.
- F. The contractual relationship of the parties to the Contract shall not be altered from the contractual relationship as indicated in the Contract Documents by mention or inference otherwise in any referenced document.
- G. Governing Codes shall be as shown in the Contract Documents including, without limitation, the Specifications.



**1.03 SCHEDULE OF REFERENCES:**

**The following information is intended only for the general assistance of the Contractor, and the County does not represent that all of the information is current. It is the Contractor's responsibility to verify the correct information for each of the entities listed.**

AA	Aluminum Association 900 19 <sup>th</sup> Street NW, Suite 300 Washington, DC 20006 <a href="http://www.aluminum.org">www.aluminum.org</a>	202/862-5100
AABC	Associated Air Balance Council 1518 K Street, NW, Suite 503 Washington, DC 20005 <a href="http://www.aabchq.com">www.aabchq.com</a>	202/737-0202
AAMA	American Architectural Manufacturers Association 1827 Walden Office Sq., Suite 104 Schaumburg, IL 60173-4268 <a href="http://www.aamanet.org">www.aamanet.org</a>	847/303-5664
AASHTO	American Association of State Highway and Transportation Officials 444 North Capitol Street, Suite 249 Washington, DC 20001 <a href="http://www.aashto.org">www.aashto.org</a>	202/624-5800
AATCC	American Association of Textile Chemists and Colorists P.O. Box 12215 One Davis Drive Research Triangle Park, NC 27709-2215 <a href="http://www.aatcc.org">www.aatcc.org</a>	919/549-8141
ACI	American Concrete Institute P.O. Box 9094 Farmington Hills, MI 48333-9094 <a href="http://www.aci-int.org">www.aci-int.org</a>	248/848-3700
ACPA	American Concrete Pipe Association 222 West Las Colinas Blvd., Suite 641 Irving, TX 75039-5423 <a href="http://www.concrete-pipe.org">www.concrete-pipe.org</a>	972/506-7216

ADC	Air Diffusion Council 11 South LaSalle St., Suite 1400 Chicago, IL 60603	312/201-0101
AFPA	American Forest and Paper Association 1111 19th St., NW, Suite 800 Washington, DC 20036	202/463-2700
AGA	American Gas Association 1515 Wilson Blvd. Arlington VA 22209 <a href="http://www.aga.com">www.aga.com</a>	703/841-8400
AHA	American Hardboard Association 1210 W. Northwest Hwy Palatine, IL 60067-1897	847/934-8800
AI	Asphalt Institute Research Park Drive P.O. Box 14052 Lexington, KY 40512-4052 <a href="http://www.asphaltinstitute.org">www.asphaltinstitute.org</a>	606/288-4960
AIA	The American Institute of Architects 1735 New York Avenue, NW Washington, DC 20006-5292 <a href="http://www.aia.org">www.aia.org</a>	202/626-7300
AISC	American Institute of Steel Construction One East Wacker Drive, Suite 3100 Chicago, IL 60601-2001	800/644-2400
AITC	American Institute of Timber Construction 7012 S. Revere Pkwy., Suite 140 Englewood, CO 80112 <a href="http://www.aitc-glulam.org">www.aitc-glulam.org</a>	303/792-9559
ALCA	Associated Landscape Contractors of America 12200 Sunrise Valley Drive, Suite 150 Reston, VA 20191 <a href="http://www.alca.org">www.alca.org</a>	703/620-6363

**Alameda County General Services Agency**  
**AS-NEEDED HVAC MAINTENANCE**  
**AND REPAIRS**

**MASTER CONTRACT ID #901911**

ALI	Associated Laboratories, Inc. P.O. Box 152837 1323 Wall St. Dallas, TX 75315	214/565-0593
ALSC	American Lumber Standards Committee P.O. Box 210 Germantown, MD 20875	301/972-1700
AMCA	Air Movement and Control Association International, Inc. 30 W. University Drive Arlington Heights, IL 60004-1893 <a href="http://www.amca.org">www.amca.org</a>	847/394-0150
ANLA	American Nursery and Landscape Association 1250 Eye Street, NW, Suite 500 Washington, DC 20005	202/789-2900
ANSI	American National Standards Institute 11 West 42nd Street, 13th Floor New York, NY 10036-8002 <a href="http://www.ansi.org">www.ansi.org</a>	212/642-4900
APA	APA-The Engineered Wood Association P.O. Box 11700 Tacoma, WA 98411-0700 <a href="http://www.apawood.org">www.apawood.org</a>	206/565-6600
APA	Architectural Precast Association P.O. Box 08669 Fort Myers, FL 33908-0669	941/454-6989
ARI	Air Conditioning and Refrigeration Institute 4301 Fairfax Drive, Suite 425 Arlington, VA 22203 <a href="http://www.ari.org">www.ari.org</a>	703/524-8800
ARMA	Asphalt Roofing Manufacturers Association Center Park 4041 Powder Mill Road, Suite 404 Calverton, MD 20705	301/231-9050
ASA	Acoustical Society of America	516/576-2360

500 Sunnyside Blvd.  
Woodbury, NY 11797

ASCE	American Society of Civil Engineers- World Headquarters 1801 Alexander Bell Drive Reston, VA 20190-4400 <a href="http://www.asce.org">www.asce.org</a>	800/548-2723 703/295-6000
ASHRAE	American Society of Heating, Refrigerating and Air Conditioning Engineers 1791 Tullie Circle, NE Atlanta, GA 30329-2305 <a href="http://www.ashrae.org">www.ashrae.org</a>	800/527-4723 404/636-8400
ASLA	American Society of Landscape Architects 4401 Connecticut Ave., NW, 5th Floor Washington, DC 20008-2369 <a href="http://www.asla.org">www.asla.org</a>	202/686-2752
ASME	American Society of Mechanical Engineers 345 East 47 <sup>th</sup> Street New York, NY 10017-2392 <a href="http://www.asme.org">www.asme.org</a>	800/434-2763
ASPE	American Society of Plumbing Engineers 3617 Thousand Oaks Blvd., Suite 210 Westlake, CA 91362-3649	805/495-7120
ASQC	American Society for Quality Control 611 E. Wisconsin Avenue Milwaukee, WI 53201-3005 <a href="http://www.asqc.org">www.asqc.org</a>	800/248-1946 414/272-8575
ASSE	American Society of Sanitary Engineering 28901 Clemens Road Westlake, OH 44145 <a href="http://www.asse-plumbing.org">www.asse-plumbing.org</a>	216/835-3040
ASTM	American Society for Testing and Materials 100 Barr Harbor Drive West Conshohocken, PA 19428-2959 <a href="http://www.astm.org">www.astm.org</a>	610/832-9500

AWCI	Association of the Wall and Ceiling Industries--International 307 E. Annandale Road, Suite 200 Falls Church, VA 22042-2433 <a href="http://www.awci.org">www.awci.org</a>	703/534-8300
AWPA	American Wood-Preservers' Association 3246 Fall Creek Highway, Suite 1900 Granbury, TX 76049-7979	817/326-6300
AWS	American Welding Society 550 NW LeJeune Road Miami, FL 33126 <a href="http://www.amweld.org">www.amweld.org</a>	800/443-9373 305/443-9353
AWWA	American Water Works Association 6666 West Quincy Avenue Denver, CO 80235 <a href="http://www.awwa.org">www.awwa.org</a>	800/926-7337 303/794-7711
BHMA	Builders' Hardware Manufacturers Association 355 Lexington Avenue, 17th Floor New York, NY 10017-6603	212/661-4261
CBM	Certified Ballast Manufacturers Association 1422 Euclid Avenue, Suite 402 Cleveland, OH 44115-2094	216/241-0711
CGA	Compressed Gas Association 1725 Jefferson Davis Hwy, Suite 1004 Arlington, VA 22202-4102 <a href="http://www.cganet.com">www.cganet.com</a>	703/412-0900
CISCA	Ceilings & Interior Systems Construction Association 1500 Lincoln Hwy, Suite 202 St. Charles, IL 60174 <a href="http://www.cisca.org">www.cisca.org</a>	630/584-1919
CISPI	Cast Iron Soil Pipe Institute 5959 Shallowford Road, Suite 419 Chattanooga, TN 37421	423/892-0137

CPSC	Consumer Product Safety Commission East West Towers 4330 East-West Hwy. Bethesda, MD 20814	800/638-2772
CPPA	Corrugated Polyethylene Pipe Association 432 N. Superior Street Toledo, OH 43604	800/510-2772 419/241-2221
CRA	California Redwood Association 405 Enfrente Drive, Suite 200 Novato, CA 94949	415/382-0662
CRI	Carpet and Rug Institute 310 S. Holiday Avenue Dalton, GA 30722-2048 <a href="http://www.carpet-rug.com">www.carpet-rug.com</a>	800/882-8846 706/278-3176
CRSI	Concrete Reinforcing Steel Institute 933 N. Plum Grove Road Schaumburg, IL 60173-4758 <a href="http://www.crsi.org">www.crsi.org</a>	847/517-1200
CTI	Ceramic Tile Institute of America 12061 W. Jefferson Blvd. Culver City, CA 90230-6219	310/574-7800
DHI	Door and Hardware Institute 14170 Newbrook Drive Chantilly, VA 20151-2223 <a href="http://www.dhi.org">www.dhi.org</a>	703/222-2010
DIPRA	Ductile Iron Pipe Research Association 245 Riverchase Pkwy East, Suite O Birmingham, AL 35244	205/988-9870
DOC	Department of Commerce 14 <sup>th</sup> Street and Constitution Avenue, NW Washington, DC 20230	202/482-2000
DOT	Department of Transportation 400 Seventh Street, SW Washington, DC 20590	202/366-4000

EJMA	Expansion Joint Manufacturers Association 25 N. Broadway Tarrytown, NY 10591-3201	914/332-0040
EPA	Environmental Protection Agency 401 M Street, SW Washington, DC 20460	202/260-2090
FCICA	Floor Covering Installation Contractors Association P.O. Box 948 Dalton, GA 30722-0948	706/226-5488
FM	Factory Mutual 1151 Boston-Providence Turnpike P.O. Box 9102 Norwood, MA 02062-9102 <a href="http://www.factorymutual.com">www.factorymutual.com</a>	781/255-4300
FS	Federal Specifications Unit (Available from GSA) 470 East L'Enfant Plaza, SW, Suite 8100 Washington, DC 20407	202/619-8925
GA	Gypsum Association 810 First Street NE, Suite 510 Washington, DC 20002 <a href="http://www.usg.com">www.usg.com</a>	202/289-5440
GANA	Glass Association of North America 3310 SW Harrison Street Topeka, KS 66611-2279 <a href="http://www.glasswebsite.com/gana">www.glasswebsite.com/gana</a>	913/266-7013
HMA	Hardwood Manufacturers Association 400 Penn Center Blvd., Suite 530 Pittsburgh, PA 15235-5605 <a href="http://www.hardwood.org">www.hardwood.org</a>	412/828-0770
HPVA	Hardwood Plywood and Veneer Association 1825 Michael Farraday Drive P.O. Box 2789 Reston, VA 22195-0789	703/435-2900

[www.hpva.org](http://www.hpva.org)

IEEE	Institute of Electrical and Electronic Engineers 345 E. 47 <sup>th</sup> Street New York, NY 10017-2394 <a href="http://www.ieee.org">www.ieee.org</a>	800/678-4333 212/705-7900
IESNA	Illuminating Engineering Society of North America 120 Wall Street, 17th Floor New York, NY 10005-4001 <a href="http://www.iesna.org">www.iesna.org</a>	212/248-5000
ITS	Intertek Testing Services P.O. Box 2040607/753-6711 3933 US Route 11 Cortland, NY 13045-7902 <a href="http://www.itsglobal.com">www.itsglobal.com</a>	800/345-3851
LMA	Laminating Materials Association 116 Lawrence Street Hillsdale, NJ 07642-2730 <a href="http://www.lma.org">www.lma.org</a>	201/664-2700
MCAA	Mechanical Contractors Association of America 1385 Piccard Drive Rockville, MD 20850-4329	301/869-5800
ML/SFA	Metal Lath/Steel Framing Association (A Division of the NAAMM) 8 South Michigan Avenue, Suite 1000 Chicago, IL 60603	312/456-5590
MSS	Manufacturers Standardization Society for the Valve and Fittings Industry 127 Park Street, NE Vienna, VA 22180-4602	703/281-6613
NAA	National Arborist Association P.O. Box 1094603/673-3311 Amherst, NH 03031-1094 <a href="http://www.natlarb.com">www.natlarb.com</a>	800/733-2622
NAAMM	National Association of Architectural Metal Manufacturers	312/782-5590



8 South Michigan Avenue, Suite 1000  
Chicago, IL 60603  
[www.gss.net/naamm](http://www.gss.net/naamm)

NAIMA	North American Insulation Manufacturers Association 44 Canal Center Plaza, Suite 310 Alexandria, VA 22314 <a href="http://www.naima.org">www.naima.org</a>	703/684-0084
NAPA	National Asphalt Pavement Association NAPA Building 5100 Forbes Blvd. Lanham, MD 20706-4413	301/731-4748
NCSA	National Corrugated Steel Pipe Association 1255 23rd Street, NW, Suite 850 Washington, DC 20037 <a href="http://www.ncspa.org">www.ncspa.org</a>	202/452-1700
NEBB	National Environmental Balancing Bureau 8575 Grovemont Circle Gaithersburg, MD 20877-4121	301/977-3698
NECA	National Electrical Contractors Association 3 Bethesda Metro Center, Suite 1100 Bethesda, MD 20814-5372	301/657-3110
NEI	National Elevator Industry 185 Bridge Plaza North, Suite 310 Fort Lee, NJ 07024	201/944-3211
NEMA	National Electrical Manufacturers' Association 1300 N. 17 <sup>th</sup> Street, Suite 1847 Rosslyn, VA 22209 <a href="http://www.nema.org">www.nema.org</a>	703/841-3200
NFPA	National Fire Protection Association One Batterymarch Park P.O. Box 9101 Quincy, MA 02269-9101 <a href="http://www.nfpa.org">www.nfpa.org</a>	800/344-3555 617/770-3000
NHLA	National Hardwood Lumber Association	901/377-1818

P.O. Box 34518  
Memphis, TN 38184-0518  
[www.natlhardwood.org](http://www.natlhardwood.org)

NIA	National Insulation Association 99 Canal Center Plaza, Suite 222 Alexandria, VA 22314 <a href="http://www.insulation.org">www.insulation.org</a>	703/683-6422
NPA	National Particleboard Association 18928 Premiere Court Gaithersburg, MD 20879-1569 <a href="http://www.pbmdf.com">www.pbmdf.com</a>	301/670-0604
NPCA	National Paint and Coatings Association 1500 Rhode Island Avenue, NW Washington, DC 20005-5597 <a href="http://www.paint.org">www.paint.org</a>	202/462-6272
NRCA	National Roofing Contractors Association O'Hare International Center 10255 W. Higgins Road, Suite 600 Rosemont, IL 60018-5607 <a href="http://www.roofonline.org">www.roofonline.org</a>	800/323-9545
NRMCA	National Ready Mixed Concrete Association 900 Spring Street Silver Spring, MD 20910 <a href="http://www.nrmca.org">www.nrmca.org</a>	301/587-1400
NSF	NSF International P.O. Box 130140 Ann Arbor, MI 48113-0140 <a href="http://www.nsf.org">www.nsf.org</a>	313/769-8010
NUSIG	National Uniform Seismic Installation Guidelines 12 Lahoma Court Alamo, CA 94526	510/946-0135
NWWDA	National Wood Window and Door Association 1400 E. Touhy Avenue, G-54 847/299-5200 Des Plaines, IL 60018 <a href="http://www.nwwda.org">www.nwwda.org</a>	800/223-2301

SHA	Occupational Safety and Health Administration (U.S. Department of Labor) 200 Constitution Ave., NW Washington, DC 20210	202/219-8148
PCA	Portland Cement Association 5420 Old Orchard Road Skokie, IL 60077-1083 <a href="http://www.portcement.org">www.portcement.org</a>	847/966-6200
PDCA	Painting and Decorating Contractors of America 3913 Old Lee Hwy, Suite 33-B Fairfax, VA 22030 <a href="http://www.pdca.com">www.pdca.com</a>	800/332-7322 703/359-0826
PDI	Plumbing and Drainage Institute 45 Bristol Drive, Suite 101 South Easton, MA 02375	800/589-8956 508/230-3516
RFCI	Resilient Floor Covering Institute 966 Hungerford Drive, Suite 12-B Rockville, MD 20805-1714	301/340-8580
RIS	Redwood Inspection Service c/o California Redwood Association 405 Enfrente Drive, Suite 200 Novato, CA 94949-7206	415/382-0662
SDI	Steel Deck Institute P.O. Box 25 Fox River Grove, IL 60012 <a href="http://www.sdi.org">www.sdi.org</a>	847/462-1930
SDI	Steel Door Institute 30200 Detroit Road Cleveland, OH 44145-1967	216/889-0010
SMA	Stucco Manufacturers Association 14006 Ventura Blvd. Sherman Oaks, CA 91403	213/789-8733
SMACNA	Sheet Metal and Airconditioning Contractors National Association, Inc.	703/803-2980

P.O. Box 221230  
Chantilly, VA 20151-1209  
[www.smacna.org](http://www.smacna.org)

SPI	Society of the Plastics Industry, Inc. Spray Polyurethane Division 202/974-5200 1801 K Street, NW, Suite 600K Washington, DC 20006 <a href="http://www.socplas.org">www.socplas.org</a>	800/951-2001
SSPC	Steel Structures Painting Council 40 24th Street, 6th Floor Pittsburgh, PA 15222-4643	412/281-2331
TCA	Tile Council of America 100 Clemson Research Blvd. Anderson, SC 29625	864/646-8453
TPI	Turfgrass Producers International 1855-A Hicks Road Rolling Meadows, IL 60008	800/405-8873 847/705-9898
UL	Underwriters Laboratories, Inc. 333 Pfingston Road 847/272-8800 Northbrook, IL 60062 <a href="http://www.ul.com">www.ul.com</a>	800/704-4050
UNI	Uni-Bell PVC Pipe Association 2655 Villa Creek Drive, Suite 155 Dallas, TX 75234 <a href="http://www.members.aol.com/unibell1">www.members.aol.com/unibell1</a>	972/243-3902
USDA	U.S. Department of Agriculture 14th St. and Independence Ave., SW Washington, DC 20250	202/720-8732
WA	Wallcoverings Association 401 N. Michigan Avenue Chicago, IL 60611-4267	312/644-6610
WCLIB	West Coast Lumber Inspection Bureau P.O. Box 23145 Portland, OR 97281-3145	503/639-0651

WCMA	Window Covering Manufacturers Association 355 Lexington Ave., 17th Floor New York, NY 10017-6603	212/661-4261
WIC	Woodwork Institute of California P.O. Box 980247 West Sacramento, CA 95798-0247	916/372-9943
WLPDIA	Western Lath/Plaster/Drywall Industries Association 8635 Navajo Road San Diego, CA 92119	619/466-9070
WMMPA	Wood Moulding & Millwork Producers Association 507 First Street Woodland, CA 95695 <a href="http://www.wmmpa.com">www.wmmpa.com</a>	800/550-7889 916/661-9591
WRI	Wire Reinforcement Institute 203 Loudoun Street, SW Leesburg, VA 20175-2718	703/779-2339
WWPA	Western Wood Products Association Yeon Building 522 S.W. 5th Avenue Portland, OR 97204-2122	503/224-3930

END OF DOCUMENT

DOCUMENT 01 43 00

**QUALITY ASSURANCE - MATERIALS AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Purchase of Materials and Equipment;
- B. Special Conditions;
- C. Imported Materials Certification.

**1.02 MATERIAL AND EQUIPMENT**

- A. Only items approved by the County and/or Architect shall be used.
- B. Contractor shall submit lists of products and other product information in accordance with the Contract Documents, including, without limitation, the provisions regarding the submittals.

**1.03 MATERIAL AND EQUIPMENT COLORS**

- A. The County and/or Architect will provide a schedule of colors.
- B. No individual color selections will be made until after approval of all pertinent materials and equipment and after receipt of appropriate samples in accordance with the Contract Documents, including, without limitation, the provisions regarding the submittals.
- C. Contractor shall request priority in writing for any item requiring advance ordering to maintain the approved Construction Schedule.

**1.04 DELIVERY, STORAGE, AND HANDLING**

- A. Contractor shall deliver manufactured materials in original packages, containers, or bundles (with seals unbroken), bearing name or identification mark of manufacturer.

- B. Contractor shall deliver fabrications in as large assemblies as practicable; where specified as shop-primed or shop-finished, package or crate as required to preserve such priming or finish intact and free from abrasion.
- C. Contractor shall store materials in such a manner as necessary to properly protect them from damage. Materials or equipment damaged by handling, weather, dirt, or from any other cause will not be accepted.
- D. Materials are not be acceptable that have been warehoused for long periods of time, stored or transported in improper environment, improperly packaged, inadequately labeled, poorly protected, excessively shipped, deviated from normal distribution pattern, or reassembled.
- E. Contractor shall store material so as to cause no obstructions of sidewalks, roadways, and underground services. Contractor shall protect material and equipment furnished under Contract.
- F. Contractor may store materials on Site with prior written approval by the County, all material shall remain under Contractor's control and Contractor shall remain liable for any damage to the materials. Should the Project Site not have storage area available, the Contractor shall provide for off-site storage at no cost to County.
- G. When any room in Project is used as a shop or storeroom, the Contractor shall be responsible for any repairs, patching, or cleaning necessary due to that use. Location of storage space shall be subject to prior written approval by County.

## **PART 2 - PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Manufacturers listed in various sections of Contract Documents are names of those manufacturers that are believed to be capable of supplying one or more of items specified therein.
- B. The listing of a manufacturer does not imply that every product of that manufacturer is acceptable as meeting the requirements of the Contract Documents.

### **2.02 FACILITIES AND EQUIPMENT**

- A. Contractor shall provide, install, maintain, and operate a complete and adequate facility for handling, the execution, disposal, and distribution of material and

equipment as required for proper and timely performance of Work connected with Contract.

### **2.03 MATERIAL REFERENCE STANDARDS**

- A. Where material is specified solely by reference to “standard specifications” and if requested by County, Contractor shall submit for review data on actual material proposed to be incorporated into Work of Contract listing name and address of vendor, manufacturer, or producer, and trade or brand names of those materials, and data substantiating compliance with standard specifications.

## **PART 3 - EXECUTION**

### **3.01 WORKMANSHIP**

- A. Where not more specifically described in any other Contract Documents, workmanship shall conform to methods and operations of best standards and accepted practices of trade or trades involved and shall include items of fabrication, construction, or installation regularly furnished or required for completion (including finish and for successful operation, as intended).
- B. Work shall be executed by tradespersons skilled in their respective lines of Work. When completed, parts shall have been durably and substantially built and present a neat appearance.

### **3.02 COORDINATION**

- A. Contractor shall coordinate installation of Work so as to not interfere with installation of others. Adjustment or rework because of Contractor’s failure to coordinate will be at no additional cost to County.
- B. Contractor shall examine in-place work for readiness, completeness, fitness to be concealed or to receive other work, and in compliance with Contract Documents. Concealing or covering Work constitutes acceptance of additional cost which will result should in-place Work be found unsuitable for receiving other Work or otherwise deviating from the requirements of the Contract Documents.

### **3.03 COMPLETENESS**

- A. Contractor shall provide all portions of the Work, unless clearly stated otherwise, installed complete and operational with all elements, accessories, anchorages, utility connections, etc., in manner to assure well-balanced performance, in accordance with manufacturer's recommendations and by Contract Documents. For example, electric water coolers require water, electricity, and drain services;



roof drains require drain system; sinks fit within countertop, etc. Terms such as "installed complete," "operable condition," "for use intended," "connected to all utilities," "terminate with proper cap," "adequately anchored," "patch and refinish," "to match similar," should be assumed to apply in all cases, except where completeness of functional or operable condition is specifically stated as not required.

### **3.04 APPROVED INSTALLER OR APPLICATOR**

- A. Installation by a manufacturer's approved installer or applicator is an understood part of Specifications and only approved installer or applicator is to provide on-site Work where specified manufacturer has on-going program of approving (i.e. certifying, bonding, re-warranting) installers or applicators. Newly established relationships between a manufacturer and an installer or applicator that does not have other approved applicator work in progress or completed is not approved for this Project.

### **3.05 MANUFACTURER'S RECOMMENDATIONS**

- A. All installations shall be in accordance with manufacturer's published recommendations and specific written directions of manufacturer's representative. Should Contract Documents differ from recommendations of manufacturer or directions of his representative, Contractor shall analyze differences, make recommendations to the County and the Architect in writing, and shall not proceed until interpretation or clarification has been issued by the County and/or the Architect.

END OF DOCUMENT

DOCUMENT 01 45 00

**QUALITY CONTROL**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Inspections and Tests, Uncovering of Work and Non-conforming of Work and Correction of Work;
- B. Special Conditions.

**1.02 RELATED CODES:**

- A. The Work is governed by requirements of Title 24, California Code of Regulations ("CCR"), and the Contractor shall keep a copy of these available at the job Site for ready reference during construction.

**1.03 OBSERVATION AND SUPERVISION:**

The County and Architect or their appointed representatives will review the Work and the Contractor shall provide facilities and access to the Work at all times as required to facilitate this review. Administration by the Architect and any consulting Structural Engineer will be in accordance with applicable regulations.

**1.04 TESTING AGENCIES:**

- A. Testing agencies and tests shall be in conformance with the General Documents. .
- B. Testing and inspection in connection with earthwork shall be under the direction of the County's consulting soils engineer, if any, referred to hereinafter as the "Soils Engineer."
- C. Testing and inspection of construction materials and workmanship shall be performed by a qualified laboratory, referred to hereinafter as the "Testing Laboratory." The Testing Laboratory shall be under direction of an engineer registered in the State of California, shall conform to requirements of ASTM E329, and shall be employed by or in contract with the County.

**1.05 TESTS AND INSPECTIONS:**

- A. The Contractor shall be responsible for notifying the Construction Manager of all required tests and inspections. Contractor shall notify the Construction Manager forty-eight (48) hours in advance of performing any Work requiring testing or inspection.
- B. The Contractor shall provide access to Work to be tested and furnish incidental labor, equipment, and facilities to facilitate all inspections and tests.
- C. The County will pay for first inspections and tests required by the “CCR”, and other inspections or tests that the County and/or the Architect may direct to have made, including the following principal items:
  - (1) Tests and observations for earthwork and paving.
  - (2) Tests for concrete mix designs, including tests of trial batches.
  - (3) Tests and inspections for structural steel work.
  - (4) Field tests for framing lumber moisture content.
  - (5) Additional tests directed by the County that establish that materials and installation comply with the Contract Documents.
  - (6) Test and observation of welding and expansion anchors.
- D. The County may at its discretion, pay and back charge the Contractor for:
  - (1) Retests or reinspections, if required, and tests or inspections required due to Contractor error or lack of required identifications of material.
  - (2) Uncovering of work in accordance with Contract Documents.
  - (3) Testing done on weekends, holidays, and overtime will be chargeable to the Contractor for the overtime portion.
  - (4) Testing done off Site.
- E. Testing and inspection reports and certifications:

- (1) If initially received by Contractor, Contractor shall provide to each of the following a copy of the agency or laboratory report of each test or inspection or certification.
  - a. The County;
  - b. The Construction Manager, if any;
  - c. The Architect;
  - d. The Consulting Engineer, if any;
  - e. Other Engineers on the Project, as appropriate; and
  - f. The Contractor.

## **PART 2 - PRODUCTS**

### **2.01 TYPE OF TEST AND INSPECTIONS (As Applies to each Task Order, if needed):**

#### **THE FOLLOWING ARE EXAMPLES ONLY**

- A. Slump Test  
ASTM C 143
- B. Concrete Tests  
Testing agency shall test concrete used in the work per the following paragraphs:
  - (1) Compressive Strength:
    - a. Minimum number of tests required: One (1) set of three (3) cylinders for each 100 cubic yards (Sec. 2604(h) 01) of concrete or major fraction thereof, placed in one (1) day. See Title 24, Section 2605(g).
    - b. Two cylinders of each set shall be tested at twenty-eight (28) days. One (1) cylinder shall be held in reserve and tested only when directed by the Architect or County.
    - c. Concrete shall test the minimum ultimate compressive strength in 28 days, as specified on the structural drawings.

- d. In the event that the twenty-eight (28) day test falls below the minimum specified strength, the effective concrete in place shall be tested by taking cores in accordance with UBC Standard No. 26-13 and tested as required for cylinders.
  - e. In the event that the test on core specimens falls below the minimum specified strength, the concrete will be deemed defective and shall be removed and replaced upon such direction of the Architect.
- C. Reinforcing, Steel
- D. Structural Steel Per Title 24 and as noted:
  - (1) Material: Steel per Table in Title 24, Section 2712.
  - (2) Qualification of Welders (UBC Std. 27-6).
  - (3) Shop fabrication (Section 2712(d). Structural steel only).
  - (4) Shop and field welding (Section 2712(e)).

END OF DOCUMENT

DOCUMENT 01 50 00

**TEMPORARY FACILITIES AND CONTROLS**

**PART 1 – GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions
- B. Special Conditions
- C. Site Standards

**1.02 TEMPORARY UTILITIES:**

- A. Electric Power and Lighting
  - (1) The County will furnish and pay for power during the course of the work to the extent power is available in the building(s) or on the Site. The Contractor shall be responsible for providing temporary facilities required to deliver that power service from its existing location in the building(s) or on the Site to point of intended use.
  - (2) Contractor shall verify characteristics of power available in building(s) or on the Site. Contractor shall take all actions required to make modifications where power of higher voltage or different phases of current are required. Contractor shall be fully responsible for providing that service and shall pay all costs required therefor.
  - (3) The Contractor shall furnish, wire for, install, and maintain temporary electrical lights wherever it is necessary to provide illumination for the proper performance and/or observation of the Work: a minimum of 20 foot-candles for rough work and 50 foot-candles for finish work.
- B. Heat and Ventilation
  - (1) Contractor shall provide temporary heat to maintain environmental conditions to facilitate progress of the Work, to meet specified minimum conditions for the installation and curing of materials, and to protect materials and finishes from damage due to improper temperature and

humidity conditions. Portable heaters shall be standard units complete with controls.

- (2) Contractor shall provide forced ventilation and dehumidification, as required, of enclosed areas for proper installation and curing of materials, to disperse humidity, and to prevent hazardous accumulations of dust, fumes, vapors, and gases.
- (3) Contractor shall pay the costs of installation, maintenance, operation, and removal of temporary heat and ventilation, including costs for fuel consumed, required for the performance of the Work.

**C. Water**

- (1) The County will furnish and pay for water during the course of the work to the extent water is then available in the building(s) or on the Site. The Contractor shall be responsible for providing temporary facilities required to deliver such utility service from its existing location in the building(s) or on the Site to point of intended use.
- (2) Contractor shall use backflow preventers on water lines at point of connection to County's water supply. Backflow preventers shall comply with requirements of Uniform Plumbing Code.
- (3) Contractor shall make potable water available for human consumption.

**D. Sanitary Facilities**

- (1) Contractor shall provide sanitary temporary facilities in no fewer numbers than required by law and such additional facilities as may be directed by the County for the use of all workers. The facilities shall be maintained in a sanitary condition at all times and shall be left at the Site until removal is directed by the County or Contractor completes all other work at the Site.
- (2) Use of toilet facilities in the Work under construction shall not be permitted except by consent of the County.

**E. Telephone Service**

- (1) Contractor shall arrange with local telephone service company for telephone service for the performance of the Work. Contractor shall, at a minimum, provide in its field office one line for telephone and one line for fax machine.

- (2) Contractor shall pay the costs for telephone and fax lines installation, maintenance, service, and removal.

F. Fire Protection:

- (1) Contractor shall provide and maintain fire extinguishers and other equipment for fire protection. Such equipment shall be designated for use for fire protection only and shall comply with all requirements of the California Fire, State Fire Marshall and/or its designee.
- (2) Where on-site welding and burning of steel is unavoidable, Contractor shall provide protection for adjacent surfaces.

G. Trash Removal:

- (1) See Document 01 74 19

**1.03 CONSTRUCTION AIDS:**

A. Plant and Equipment:

- (1) Contractor shall furnish, operate, and maintain a complete plant for fabricating, handling, conveying, installing, and erecting materials and equipment; and for conveyances for transporting workmen. Include elevators, hoists, debris chutes, and other equipment, tools, and appliances necessary for performance of the Work.
- (2) Contractor shall maintain plant and equipment in safe and efficient operating condition. Damages due to defective plant and equipment, and uses made thereof, shall be repaired by Contractor at no expense to the County.

B. None of the County's tools and equipment shall be used by Contractor for the performance of the Work

**1.04 BARRIERS AND ENCLOSURES:**

- A. Contractor shall obtain the County's written permission for locations and types of temporary barriers and enclosures, including fire-rated materials proposed for use, prior to their installation.
- B. Contractor shall provide and maintain temporary enclosures to prevent public entry and to protect persons using other buildings and portions of the Site and/or Premises, the public, and workers. Contractor shall also protect the Work and



existing facilities from the elements, and adjacent construction and improvements, persons, and trees and plants from damage and injury from demolition and construction operations.

- C. Contractor shall provide site access to existing facilities for persons using other buildings and portions of the Site, the public, and for deliveries and other services and activities.
- D. Tree and Plant Protection:
  - (1) Contractor shall preserve and protect existing trees and plants on the Premises that are not designated or required to be removed, and those adjacent to the Premises.
  - (2) Contractor shall provide barriers to a minimum height of 4'-0" around drip line of each tree and plant, around each group of trees and plants, as applicable, in the proximity of demolition and construction operations.
  - (3) Contractor shall not park trucks, store materials, perform Work or cross over landscaped areas. Contractor shall not dispose of paint thinners, water from cleaning, plastering or concrete operations, or other deleterious materials in landscaped areas, storm drain systems, or sewers. Plant materials damaged as a result of the performance of the Work shall, at the option of the County and at Contractor's expense, either be replaced with new plant materials equal in size to those damaged or by payment of an amount representing the value of the damaged materials as determined by the County.
  - (4) Contractor shall remove soil that has been contaminated during the performance of the Work by oil, solvents, and other materials which could be harmful to trees and plants, and replace with good soil, at Contractor's expense
  - (5) Excavation Around Trees:
    - (a) Excavation within drip lines of trees shall be done only where absolutely necessary and with written permission from the County.
    - (b) Where trenching for utilities is required within drip lines, tunneling under and around roots shall be by hand digging and shall be approved by the County. Main lateral roots and taproots shall not be cut. All roots 2 inches in diameter and larger shall be tunneled under and heavily wrapped with wet burlap so as to prevent scarring or excessive drying. Smaller roots that interfere with

installation of new work may be cut with prior approval by the County. Roots must first be cut with a Vermeer, or equivalent, root cutter prior to any trenching.

- (c) Where excavation for new construction is required within drip line of trees, hand excavation shall be employed to minimize damage to root system. Roots shall be relocated in backfill areas wherever possible. If encountered immediately adjacent to location of new construction, roots shall be cut approximately 6 inches back from new construction.
- (d) Approved excavations shall be carefully backfilled with the excavated materials approved for backfilling. Backfill shall conform to adjacent grades without dips, sunken areas, humps, or other surface irregularities. Do not use mechanical equipment to compact backfill. Tamp carefully using hand tools, refilling and tamping until Final Acceptance as necessary to offset settlement.
- (e) Exposed roots shall not be allowed to dry out before permanent backfill is placed. Temporary earth cover shall be provided, or roots shall be wrapped with four layers of wet, untreated burlap and temporarily supported and protected from damage until permanently relocated and covered with backfill.
- (f) Accidentally broken roots should be sawed cleanly 3 inches behind ragged end.

**1.05 SECURITY AND PARKING:**

- A. The Contractor shall be responsible for project security for materials, tools, equipment, supplies, and completed and partially completed Work.
- B. Contractor is responsible for any charges associated with parking of Contractor and Contractor employee's vehicles either at County facilities or off-site. Unless otherwise stated, all parking at County facilities requires payment.

**1.06 TEMPORARY CONTROLS:**

- A. Noise Control
  - (1) Contractor acknowledge, that adjacent facilities may remain in operation during all or a portion of the Work period, and it shall take all reasonable precautions to minimize noise as required by applicable laws and the Contract Documents.

- (2) Notice of proposed noisy operations, including without limitation, operation of pneumatic demolition tools, concrete saws, and other equipment, shall be submitted to the County a minimum of forty-eight (48) hours in advance of their performance.

**B. Noise and Vibration**

- (1) Equipment and impact tools shall have intake and exhaust mufflers.
- (2) Contractor shall cooperate with County to minimize and/or seize the use of noisy and vibratory equipment if that equipment becomes objectionable by its longevity.

**C. Dust and Dirt**

- (1) Contractor shall conduct demolition and construction operations to minimize the generation of dust and dirt, and prevent dust and dirt from interfering with the progress of the Work and from accumulating in the Work and adjacent areas including, without limitation, occupied facilities.
- (2) Contractor shall periodically water exterior demolition and construction areas to minimize the generation of dust and dirt.
- (3) Contractor shall ensure that all hauling equipment and trucks carrying loads of soil and debris shall have their loads sprayed with water or covered with tarpaulins, and as otherwise required by local and state ordinance.
- (4) Contractor shall prevent dust and dirt from accumulating on walks, roadways, parking areas, and planting, and from washing into sewer and storm drain lines.

**D. Water**

Contractor shall not permit surface and subsurface water, and other liquids, to accumulate in or about the vicinity of the Premises. Should accumulation develop, Contractor shall control the water or other liquid, and suitably dispose of it by means of temporary pumps, piping, drainage lines, troughs, ditches, dams, or other methods.

**E. Pollution**

- (1) No burning of refuse, debris, or other materials shall be permitted on or in the vicinity of the Premises.
  - (2) Contractor shall comply with applicable regulatory requirements and anti-pollution ordinances during the conduct of the Work including, without limitation, demolition, construction, and disposal operations.
- F. Lighting:
- (1) If portable lights are used after dark, all light must be located so as not to direct light into neighboring property.

**1.07 JOB SIGN(S):**

- A. General:
- (1) If required, contractor shall provide and maintain a Project identification sign with the design, text, and colors designated by the County and/or the Architect; locate sign as approved by the County.
  - (2) Signs other than the specified Project sign and or signs required by law, for safety, or for egress, shall not be permitted, unless otherwise approved in advance by the County.
- B. Materials:
- (1) Structure and Framing: Structurally sound, new or used wood or metal; wood shall be nominal 3/4-inch exterior grade plywood.
  - (2) Sign Surface: Minimum 3/4-inch exterior grade plywood.
  - (3) Rough Hardware: Galvanized.
  - (4) Paint: Exterior quality, of type and colors selected by the County and/or the Architect.
- C. Fabrication:
- (1) Contractor shall fabricate to provide smooth, even surface for painting.
  - (2) Size: 4'-0" x 8'-0", unless otherwise indicated.
  - (3) Contractor shall paint exposed surfaces of supports, framing, and surface material with exterior grade paint: one coat of primer and one coat of finish paint.

(4) Text and Graphics: As indicated.

**1.08 PUBLICITY RELEASES:**

- A. Contractor shall not release any information, story, photograph, plan, or drawing relating information about the Project to anyone, including press and other public communications medium, including, without limitation, on website(s).

END OF DOCUMENT

DOCUMENT 01 62 00

**PRODUCT OPTIONS AND SUBSTITUTIONS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. Instructions to Bidders;
- B. General Conditions, including, without limitation, Substitutions For Specified Items;
- C. Special Conditions.
- D. LEED™ Requirements Document 01 35 13.23

**1.02 SUBSTITUTIONS OF MATERIALS AND EQUIPMENT:**

- A. Catalog numbers and specific brands or trade names followed by the designation "or equal" are used in conjunction with material and equipment required by the Specifications to establish the standards of quality, utility, and appearance required. Substitutions which are equal in quality, utility, and appearance to those specified may be reviewed subject to the provisions of the General Conditions.
- B. Wherever more than one manufacturer's product is specified, the first-named product is the basis for the design used in the work and the use of alternative-named manufacturers' products or substitutes may require modifications in that design. If such alternatives are proposed by Contractor and are approved by the County and/or the Architect, Contractor shall assume all costs required to make necessary revisions and modifications of the design resulting from the substitutions requested by the Contractor.
- C. When materials and equipment are specified by first manufacturer's name and product number, second manufacturer's name and "or approved equal," supporting data for the second product, if proposed by Contractor, shall be submitted in accordance with the requirements for substitutions.
- D. If the County and/or Architect, in reviewing proposed substitute materials and equipment, require revisions or corrections to be made to previously accepted Shop Drawings and supplemental supporting data to be resubmitted, Contractor

shall promptly do so. If any proposed substitution is judged by the County and/or Architect to be unacceptable, the specified material or equipment shall be provided.

- E. Samples may be required. Tests required by the County and/or Architect for the determination of quality and utility shall be made at the expense of Contractor, with acceptance of the test procedure first given by the County.
- F. In reviewing the supporting data submitted for substitutions, the County and/or Architect will use for purposes of comparison all the characteristics of the specified material or equipment as they appear in the manufacturer's published data even though all the characteristics may not have been particularly mentioned in the Contract Documents. If more than two (2) submissions of supporting data are required, the cost of reviewing the additional supporting data shall be borne by Contractor, and the County will deduct the costs from the Contract Price.

**END OF DOCUMENT**

DOCUMENT 01 65 00

**DELIVERY, STORAGE AND HANDLING**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Site Access, Conditions and Requirements;
- B. Special Conditions.

**1.02 PRODUCTS**

- A. Products are as defined in the General Conditions.
- B. Contractor shall not use and/or reuse materials and/or equipment removed from existing Premises, except as specifically permitted by the Contract Documents.
- C. Contractor shall provide interchangeable components of the same manufacturer, for similar components.

**1.03 TRANSPORTATION AND HANDLING**

- A. Contractor shall transport and handle Products in accordance with manufacturer's instructions.
- B. Contractor shall promptly inspect shipments to confirm that Products comply with requirements, quantities are correct, and products are undamaged.
- C. Contractor shall provide equipment and personnel to handle Products by methods to prevent soiling, disfigurement, or damage.

**1.04 STORAGE AND PROTECTION**

- A. Contractor shall store and protect Products in accordance with manufacturer's instructions, with seals and labels intact and legible. Contractor shall store sensitive products in weather-tight, climate controlled enclosures.



- B. For exterior storage of fabricated Products, Contractor shall place on sloped supports, above ground.
- C. Contractor shall provide off-site storage and protection when Site does not permit on-site storage or protection.
- D. Contractor shall cover products subject to deterioration with impervious sheet covering and provide ventilation to avoid condensation.
- E. Contractor shall store loose granular materials on solid flat surfaces in a well-drained area and prevent mixing with foreign matter.
- F. Contractor shall provide equipment and personnel to store Products by methods to prevent soiling, disfigurement, or damage.
- G. Contractor shall arrange storage of Products to permit access for inspection and periodically inspect to assure Products are undamaged and are maintained under specified conditions.

**END OF DOCUMENT**

DOCUMENT 01 71 23

**FIELD ENGINEERING**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Site Investigation, and Soils Investigation Report;
- B. Special Conditions;
- C. Site-Visit Certification.

**1.02 REQUIREMENTS INCLUDED:**

- A. Contractor shall provide and pay for field engineering services by a California-registered engineer, required for the project, including, without limitations:
  - (1) Survey work required in execution of the Project.
  - (2) Civil or other professional engineering services specified, or required to execute Contractor's construction methods.

**1.03 QUALIFICATIONS OF SURVEYOR OR ENGINEERS:**

- A. Contractor shall only use a qualified licensed engineer or registered land surveyor, to whom County makes no objection.

**1.04 SURVEY REFERENCE POINTS:**

- A. Existing basic horizontal and vertical control points for the Project are those designated on the Drawings.
- B. Contractor shall locate and protect control points prior to starting Site Work and preserve all permanent reference points during construction. In addition Contractor shall:
  - (1) Make no changes or relocation without prior written notice to County and Architect.

- (2) Report to County and Architect when any reference point is lost or destroyed, or requires relocation because of necessary changes in grades or locations.
- (3) Require surveyor to replace Project control points based on original survey control that may be lost or destroyed.

**1.05 RECORDS:**

- A. Contractor shall maintain a complete, accurate log of all control and survey work as it progresses.

**1.06 SUBMITTALS:**

- A. Contractor shall submit name and address of Surveyor and Professional Engineer to County and Architect prior to its/their work on the Project.
- B. On request of County and Architect, Contractor shall submit documentation to verify accuracy of field engineering work, at no additional cost to the County.
- C. Contractor shall submit a certificate signed by registered engineer or surveyor certifying that elevations and locations of improvements are in conformance or nonconformance with Contract Documents.

**PART 2 – PRODUCTS**

Not Used.

**PART 3 - EXECUTION**

- 3.01 Contractor is responsible for meeting all applicable codes, OSHA, safety and shoring requirements.
- 3.02 Contractor is responsible for any re-surveying required by correction of nonconforming work.

END OF DOCUMENT

DOCUMENT 01 73 29

**CUTTING AND PATCHING**

**1. PART 1 – GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions;
- B. Special Conditions;
- C. Hazardous Materials Procedures and Requirements;
- D. Hazardous Materials Certification;
- E. Imported Materials Certification.

**1.02 CUTTING AND PATCHING:**

- A. Contractor shall be responsible for all cutting, fitting, and patching, including associated excavation and backfill, required to complete the Work or to:
  - (1) Make several parts fit together properly.
  - (2) Uncover portions of Work to provide for installation of ill-timed Work.
  - (3) Remove and replace defective Work.
  - (4) Remove and replace Work not conforming to requirements of Contract Documents.
  - (5) Remove Samples of installed Work as specified for testing.
  - (6) Provide routine penetrations of non-structural surfaces for installation of piping and electrical conduit.
  - (7) Attach new materials to existing remodeling areas, including painting (or other finishes) to match existing conditions.

- B. In addition to Contract requirements, upon written instructions from the County, Contractor shall uncover Work to provide for observations of covered Work in accordance with the Contract Documents; remove samples of installed materials for testing as directed by County; and remove Work to provide for alteration of existing Work.
- C. Contractor shall not cut or alter Work, or any part of it, in such a way that endangers or compromises the integrity of the Work, the Project, or work of others.

**1.03 SUBMITTALS:**

- A. Prior to any cutting or alterations that may affect the structural safety of Project, or work of others, and well in advance of executing such cutting or alterations, Contractor shall submit written notice to County pursuant to the applicable notice provisions of the Contract Documents, requesting consent to proceed with the cutting or alteration, including the following:
  - (1) The Work of the County or other trades.
  - (2) Structural value or integrity of any element of Project.
  - (3) Integrity or effectiveness of weather-exposed or weather-resistant elements or systems.
  - (4) Efficiency, operational life, maintenance or safety of operational elements.
  - (5) Visual qualities of sight-exposed elements.
- B. Contractor's Request shall also include:
  - (1) Identification of Project.
  - (2) Description of affected Work.
  - (3) Necessity for cutting, alteration, or excavations.
  - (4) Effects of Work on County, other trades, or structural or weatherproof integrity of Project.
  - (5) Description of proposed Work:

- (a) Scope of cutting, patching, alteration, or excavation.
- (b) Trades that will execute Work.
- (c) Products proposed to be used.
- (d) Extent of refinishing to be done.
- (6) Alternates to cutting and patching.
- (7) Cost proposal, when applicable.
- (8) The scheduled date the Contractor intends to perform the Work and the duration of time to complete the Work.
- (9) Written permission of other trades whose Work will be affected.

**1.04 QUALITY ASSURANCE:**

- A. Contractor shall ensure that cutting, fitting, and patching shall achieve security, strength, weather protection, appearance for aesthetic match, efficiency, operational life, maintenance, safety of operational elements, and the continuity of existing fire ratings.
- B. Contractor shall ensure that cutting, fitting, and patching shall successfully duplicate undisturbed adjacent profiles, materials, textures, finishes, colors, and that materials shall match existing construction. Where there is dispute as to whether duplication is successful or has been achieved to a reasonable degree, the County's decision shall be final.

**1.05 PAYMENT FOR COSTS:**

- A. Cost caused by ill-timed or defective Work or Work not conforming to Contract Documents, including costs for additional services of the County, its consultants, including but not limited to the Construction Manager, the Architect, the Project Inspector(s), Engineers, and Agents, will be paid by Contractor and/or deducted from the Contract by the County.
- B. County shall only pay for cost of Work if it is part of the original Contract Price or if a change has been made to the contract in compliance with the provisions of the General Conditions. Cost of Work performed upon instructions from the County, other than defective or nonconforming Work, will be paid by County on approval

of written Change Order. Contractor shall provide written cost proposals prior to proceeding with cutting and patching.

## **PART 2 - PRODUCTS**

### **2.01 MATERIALS:**

- A. Contractor shall provide for replacement and restoration of Work removed. Contractor shall comply with the Contract Documents and with the Industry Standard(s), for the type of Work, and the Specification requirements for each specific product involved. If not specified, Contractor shall first recommend a product of a manufacturer or appropriate trade association for approval by the County.
- B. Materials to be cut and patched include those damaged by the performance of the Work.

## **PART 3 – EXECUTION**

### **3.01 INSPECTION:**

- A. Contractor shall inspect existing conditions of the Site and the Work, including elements subject to movement or damage during cutting and patching, excavating and backfilling. After uncovering Work, Contractor shall inspect conditions affecting installation of new products.
- B. Contractor shall report unsatisfactory or questionable conditions in writing to County as indicated in the General Conditions and shall proceed with Work as indicated in the General Conditions by County.

### **3.02 PREPARATION:**

- A. Contractor shall provide shoring, bracing and supports as required to maintain structural integrity for all portions of the Project, including all requirements of the Project.
- B. Contractor shall provide devices and methods to protect other portions of Project from damage.
- C. Contractor shall, provide all necessary protection from weather and extremes of temperature and humidity for the Project, including without limitation, any work that may be exposed by cutting and patching Work. Contractor shall keep excavations free from water.

**3.03 ERECTION, INSTALLATION AND APPLICATION:**

- A. With respect to performance, Contractor shall:
  - (1) Execute fitting and adjustment of products to provide finished installation to comply with and match specified tolerances and finishes.
  - (2) Execute cutting and demolition by methods that will prevent damage to other Work, and provide proper surfaces to receive installation of repairs and new Work.
  - (3) Execute cutting, demolition excavating, and backfilling by methods that will prevent damage to other Work and damage to settlement.
- B. Contractor shall employ original installer or fabricator to perform cutting and patching for:
  - (1) Weather-exposed surfaces and moisture-resistant elements such as roofing, sheet metal, sealants, waterproofing, and other trades.
  - (2) Sight-exposed finished surfaces.
- C. Contractor shall execute fitting and adjustment of products to provide a finished installation to comply with specified products, functions, tolerances, and finishes as shown or specified in the Contract Documents including, without limitation, the Drawings and Specifications.
- D. Contractor shall fit Work airtight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces. Contractor shall conform to all Code requirements for penetrations or the Drawings and Specifications, whichever calls for a higher quality or more thorough requirement. Contractor shall maintain integrity of both rated and non-rated fire walls, ceilings, floors, etc.
- E. Contractor shall restore Work which has been cut or removed. Contractor shall install new products to provide completed Work in accordance with requirements of the Contract Documents and as required to match surrounding areas and surfaces.
- F. Contractor shall refinish all continuous surfaces to nearest intersection as necessary to match the existing finish to any new finish.

**END OF DOCUMENT**





---

**DOCUMENT 01 74 19**  
**CONSTRUCTION WASTE MANAGEMENT**

---

**PART 1 – GENERAL**

**1.01 SUMMARY**

- A. This section specifies the requirements for the diversion of demolition (non-hazardous) and construction debris from landfill and submittal of the Waste Management Plan.
- B. Performance Requirement: Divert a minimum of 75% of construction and demolition (non-hazardous) debris from landfill. Diversion of 95% of the construction & demolition debris is the project goal.

**1.03 DEFINITIONS**

- A. "Conversion Rate" means the rate set forth in the standardized Conversion Rate Table approved by the County of Alameda for use in estimating the weight of materials identified in the Waste Management Plan and Waste Management Table.
- B. "Divert" means to use material for any purpose other than disposal in a landfill or transfer facility.
- C. "Good faith" shall be as defined by law.
- D. "Recycling Service" means an off-site service that provides processing of material and diversion from landfill.
- E. "Hauler" means the entity who transports construction and demolition debris to either a landfill or a recycling service.
- F. "Recycling Wizard" means an online database maintained by StopWaste.Org of approved recycling vendors that can be accessed at [www.StopWaste.Org](http://www.StopWaste.Org) or by calling 1-877-STOPWASTE.
- G. "Waste Management Plan or Plan" means a waste management plan required under this contract that is used to track and report the means of disposal of all construction debris generated on this project.
- H. "WasteTracking.com powered by Green Halo Systems" means the web based system required for use in developing a waste management plan, uploading recycling data throughout the construction process and submitting the final report demonstrating the project compliance online. More information about WasteTracking.com powered by Green Halo Systems is available by visiting them online at [www.wastetracking.com](http://www.wastetracking.com) or calling (888) 525-1301.

**1.04 QUALITY ASSURANCE**

- A. The Contractor shall obtain all special permits and licenses and meet all special requirements for performance and completion of the work of this section.

**B. Regulatory requirements**

1. Approval of the Waste Management Plan and Waste Management Table using the WasteTracking.com powered by Green Halo Systems by the Owner's Representative is required before beginning construction or demolition.
- C. Recycling service company qualifications – Submit certification for recycling services listed in the approved Waste Management Plan that accepted waste will be diverted from landfill. Certification shall be demonstrated in one of the following ways:
  1. Recycling service is listed in the Green Halo System as an approved recycler for Alameda County projects; or
  2. Recycling service is listed within Alameda County Waste Management Authority's Recycling Wizard, a Directory of where to recycle construction and demolition debris materials, or equivalent database/listing at StopWaste.Org. A database of construction and demolition recyclers can be found at [www.StopWaste.Org](http://www.StopWaste.Org) or can be obtained by calling 1-877-STOPWASTE; or.
  3. If not listed as described in items 1 and 2 above, submit certification in writing from any recycling services that verifies accepted waste will be diverted from landfill.

**1.05 SUBMITTALS**

- A. Submit specified Waste Management Plan to indicate how waste will be diverted from landfills. Plan to include procedures and schedule for debris disposal. Submittal shall be made using WasteTracking.com powered by Green Halo Systems using the following URL: [ACGSA.WasteTracking.com](http://ACGSA.WasteTracking.com). Submittal is required within 7 calendar days after receipt of Notice to Proceed; and
- B. Submit written documentation from recycling services that are not listed in the WasteTracking.com powered by Green Halo Systems or the Stopwaste.Org Recycling Wizard identifying where the construction and demolition material is taken, what method or process is being used to recycle the material, and identifying applicable state and local permits held by the recycling service provider and recycling facility; and
- C. Submit completed Waste Management Plan to report on the means of disposal of waste generated from project at the following project milestones:
  1. Fifty (50) percent progress payment; and
  2. One hundred (100) percent construction complete. County approval of final Waste Management Plan is required before full release of retention.

**1.06 WASTE MANAGEMENT PLAN**

- A. Plan Development: Using the website [ACGSA.WasteTracking.com](http://ACGSA.WasteTracking.com) develop a plan for diverting the specified percentage of construction debris from landfill. The plan shall include the following:
  1. Submit within 7-calendar days after receipt of Notice to Proceed.

2. Propose means and methods for collecting and separating each type of debris deemed reusable or recyclable.
3. Identify the off-site recycling service and hauler of each designated debris item, who has agreed to accept and divert that item from landfill, in the proposed quantities anticipated. Schedule each item and list off-site recycling service and hauler company name, telephone number, address, and person contacted.
4. Include a "good faith" estimate of each type of construction waste that would be generated if no diversion methods were implemented. Submit with calculations based upon weight or volume of each. The following items are subject to the "good faith" estimate and diversion requirement:
  - a. Asphalt & Concrete
  - b. Brick/Masonry/Tiles
  - c. Building Materials (doors, windows, fixtures, etc.)
  - d. Cardboard and other paper products
  - e. Carpet/Carpet Padding/Foam
  - f. Ceiling Tiles (acoustic)
  - g. Drywall
  - h. Electrical Components (light fixtures, cables, etc)
  - i. Film Plastic & Styrofoam Blocks
  - j. Landscape Debris (Plant & tree trimmings)
  - k. Mechanical Debris (ducts, controls, plumbing fixtures, etc)
  - l. Scrap Metal
  - m. Unpainted Wood and Pallets
  - n. Other (painted wood & drywall, roofing, etc)
  - o. Mixed C&D (defined as a mixture of three or more materials from construction or demolition sites that will be taken to a "qualified" facility for recycling.)
  - p. Trash/garbage
5. Construction waste quantities entered in volume will be converted automatically using the defined Conversion Rate approved by Alameda County that is integrated into WasteTracking.com powered by Green Halo Systems.

**B. Plan Implementation**

1. Contractor shall do all of the following:
  - a. Retain a copy of, and upload into WasteTracking.com powered by Green Halo Systems, all weight tickets, copies of receipts and invoices and any other documentation related to the reuse, recycling, and disposal of generated waste/debris from demolition and construction activities; and
  - b. Maintain a log of each load of each category item diverted from landfill. Log in separately debris sent to a Class III landfill and materials sent to recycling facilities.
    - 1) Include in log: type of load, load weight, name of hauling service, name of recycling service or landfill, and date accepted by recycling service or by landfill.

- 2) Owner reserves the right to audit the log at any time. Contractor shall retain and provide to the Owner all weight tickets, copies of receipts and invoices and any other documentation related to the disposal or recycling of generated waste/debris from demolition and construction activities.
    - c. Units of measure: Use same units as stated in the approved plan "good faith" estimate of construction waste that would be generated if no remedial methods were implemented.
2. Material handling
  - a. Separation facilities
    - 1) Designate a specific on site area or areas to facilitate separation of materials for potential reuse, salvage, recycling, and return.
    - 2) Keep waste bins and pile areas neat and clean. Clearly mark bins for each category of waste. Do not co-mingle non-recyclable waste with materials designated for reuse or recycling.
  - b. Environmental controls during handling, storage, or transport: Do not permit designated materials to become contaminated or to contaminate site or surrounding areas.
3. Training and coordination
  - a. Provide access and training as needed to subcontractors to the online construction and demolition debris waste management tool Green Halo Systems for the purposes of input of waste management information.
  - b. Furnish copies of the Waste Management Plan to all on-site supervisors, each subcontractor, and the Owner.
  - c. Instruction: Provide on-site instruction of appropriate separation, handling, and recycling, salvage, reuse, and return methods to be used by all entities at the appropriate stages of the Project.
  - d. Meetings: Include construction waste management on the agenda of meetings. At a minimum, discuss waste management goals and issues at the following meetings:
    - 1) Pre-bid meetings.
    - 2) Pre-construction meeting.
    - 3) Regularly scheduled job-site meetings.

## **PART 2 - PRODUCTS**

### **2.01 MATERIALS, EQUIPMENT AND FACILITIES**

Furnish all materials, tools, equipment, devices, appurtenances, facilities, and services required for performing waste management of debris covered under this Section.

**PART 3 - EXECUTION**

**3.01 EXAMINATION AND PREPARATION**

- A. Set up and maintain in good standing a project account with WasteTracking.com powered by Green Halo Systems using the website [ACGSA.WasteTracking.com](https://www.acgsa.wastetracking.com) to be used exclusively for this project to develop a waste management plan, upload all reuse, recycling and waste disposal data throughout the construction process and submit the final online report demonstrating project compliance.
- B. Perform as required in the approved Waste Management Plan.

**3.02 DISPOSAL OF DEBRIS**

- A. Dispose of waste, trash and debris in a safe, acceptable manner, in accordance with applicable laws and ordinances and as prescribed by authorities having jurisdiction. Burying of trash and debris on the site is prohibited.
- B. Remove demolished materials from site as work progresses. Remove debris from the site so that its presence will not delay the progress of the work.
- C. Debris shall be the property of the Contractor and shall be removed and disposed of in a legal manner off the County's property in accordance with the approved Waste Management Plan described herein. Location of recycling facility or dump and length of haul shall be the Contractor's responsibility.

**END OF DOCUMENT**

DOCUMENT 01 76 00

**PROTECTING INSTALLED CONSTRUCTION**

**PART 1 – GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions;
- B. Special Conditions.

**PART 2 - PRODUCTS**

**2.01 PRODUCTS FOR PATCHING AND EXTENDING WORK:**

- A. New Materials: As specified in the Contract Documents including, without limitation, in the Specifications, Contractor shall match existing products, conditions, and work for patching and extending work.
- B. Type and Quality of Existing Products: Contractor shall determine by inspection, by testing products where necessary, by referring to existing conditions and to the Work as a standard.

**PART 3 - EXECUTION**

**3.01 EXAMINATION:**

- A. Contractor shall verify that demolition is complete and that areas are ready for installation of new Work.
- B. By beginning restoration Work, Contractor acknowledges and accepts the existing conditions.

**3.02 PREPARATION:**

- A. Contractor shall cut, move, or remove items as necessary for access to alterations and renovation Work. Contractor shall replace and restore these at completion.
- B. Contractor shall remove unsuitable material not as salvage unless otherwise indicated in the Contract Documents. Unsuitable material may include, without

limitation, rotted wood, corroded metals, and deteriorated masonry and concrete. Contractor shall replace materials as specified for finished Work.

- C. Contractor shall remove debris and abandoned items from all areas of the Site and from concealed spaces.
- D. Contractor shall prepare surface and remove surface finishes to provide for proper installation of new Work and finishes.
- E. Contractor shall close openings in exterior surfaces to protect existing work from weather and extremes of temperature and humidity. Contractor shall insulate ductwork and piping to prevent condensation in exposed areas. Contractor shall insulate building cavities for thermal and/or acoustical protection, as detailed.

**3.03 INSTALLATION:**

- A. Contractor shall coordinate Work of all alternations and renovations to expedite completion and to accommodate County occupancy.
- B. Designated Areas and Finishes: Contractor shall complete all installations in all respects, including operational, mechanical work and electrical work.
- C. Contractor shall remove, cut, and patch Work in a manner to minimize damage and to provide a means of restoring Products and finishes to original or specified condition.
- D. Contractor shall refinish visible existing surfaces to remain in renovated rooms and spaces, to specified condition for each material, with a neat transition to adjacent finishes.
- E. Contractor shall install products as specified in the Contract Documents, including without limitation, the Specifications.

**3.04 TRANSITIONS:**

- A. Where new Work abuts or aligns with existing, Contractor shall perform a smooth and even transition. Patched Work must match existing adjacent work in texture and appearance.
- B. When finished surfaces are cut so that a smooth transition with new Work is not possible, Contractor shall terminate existing surface along a straight line at a natural line of division and make a recommendation for resolution to the County and the Architect for review and approval.



**3.05 ADJUSTMENTS:**

- A. Where removal of partitions or walls results in adjacent spaces becoming one, Contractor shall rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
- B. Where a change of plane of 1/4 inch or more occurs, Contractor shall submit a recommendation for providing a smooth transition to the County and the Architect for review and approval.
- C. Contractor shall trim existing doors as necessary to clear new floor finish and refinish trim as required.
- D. Contractor shall fit Work at penetrations of surfaces.

**3.06 REPAIR OF DAMAGED SURFACES:**

- A. Contractor shall patch or replace portions of existing surfaces which are damaged, lifted, discolored, or showing other imperfections.
- B. Contractor shall repair substrate prior to patching finish.

**3.07 CULTIVATED AREAS AND OTHER SURFACE IMPROVEMENTS:**

- A. Cultivated or planted areas and other surface improvements which are damaged by actions of the Contractor shall be restored by Contractor to their original condition or better, where indicated.
- B. Contractor shall protect and replace, if damaged, all existing guard posts, barricades, and fences.
- C. Contractor shall give special attention to avoid damaging or killing trees, bushes and/or shrubs on the Premises and/or identified the Contract Documents, including without limitation, the Drawings.

**3.08 FINISHES:**

- A. Contractor shall finish surfaces as specified in the Contract Documents, including without limitations, the provisions of all Divisions of the Specifications.
- B. Contractor shall finish patches to produce uniform finish and texture over entire area. When finish cannot be matched, Contractor shall refinish entire surface to nearest intersections.

**3.09 CLEANING:**

- A. Contractor shall continually clean the Site and the Premises as indicated in the Contract Documents, including without limitation, the provisions in the General Conditions and the Specifications regarding cleaning.

**END OF DOCUMENT**

DOCUMENT 01 77 00

**CONTRACT CLOSEOUT**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Completion of Work;
- B. Special Conditions;
- C. Construction Facilities and Temporary Controls.

**1.02 CLOSEOUT PROCEDURES**

Contractor shall comply with all closeout provisions as indicated in the General Conditions.

**1.03 FINAL CLEANING**

- A. Contractor shall execute final cleaning prior to final inspection.
- B. Contractor shall clean interior and exterior glass and surfaces exposed to view; remove temporary labels, tape, stains, and foreign substances, polish transparent and glossy surfaces, wax and polish new vinyl floor surfaces, vacuum carpeted and soft surfaces.
- C. Contractor shall clean equipment and fixtures to a sanitary condition.
- D. Contractor shall replace filters of operating equipment.
- E. Contractor shall clean debris from roofs, gutters, down spouts, and drainage systems.
- F. Contractor shall clean Site, sweep paved areas, and rake clean landscaped surfaces.
- G. Contractor shall remove waste and surplus materials, rubbish, and construction facilities from the Site.

**1.04 ADJUSTING**

- A. Contractor shall adjust operating products and equipment to ensure smooth and unhindered operation.
- B. Record Documents and Shop Drawings: Contractor shall legibly mark each item to record actual construction, including:
  - (1) Measured depths of foundations in relation to finish floor datum.
  - (2) Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
  - (3) Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
  - (4) Field changes of dimension and detail.
  - (5) Details not on original Contract Drawings.
  - (6) Changes made by modification(s).
  - (7) References to related Shop Drawings and modifications.
- C. County will provide one set of reproducible drawings to Contractor.
- D. Contractor shall submit all required documents to County and/or Architect prior to or with its final Application for Payment.

**1.06 INSTRUCTION OF COUNTY PERSONNEL:**

- A. Before final inspection, at agreed upon times, Contractor shall instruct County's designated personnel in operation, adjustment, and maintenance of products, equipment, and systems.
- B. For equipment requiring seasonal operation, Contractor shall perform instructions for other seasons within six months.
- C. Contractor shall use operation and maintenance manuals as basis for instruction. Contractor shall review contents of manual with personnel in detail to explain all aspects of operation and maintenance.

- D. Contractor shall prepare and insert additional data in Operation and Maintenance Manual when need for such data becomes apparent during instruction.
- E. Contractor shall use operation and maintenance manuals as basis for instruction. Contractor shall review contents of manual with personnel in detail to explain all aspects of operation and maintenance.

**1.07 SPARE PARTS AND MAINTENANCE MATERIALS:**

- A. Contractor shall provide products, spare parts, maintenance, and extra materials in quantities specified in the Specifications and in Manufacturer's recommendations.
- B. Contractor shall provide County all required Operation and Maintenance Data.

**PART 2 – PRODUCTS** Not used.

**PART 3 – EXECUTION** Not used.

END OF DOCUMENT

DOCUMENT 01 78 23

**OPERATION AND MAINTENANCE INSTRUCTIONS**

**PART 1 – GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Completion of the Work;
- B. Special Conditions.

**1.02 QUALITY ASSURANCE:**

- A. Contractor shall prepare instructions and data by personnel experienced in maintenance and operation of described products.

**1.03 FORMAT:**

- A. Contractor shall prepare data in the form of an instructional manual entitled "OPERATIONS AND MAINTENANCE MANUAL & INSTRUCTIONS" ("Manual").
- B. Binders: Contractor shall use commercial quality, 8-1/2 by 11 inch, three-side rings, with durable plastic covers; two inch maximum ring size. When multiple binders are used, Contractor shall correlate data into related consistent groupings.
- C. Cover: Contractor shall identify each binder with typed or printed title "OPERATION AND MAINTENANCE MANUAL & INSTRUCTIONS"; and shall list title of Project and identify subject matter of contents.
- D. Contractor shall arrange content by systems process flow under section numbers and sequence of Table of Contents of the Contract Documents.
- E. Contractor shall provide tabbed fly leaf for each separate product and system, with typed description of product and major component parts of equipment.
- F. Text: The content shall include Manufacturer's printed data, or typewritten data on 24 pound paper.

- G. Drawings: Contractor shall provide with reinforced punched binder tab and shall bind in with text; folding larger drawings to size of text pages.

**1.04 CONTENTS, EACH VOLUME:**

- A. Table of Contents: Contractor shall provide title of Project; names, addresses, and telephone numbers of the Architect, any engineers, subconsultants, Subcontractor(s), and Contractor with name of responsible parties; and schedule of products and systems, indexed to content of the volume.
- B. For Each Product or System: Contractor shall list names, addresses, and telephone numbers of Subcontractor(s) and suppliers, including local source of supplies and replacement parts.
- C. Product Data: Contractor shall mark each sheet to clearly identify specific products and component parts, and data applicable to installation. Delete inapplicable information.
- D. Drawings: Contractor shall supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams. Contractor shall not use Project Record Documents as maintenance drawings.
- E. Text: The Contractor shall include any and all information as required to supplement product data. Contractor shall provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions.
- F. Warranties and Bonds: Contractor shall bind in one copy of each.

**1.05 MANUAL FOR MATERIALS AND FINISHES:**

- A. Building Products, Applied Materials, and Finishes: Contractor shall include product data, with catalog number, size, composition, and color and texture designations. Contractor shall provide information for re-ordering custom manufactured products.
- B. Instructions for Care and Maintenance: Contractor shall include Manufacturer's recommendations for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- C. Moisture Protection and Weather Exposed Products: Contractor shall include product data listing applicable reference standards, chemical composition, and details of installation. Contractor shall provide recommendations for inspections, maintenance, and repair.

- D. Additional Requirements: Contractor shall include all additional requirements as specified in the Specifications.
- E. Contractor shall provide a listing in Table of Contents for design data, with tabbed fly sheet and space for insertion of data.

**1.06 MANUAL FOR EQUIPMENT AND SYSTEMS:**

- A. Each Item of Equipment and Each System: Contractor shall include description of unit or system, and component parts and identify function, normal operating characteristics, and limiting conditions. Contractor shall include performance curves, with engineering data and tests, and complete nomenclature, and commercial number of replaceable parts.
- B. Panelboard Circuit Directories: Contractor shall provide electrical service characteristics, controls, and communications.
- C. Contractor shall include color coded wiring diagrams as installed.
- D. Operating Procedures: Contractor shall include start-up, break-in, and routine normal operating instructions and sequences. Contractor shall include regulation, control, stopping, shut-down, and emergency instructions. Contractor shall include summer, winter, and any special operating instructions.
- E. Maintenance Requirements: Contractor shall include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- F. Contractor shall provide servicing and lubrication schedule, and list of lubricants required.
- G. Contractor shall include manufacturer's printed operation and maintenance instructions.
- H. Contractor shall include sequence of operation by controls manufacturer.
- I. Contractor shall provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- J. Contractor shall provide control diagrams by controls manufacturer as installed.
- K. Contractor shall provide Contractor's coordination drawings, with color coded piping diagrams as installed.



- L. Contractor shall provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- M. Contractor shall provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- N. Additional Requirements: Contractor shall include all additional requirements as specified in Specification(s).
- O. Contractor shall provide a listing in Table of Contents for design data, with tabbed fly sheet and space for insertion of data.

**1.08 SUBMITTAL:**

- A. Contractor shall submit to the County for review two (2) copies of preliminary draft or proposed formats and outlines of the contents of the Manual within thirty (30) days of Contractor's start of Work.
- B. For equipment, or component parts of equipment put into service during construction and to be operated by County, Contractor shall submit draft content for that portion of the Manual within ten (10) days after acceptance of that equipment or component.
- C. Contractor shall submit two (2) copies of a complete Manual in final form prior to final Application for Payment. Copy will be returned with Architect/Engineer comments. Contractor must revise the content of the Manual as required by County prior to County's approval of Contractor's final Application for Payment.
- D. Contractor must submit two (2) copies of revised Manual in final form within ten (10) days after final inspection.

END OF DOCUMENT

DOCUMENT 01 78 36

**WARRANTIES**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Warranty/Guarantee Information;
- B. Special Conditions.

**1.02 FORMAT**

- A. Binders: Contractor shall use commercial quality, 8-1/2 by 11 inch, three-side rings, with durable plastic covers; two inch maximum ring size.
- B. Cover: Contractor shall identify each binder with typed or printed title "WARRANTIES" and shall list title of Project.
- C. Table of Contents: Contractor shall provide title of Project; name, address, and telephone number of Contractor and equipment supplier, and name of responsible principal. Contractor shall identify each item with the number and title of the specific Specification, document, provision, or section in which the name of the product or work item is specified.
- D. Contractor shall separate each warranty with index tab sheets keyed to the Table of Contents listing, providing full information and using separate typed sheets as necessary. Contractor shall list each applicable and/or responsible subcontractor(s), supplier(s), and/or manufacturer(s), with name, address, and telephone number of each responsible principal(s).

**1.03 PREPARATION:**

- A. Contractor shall obtain warranties, executed in duplicate by each applicable and/or responsible subcontractor(s), supplier(s), and manufacturer(s), within ten (10) days after completion of the applicable item or work. Except for items put into use with County's permission, Contractor shall leave date of beginning of time of warranty until the date of completion is determined.

- B. Contractor shall verify that documents are in proper form, contain full information, and are notarized, when required.
- C. Contractor shall co-execute submittals when required.
- D. Contractor shall retain warranties until time specified for submittal.

**1.04 TIME OF SUBMITTALS:**

- A. For equipment or component parts of equipment put into service during construction with County's permission, Contractor shall submit a draft warranty for that equipment or component within ten (10) days after acceptance of that equipment or component.
- B. Contractor shall submit for County approval all warranties and related documents within ten (10) days after date of completion. Contractor must revise the warranties as required by the County prior to County's approval of Contractor's final Application for Payment.
- C. For items of work delayed beyond date of completion, provide updated submittal within ten days after acceptance, listing the date of acceptance as start of warranty period.

**END OF DOCUMENT**

DOCUMENT 01 78 39

**PROJECT RECORD DOCUMENTS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents should be reviewed for applicable provisions related to the provisions in this document, including without limitation:

- A. General Conditions, including, without limitation, Documents on Work;
- B. Special Conditions.

**PART 2 - RECORD DRAWINGS**

**2.01 GENERAL:**

- A. As indicated in the Contract Documents, the County will provide Contractor with one set of plans of the original Contract Drawings, if required for each individual Task Order.
- B. Contractor shall maintain at each Project Site one set of marked-up blueline prints and each month, or as otherwise agreed, shall transfer all changes and information to those marked-up blueline prints. Contractor shall submit to the Project County one set of reproducible vellums of the Project Record Drawings ("As-Builts") showing all changes incorporated into the Work since the preceding monthly submittal. The Record Drawings shall be available at the Project Site. The Contractor shall submit reproducible vellums at the conclusion of the Project following review of the blueline prints.
- C. Label and date each Record Drawing "RECORD DOCUMENT" in legibly printed letters.
- D. All deviations in construction, including but not limited to pipe and conduit locations and deviations caused by without limitation Change Orders, Construction Claim Directives, RFI's, and Addenda, shall be accurately and legibly recorded by Contractor.
- E. Locations and changes shall be done by Contractor in a neat and legible manner and, where applicable, indicated by drawing a "cloud" around the changed or additional information.

## **2.02 RECORD DRAWING INFORMATION:**

- A. Contractor shall record the following information:
  - (1) Locations of Work buried under or outside each building, including, without limitation, all utilities, plumbing and electrical lines, and conduits.
  - (2) Actual numbering of each electrical circuit.
  - (3) Locations of significant Work concealed inside each building whose general locations are changed from those shown on the Contract Drawings.
  - (4) Locations of all items, not necessarily concealed, which vary from the Contract Documents.
  - (5) Installed location of all cathodic protection anodes.
  - (6) Deviations from the sizes, locations, and other features of installations shown in the Contract Documents.
  - (7) Locations of underground work, points of connection with existing utilities, changes in direction, valves, manholes, catch basins, capped stub outs, invert elevations, etc.
  - (8) Sufficient information to locate Work concealed in each building with reasonable ease and accuracy. In some instances, this may be by dimension, in others, it may be in relation to the spaces in the building near which it was installed.
- B. Contractor shall provide additional drawings as necessary for clarification.
- C. Contractor shall provide reproducible record drawings, made from final Shop Drawings marked "No Exceptions Taken" or "Approved as Noted."

## **PART 3 - RECORD SPECIFICATIONS**

### **3.01 GENERAL:**

- A. Contractor shall mark each section legibly to record manufacturer, trade name, catalog number, and supplier of each Product and item of equipment actually installed.

## **PART 4 - MAINTENANCE OF RECORD DOCUMENTS**

**4.01 GENERAL**

- A. Contractor shall store Record Documents apart from documents used for construction:
  - (1) Provide files and racks for storage of Record Documents.
  - (2) Maintain Record Documents in a clean, dry, legible condition and in good order.
- B. Do not use Record Documents for construction purposes.

END OF DOCUMENT

**DOCUMENT 01 91 13**

**GENERAL COMMISSIONING REQUIREMENTS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.
- B. OPR and BoD documentation prepared by Owner and Architect contains requirements that apply to this Section.

**1.02 SUMMARY**

- A. This Section includes general requirements that apply to implementation of commissioning without regard to systems, subsystems, and equipment being commissioned.
- B. Related Sections include the following:
  - 1. Division 1 Section "HVAC Commissioning Requirements" for specific requirements for commissioning HVAC systems.

**1.2 DEFINITIONS**

- A. BoD: Basis of Design.
- B. CxA: Commissioning Authority.
- C. OPR: Owner's Project Requirements.
- D. Systems, Subsystems, and Equipment: Where these terms are used together or separately, they shall mean "as-built" systems, subsystems, and equipment.
- E. TAB: Testing, Adjusting, and Balancing.

**1.3 COMMISSIONING TEAM**

- A. Members Appointed by Contractor(s): Individuals, each having authority to act on behalf of the entity he or she represents, explicitly organized to implement the commissioning process through coordinated actions. The commissioning team shall

consist of, but not be limited to, representatives of each Contractor, including Project superintendent and subcontractors, installers, suppliers, and specialists deemed appropriate by the CxA.

**B. Members Appointed by Owner:**

1. CxA: The designated person, company, or entity that plans, schedules, and coordinates the commissioning team to implement the commissioning process. Owner will engage the CxA under a separate contract.
2. Representatives of the facility user and operation and maintenance personnel.
3. Architect and engineering design professionals.

**1.4 OWNER'S RESPONSIBILITIES**

- A. Provide the OPR documentation to the CxA and each Contractor for use in developing the commissioning plan; systems manual; operation and maintenance training plan; and testing plans and checklists.
- B. Assign operation and maintenance personnel and schedule them to participate in commissioning team activities including, but not limited to, the following:
1. Coordination meetings.
  2. Training in operation and maintenance of systems, subsystems, and equipment.
  3. Testing meetings.
  4. Demonstration of operation of systems, subsystems, and equipment.
- C. Provide utility services required for the commissioning process.
- D. Provide the BoD documents, prepared by Architect and approved by Owner, to the CxA and each Contractor for use in developing the commissioning plan, systems manual, and operation and maintenance training plan.

**1.5 CONTRACTOR'S RESPONSIBILITIES**

- A. Provide utility services required for the commissioning process.
- B. Each Contractor shall assign representatives with expertise and authority to act on behalf of the Contractor and schedule them to participate in and perform commissioning team activities including, but not limited to, the following:
1. Participate in design- and construction-phase coordination meetings.
  2. Participate in maintenance orientation and inspection.
  3. Participate in operation and maintenance training sessions.
  4. Participate in final review at acceptance meeting.



5. Certify that Work is complete and systems are operational according to the Contract Documents, including calibration of instrumentation and controls.
  6. Evaluate performance deficiencies identified in test reports and, in collaboration with entity responsible for system and equipment installation, recommend corrective action.
  7. Review and approve final commissioning documentation.
- C. Subcontractors shall assign representatives with expertise and authority to act on behalf of subcontractors and schedule them to participate in and perform commissioning team activities including, but not limited to, the following:
1. Participate in design- and construction-phase coordination meetings.
  2. Participate in maintenance orientation and inspection.
  3. Participate in procedures meeting for testing.
  4. Participate in final review at acceptance meeting.
  5. Provide schedule for operation and maintenance data submittals, equipment startup, and testing to CxA for incorporation into the commissioning plan. Update schedule on a weekly basis throughout the construction period.
  6. Provide information to the CxA for developing construction-phase commissioning plan.
  7. Participate in training sessions for Owner's operation and maintenance personnel.
  8. Provide updated Project Record Documents to the CxA on a daily basis.
  9. Gather and submit operation and maintenance data for systems, subsystems, and equipment to the CxA, as specified in Division 1 Section "Operation and Maintenance Data."
  10. Provide technicians who are familiar with the construction and operation of installed systems and who shall develop specific test procedures and participate in testing of installed systems, subsystems, and equipment.

#### **1.6 CxA'S RESPONSIBILITIES**

- A. Organize and lead the commissioning team.
- B. Prepare a construction-phase commissioning plan. Collaborate with each Contractor and with subcontractors to develop test and inspection procedures. Include design changes and scheduled commissioning activities coordinated with overall Project schedule. Identify commissioning team member responsibilities, by name, firm, and trade specialty, for performance of each commissioning task.
- C. Review and comment on submittals from each Contractor for compliance with the OPR, BoD, Contract Documents, and construction-phase commissioning plan. Review and comment on performance expectations of systems and equipment and interfaces between systems relating to the OPR and BoD.

- D. Convene commissioning team meetings for the purpose of coordination, communication, and conflict resolution; discuss progress of the commissioning processes. Responsibilities include arranging for facilities, preparing agenda and attendance lists, and notifying participants. The CxA shall prepare and distribute minutes to commissioning team members and attendees within five workdays of the commissioning meeting.
- E. At the beginning of the construction phase, conduct an initial construction-phase coordination meeting for the purpose of reviewing the commissioning activities and establishing tentative schedules for operation and maintenance submittals; operation and maintenance training sessions; TAB Work; and Project completion.
- F. Observe and inspect construction and report progress and deficiencies. In addition to compliance with the OPR, BoD, and Contract Documents, inspect systems and equipment installation for adequate accessibility for maintenance and component replacement or repair.
- G. Prepare Project-specific test and inspection procedures and checklists.
- H. Schedule, direct, witness, and document tests, inspections, and systems startup.
- I. Compile test data, inspection reports, and certificates and include them in the systems manual and commissioning report.
- J. Certify date of acceptance and startup for each item of equipment for start of warranty periods.
- K. Review Project Record Documents for accuracy. Request revisions from Contractor to achieve accuracy. Project Record Documents requirements are specified in Division 1 Section "Project Record Documents."
- L. Review and comment on operation and maintenance documentation and systems manual outline for compliance with the OPR, BoD, and Contract Documents. Operation and maintenance documentation requirements are specified in Division 1 Section "Operation and Maintenance Data."
- M. Prepare operation and maintenance training program and provide qualified instructors to conduct operation and maintenance training. Operation and maintenance training is specified in Division 1 Section "Demonstration and Training."
- N. Videotape and edit training sessions.
- O. Videotape construction progress including hidden shafts.
- P. Prepare commissioning reports.

- Q. Assemble the final commissioning documentation, including the commissioning report and Project Record Documents.

#### **1.7 COMMISSIONING DOCUMENTATION**

- A. Index of Commissioning Documents: CxA shall prepare an index to include storage location of each document.
- B. OPR: A written document, prepared by Owner, which details the functional requirements of Project and expectations of how it will be used and operated. This document includes Project and design goals, measurable performance criteria, budgets, schedules, success criteria, and supporting information.
- C. BoD Document: A document, prepared by Architect, that records concepts, calculations, decisions, and product selections used to meet the OPR and to satisfy applicable regulatory requirements, standards, and guidelines. The document includes both narrative descriptions and lists of individual items that support the design process.
- D. Commissioning Plan: A document, prepared by CxA, that outlines the schedule, allocation of resources, and documentation requirements of the commissioning process, and shall include, but is not limited to the following:
  - 1. Plan for delivery and review of submittals, systems manuals, and other documents and reports. Identification of the relationship of these documents to other functions and a detailed description of submittals that are required to support the commissioning processes. Submittal dates shall include the latest date approved submittals must be received without adversely affecting commissioning plan.
  - 2. Description of the organization, layout, and content of commissioning documentation (including systems manual) and a detailed description of documents to be provided along with identification of responsible parties.
  - 3. Identification of systems and equipment to be commissioned.
  - 4. Description of schedules for testing procedures along with identification of parties involved in performing and verifying tests.
  - 5. Identification of items that must be completed before the next operation can proceed.
  - 6. Description of responsibilities of commissioning team members.
  - 7. Description of observations to be made.
  - 8. Description of requirements for operation and maintenance training, including required training materials.
  - 9. Description of expected performance for systems, subsystems, equipment, and controls.
  - 10. Schedule for commissioning activities with specific dates coordinated with overall construction schedule.
  - 11. Identification of installed systems, subsystems, and equipment, including design changes that occurred during the construction phase.

12. Process and schedule for documenting changes on a continuous basis to appear in Project Record Documents.
  13. Process and schedule for completing prestart and startup checklists for systems, subsystems, and equipment to be verified and tested.
  14. Step-by-step procedures for testing systems, subsystems, and equipment with descriptions for methods of verifying relevant data, recording the results obtained, and listing parties involved in performing and verifying tests.
- E. Test Checklists: CxA, with assistance of Architect, shall develop test checklists for each system, subsystem, or equipment including interfaces and interlocks, and include a separate entry, with space for comments, for each item to be tested. Prepare separate checklists for each mode of operation and provide space to indicate whether the mode under test responded as required. Provide space for testing personnel to sign off on each checklist. Specific checklist content requirements are specified in Division 1 Section "HVAC Commissioning Requirements." Each checklist, regardless of system, subsystem, or equipment being tested, shall include, but not be limited to, the following:
1. Name and identification code of tested item.
  2. Test number.
  3. Time and date of test.
  4. Indication of whether the record is for a first test or retest following correction of a problem or issue.
  5. Dated signatures of the person performing test and of the witness, if applicable.
  6. Individuals present for test.
  7. Deficiencies.
  8. Issue number, if any, generated as the result of test.
- F. Certificate of Readiness: Certificate of Readiness shall be signed by each Contractor, Subcontractor(s), Installer(s), and CxA certifying that systems, subsystems, equipment, and associated controls are ready for testing. Completed test checklists signed by the responsible parties shall accompany this certificate.
- G. Test and Inspection Reports: CxA shall record test data, observations, and measurements on test checklists. Photographs, forms, and other means appropriate for the application shall be included with data. CxA shall compile test and inspection reports and test and inspection certificates and include them in systems manual and commissioning report.
- H. Corrective Action Documents: CxA shall document corrective action taken for systems and equipment that fail tests. Include required modifications to systems and equipment and revisions to test procedures, if any. Retest systems and equipment requiring corrective action and document retest results.
- I. Issues Log: CxA shall prepare and maintain an issues log that describes design, installation, and performance issues that are at variance with the OPR, BoD, and

Contract Documents. Identify and track issues as they are encountered, documenting the status of unresolved and resolved issues.

1. Creating an Issues Log Entry:
  - a. Identify the issue with unique numeric or alphanumeric identifier by which the issue may be tracked.
  - b. Assign a descriptive title of the issue.
  - c. Identify date and time of the issue.
  - d. Identify test number of test being performed at the time of the observation, if applicable, for cross-reference.
  - e. Identify system, subsystem, and equipment to which the issue applies.
  - f. Identify location of system, subsystem, and equipment.
  - g. Include information that may be helpful in diagnosing or evaluating the issue.
  - h. Note recommended corrective action.
  - i. Identify commissioning team member responsible for corrective action.
  - j. Identify expected date of correction.
  - k. Identify person documenting the issue.
2. Documenting Issue Resolution:
  - a. Log date correction is completed or the issue is resolved.
  - b. Describe corrective action or resolution taken. Include description of diagnostic steps taken to determine root cause of the issue, if any.
  - c. Identify changes to the OPR, BoD, or Contract Documents that may require action.
  - d. State that correction was completed and system, subsystem, and equipment is ready for retest, if applicable.
  - e. Identify person(s) who corrected or resolved the issue.
  - f. Identify person(s) documenting the issue resolution.
3. Issues Log Report: On a periodic basis, but not less than for each commissioning team meeting, CxA shall prepare a written narrative for review of outstanding issues and a status update of the issues log. As a minimum, CxA shall include the following information in the issues log and expand it in the narrative:
  - a. Issue number and title.
  - b. Date of the identification of the issue.
  - c. Name of the commissioning team member assigned responsibility for resolution.
  - d. Expected date of correction.
- J. Commissioning Report: CxA shall document results of the commissioning process including unresolved issues and performance of systems, subsystems, and equipment. The commissioning report shall indicate whether systems, subsystems, and equipment

have been completed and are performing according to the OPR, BoD, and Contract Documents. The commissioning report shall include, but is not limited to, the following:

1. Lists and explanations of substitutions; compromises; variances in the OPR, BoD, and Contract Documents; record of conditions; and, if appropriate, recommendations for resolution. This report shall be used to evaluate systems, subsystems, and equipment and shall serve as a future reference document during Owner occupancy and operation. It shall describe components and performance that exceed requirements of the OPR, BoD, and Contract Documents and those that do not meet requirements of the OPR, BoD, and Contract Documents. It may also include a recommendation for accepting or rejecting systems, subsystems, and equipment.
  2. OPR and BoD documentation.
  3. Commissioning plan.
  4. Testing plans and reports.
  5. Corrective modification documentation.
  6. Issues log.
  7. Completed test checklists.
  8. Listing of off-season test(s) not performed and a schedule for their completion.
- K. Systems Manual: CxA shall gather required information and compile systems manual. Systems manual shall include, but is not limited to, the following:
1. OPR and BoD, including system narratives, schematics, and changes made throughout the Project.
  2. Project Record Documents as specified in Division 1 Section "Project Record Documents."
  3. Final commissioning plan.
  4. Commissioning report.
  5. Operation and maintenance data as specified in Division 1 Section "Operation and Maintenance Data."

## **1.8 SUBMITTALS**

- A. Commissioning Plan Prefinal Submittal: CxA shall submit two hard copies of prefinal commissioning plan. Deliver one copy to each Contractor, one to Owner, and one to Architect. Present submittal in sufficient detail to evaluate data collection and arrangement process. One copy, with review comments, will be returned to the CxA for preparation of the final construction-phase commissioning plan.
- B. Commissioning Plan Final Submittal: CxA shall submit two hard copies and two sets of electronically formatted information of final commissioning plan. Deliver one hard copy and one set of discs to Owner, and one copy to Architect. The final submittal

must address previous review comments. The final submittal shall include a copy of the prefinal submittal review comments along with a response to each item.

- C. Test Checklists and Report Forms: CxA shall submit sample checklists and forms to each Contractor quality-control manager and subcontractors for review and comment. Submit two copies of each checklist and report form.
- D. Certificates of Readiness: CxA shall submit Certificates of Readiness.
- E. Test and Inspection Reports: CxA shall submit test and inspection reports.
- F. Corrective Action Documents: CxA shall submit corrective action documents.
- G. Prefinal Commissioning Report Submittal: CxA shall submit two hard copies of the prefinal commissioning report. Include a copy of the preliminary submittal review comments along with CxA's response to each item. CxA shall deliver one copy to Owner and one copy to Architect. One copy, with review comments, will be returned to the CxA for preparation of final submittal.
- H. Final Commissioning Report Submittal: CxA shall submit two hard copies and two sets of electronically formatted information of the final commissioning report. CxA shall deliver one hard copy and one set of discs to Owner, and one copy to Architect. The final submittal must address previous review comments and shall include a copy of the prefinal submittal review comments along with a response to each item.

#### **1.9 QUALITY ASSURANCE**

- A. Instructor Qualifications: Factory-authorized service representatives, experienced in training, operation, and maintenance procedures for installed systems, subsystems, and equipment.
- B. Test Equipment Calibration: Comply with test equipment manufacturer's calibration procedures and intervals. Recalibrate test instruments immediately whenever instruments have been repaired following damage or dropping. Affix calibration tags to test instruments. Instruments shall have been calibrated within six months prior to use.

#### **1.10 COORDINATION**

- A. Coordinating Meetings: CxA shall conduct weekly, biweekly, or monthly coordination meetings of the commissioning team to review progress on the commissioning plan, to discuss scheduling conflicts, and to discuss upcoming commissioning process activities.
- B. Pretesting Meetings: CxA shall conduct pretest meetings of the commissioning team to review startup reports, pretest inspection results, testing procedures, testing personnel

and instrumentation requirements, and manufacturers' authorized service representative services for each system, subsystem, equipment, and component to be tested.

- C. Testing Coordination: CxA shall coordinate sequence of testing activities to accommodate required quality-assurance and -control services with a minimum of delay and to avoid necessity of removing and replacing construction to accommodate testing and inspecting.
  - 1. Schedule times for tests, inspections, obtaining samples, and similar activities.
- D. Manufacturers' Field Services: CxA shall coordinate services of manufacturers' field services.

## **PART 2 - PRODUCTS (Not Used)**

## **PART 3 - EXECUTION**

### **3.1 OPERATION AND MAINTENANCE TRAINING REQUIREMENTS**

- A. Training Preparation Conference: Before operation and maintenance training, CxA shall convene a training preparation conference to include Owner's operation and maintenance personnel, each Contractor, and subcontractors. In addition to requirements specified in Division 1 Section "Demonstration and Training," perform the following:
  - 1. Review the OPR and BoD.
  - 2. Review installed systems, subsystems, and equipment.
  - 3. Review instructor qualifications.
  - 4. Review instructional methods and procedures.
  - 5. Review training module outlines and contents.
  - 6. Review course materials (including operation and maintenance manuals).
  - 7. Inspect and discuss locations and other facilities required for instruction.
  - 8. Review and finalize training schedule and verify availability of educational materials, instructors, audiovisual equipment, and facilities needed to avoid delays.
  - 9. For instruction that must occur outside, review weather and forecasted weather conditions and procedures to follow if conditions are unfavorable.
- B. Training Modules: Develop an instruction program that includes individual training modules for each system, subsystem, and equipment as specified in Division 1 Section "Demonstration and Training."

**END OF DOCUMENT**



**DOCUMENT 26 00 00**

**ELECTRICAL BASIC REQUIREMENTS**

**PART 1 - GENERAL**

**1.01 SECTION INCLUDES**

- A. Design Builder to provide materials, labor, tools, permits, incidentals, and other services to provide and make ready for Owner's use of electrical systems for proposed project.

**1.02 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**1.07 COORDINATION DOCUMENTS**

- A. Prior to construction, coordinate installation and location of HVAC equipment, ductwork, grilles, diffusers, piping, plumbing equipment/fixtures, fire sprinklers, plumbing, lights, cable tray and electrical services with architectural and structural requirements, and other trades (including ceiling suspension and tile systems), and provide maintenance access requirements. Coordinate with submitted architectural systems (i.e. roofing, ceiling, finishes) and structural systems as submitted, including footings and foundation. Identify zone of influence from footings and ensure systems are not routed within the zone of influence.
- B. Advise Owner in event a conflict occurs in location or connection of equipment. Bear costs resulting from failure to properly coordinate installation or failure to advise Owner of conflict.
- C. Verify in field exact size, location, and clearances regarding existing material, equipment and apparatus, and advise Owner of discrepancies between that indicated on Drawings and that existing in field prior to installation related thereto.
- D. Submit final Coordination Drawings with changes as Record Drawings at completion of project.

## **PART 2 - PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Provide like items from one manufacturer.

### **2.02 MATERIALS**

- A. Base contract upon furnishing materials as specified. Materials, equipment, and fixtures used for construction are to be new, latest products as listed in manufacturer's printed catalog data and are to be UL approved or have adequate approval or be acceptable by state, county, and city authorities. Equipment/fixture supplier is responsible for obtaining State, County, and City acceptance on equipment/fixtures that are not UL approved or are not listed for installation.
- B. Articles, fixtures, and equipment of a kind to be standard product of one manufacturer.
- C. Names and manufacturer's names denote character and quality of equipment desired and are not to be construed as limiting competition.
- D. Hazardous Materials:
  - 1. Comply with local, State of California, and Federal regulations relating to hazardous materials.
  - 2. Comply with Division 00, Procurement and Contracting Requirements and Division 01, General Requirements for this project relating to hazardous materials.
  - 3. Do not use any materials containing a hazardous substance. If hazardous materials are encountered, do not disturb; immediately notify Owner. Hazardous materials will be removed by Owner under separate contract.

### **2.03 ACCESS PANELS**

- A. See Division 01, General Requirements and Division 08, Openings for products and installation requirements.
- B. Confirm Access Panel requirements in Division 01, General Requirements and individual Division 26, Electrical Sections. In the absence of specific requirements, comply with the following:
  - 1. Provide flush mounting access panels for service of systems and individual components requiring maintenance or inspection. Where access panels are located in fire-rated assemblies of building, rate access panels accordingly.
    - a. Ceiling access panels to be minimum of 24-inch by 24-inch.
    - b. Wall access panels to be minimum of 12-inch by 12-inch.
    - c. Provide screwdriver operated catch.
    - d. Manufacturers and Models:
      - 1) Drywall: Karp KDW.
      - 2) Plaster: Karp DSC-214PL.
      - 3) Masonry: Karp DSC-214M.
      - 4) 2 hour rated: Karp KPF-350FR.
      - 5) Manufacturers: Milcor, Elmdor, Acudor, or approved equivalent.

## **PART 3 - EXECUTION**

### **3.01 ACCESSIBILITY AND INSTALLATION**

- A. Confirm Accessibility and Installation requirements in contract documents.
- B. Install equipment requiring access (i.e., junction boxes, light fixtures, power supplies, motors, etc.) so that they may be serviced, reset, replaced or recalibrated by service people with normal service tools and equipment. Do not install equipment in passageways, doorways, scuttles or crawlspaces which would impede or block the intended usage.
- C. Install equipment and products complete as directed by manufacturer's installation instructions. Obtain installation instructions from manufacturer prior to rough-in of equipment and examine instructions thoroughly. When requirements of installation instructions conflict with Contract Documents, request clarification from Owner prior to proceeding with installation. This includes proper installation methods, sequencing, and coordination with other trades and disciplines.
- D. Firestopping:
  - 1. Confirm requirements in contract documents and the following:
    - a. Coordinate location and protection level of fire and/or smoke rated walls, ceilings, and floors. When these assemblies are penetrated, seal around piping and equipment with approved firestopping material. Install firestopping material complete as directed by manufacturer's installation instructions. Meet requirements of ASTM E814, Standard Test Method for Fire Tests of Through-Penetration Fire Stops.
- E. Plenums:
  - 1. In plenums, provide plenum rated materials that meet the requirements to be installed in plenums. Immediately notify Design Builder of discrepancy.
- F. Start up equipment, in accordance with manufacturer's start-up instructions, and in presence of manufacturer's representative. Test controls and demonstrate compliance with requirements. Replace damaged or malfunctioning controls and equipment.
- G. Provide miscellaneous supports/metals required for installation of equipment and conduit.

### **3.02 SEISMIC CONTROL**

- A. Confirm Seismic Control requirements in contract documents.
- B. Equipment Importance Factor: 1.0.
- C. General:
  - 1. Confirm Building Occupancy Category and Seismic Design Category with Authority Having Jurisdiction.
  - 2. Earthquake resistant designs for Electrical (Division 26, Electrical) equipment and distribution, i.e. power distribution equipment, generators, UPS, etc. to conform to regulations of jurisdiction having authority.
  - 3. Restraints which are used to prevent disruption of function of piece of equipment because of application of horizontal force to be such that forces are carried to frame of structure in such a way that frame will not be deflected when apparatus is attached to a mounting base and equipment pad, or to structure in normal way,

utilizing attachments provided. Secure equipment and distribution systems to withstand a force in direction equal to value defined by jurisdiction having authority.

4. Provide stamped shop drawings from licensed Structural Engineer of seismic bracing and seismic movement assemblies for conduit and equipment. Submit shop drawings along with equipment submittals.
5. Provide stamped shop drawings from licensed Structural Engineer of seismic flexible joints for conduit crossing building expansion or seismic joints. Submit shop drawings along with seismic bracing details. Coordinate exact design requirements with project Structural Engineer.

D. Equipment:

1. Provide means to prohibit excessive motion of electrical equipment during earthquake.

### 3.03 REVIEW AND OBSERVATION

- A. Confirm Review and Observation requirements in contract documents.
- B. Notify Owner, in writing, at following stages of construction so that they may, at their option, visit site for review and construction observation:
  1. Underground conduit installation prior to backfilling.
  2. Prior to covering walls.
  3. Prior to ceiling cover/installation.
  4. When main systems, or portions of, are being tested and ready for inspection by AHJ.
- C. Final Punch:
  1. Costs incurred by additional trips required due to incomplete systems will be the responsibility of the Design Builder.

### 3.04 CONTINUITY OF SERVICE

- A. Confirm requirements in contract documents and the following:
  1. During remodeling or addition to existing structure, while existing structure is occupied, present services to remain intact until new construction, facilities or equipment is installed.
  2. Prior to changing over to new service, verify that every item is thoroughly prepared. Install new wiring, and wiring to point of connection.
  3. Coordinate transfer time to new service with Owner. If required, perform transfer during off-peak hours. Once changeover is started, pursue to its completion to keep interference to a minimum.
    - a. If overtime is necessary, there will be no allowance made by Owner for extra expense for such overtime or shift work.
  4. No interruption of services to any part of existing facilities will be permitted without express permission in each instance from Owner. Requests for outages must state specific dates, hours and maximum durations, with outages kept to these specific dates, hours and maximum durations. Obtain written permission from Owner for any interruption of power, lighting or signal circuits and systems.

- a. Organize work to minimize duration of power interruption.
- b. Coordinate utility service outages with utility company.

### **3.05 CUTTING AND PATCHING**

- A. Confirm requirements in contract documents and the following:
  1. Proposed floor cutting/core drilling/sleeve locations to be approved by project Structural Engineer. Submit proposed locations to Owner/Project Structural Engineer. Where slabs are of post tension construction, perform x-ray scan of proposed penetration locations and submit scan results including proposed penetration locations to Owner for approval. Where slabs are of waffle type construction, show column cap extent and cell locations relative to proposed penetration(s).
  2. Cutting, patching and repairing for work specified in this Division including plastering, masonry work, concrete work, carpentry work, and painting included under this Section will be performed by skilled craftsmen of each respective trade in conformance with appropriate Division of Work.
  3. Additional openings required in building construction to be made by drilling or cutting. Use of jack hammer is specifically prohibited. Patch openings in and through concrete and masonry with grout.
  4. Restore new or existing work that is cut and/or damaged to original condition. Patch and repair specifically where existing items have been removed. This includes repairing and painting walls, ceilings, etc. where existing conduit and devices are removed as part of this project. Where alterations disturb lawns, paving, and/or walks, surfaces to be repaired, refinished and left in condition matching existing prior to commencement of work.
  5. Additional work required by lack of proper coordination will be provided at no additional cost to the Owner.

### **3.06 EQUIPMENT SELECTION AND SERVICEABILITY**

- A. Replace or reposition equipment which is too large or located incorrectly to permit servicing, at no additional cost to Owner.

### **3.07 DELIVERY, STORAGE AND HANDLING**

- A. Confirm requirements in contract documents and the following:
  1. Handle materials delivered to project site with care to avoid damage. Store materials on site inside building or protected from weather, dirt and construction dust. Products and/or materials that become damaged due to water, dirt, and/or dust as a result of improper storage and handling to be replaced before installation.
  2. Protect equipment to avoid damage. Close conduit openings with caps or plugs. Keep motors and bearings in watertight and dustproof covers during entire course of installation.
  3. Protect bus duct and similar items until in service.

### **3.08 DEMONSTRATION**

- A. Confirm Demonstration requirements in contract documents.

- B. Upon completion of work and adjustment of equipment, test systems and demonstrate to Owner's Representative and Design Builder that equipment furnished and installed or connected under provisions of these Specifications functions in manner required. Provide field instruction to Owner's Maintenance Staff as specified in contract documents.
- C. Manufacturer's Field Services: Furnish services of a qualified person at time approved by Owner, to instruct maintenance personnel, correct defects or deficiencies, and demonstrate to satisfaction of Owner that entire system is operating in satisfactory manner and complies with requirements of other trades that may be required to complete work. Complete instruction and demonstration prior to final job site observations.

### **3.09 CLEANING**

- A. Confirm Cleaning requirements in contract documents.
- B. Upon completion of installation, thoroughly clean electrical equipment, removing dirt, debris, dust, temporary labels and traces of foreign substances. Throughout work, remove construction debris and surplus materials accumulated during work.

### **3.10 INSTALLATION**

- A. Confirm Installation requirements in contract documents.
- B. Install equipment and fixtures in accordance with manufacturer's installation instructions, plumb and level and firmly anchored to vibration isolators. Maintain manufacturer's recommended clearances.
- C. Start up equipment, in accordance with manufacturer's start-up instructions, and in presence of manufacturer's representative. Test controls and demonstrate compliance with requirements. Replace damaged or malfunctioning controls and equipment.
- D. Provide miscellaneous supports/metals required for installation of equipment.

### **3.11 PAINTING**

- A. Confirm requirements in contract documents and the following:
  - 1. Ferrous Metal: After completion of work, thoroughly clean and paint exposed supports constructed of ferrous metal surfaces (i.e., hangers, hanger rods, equipment stands, etc.) with one coat of black asphalt varnish for exterior or black enamel for interior, suitable for hot surfaces.
  - 2. In Electrical Room, on roof or other exposed areas, equipment not painted with enamel to receive two coats of primer and one coat of rustproof enamel, colors as selected by Design Builder.
  - 3. See individual equipment Specifications for other painting.
  - 4. Structural Steel: Repair damage to structural steel finishes or finishes of other materials damaged by cutting, welding or patching to match original.
  - 5. Conduit: Clean, primer coat and paint interior/exterior conduit exposed in public areas with two coats paint suitable for metallic surfaces. Color selected by Design Builder.
  - 6. Covers: Covers such as manholes, vaults and the like will be furnished with finishes which resist corrosion and rust.

### **3.12 ACCESS PANELS**

- A. Confirm Access Panel requirements in contract documents and the following:
  - 1. Coordinate locations/sizes of access panels with Owner prior to work.

### **3.13 DEMOLITION**

- A. Confirm requirements in contract documents and the following:
  - 1. It is the intent of these documents to provide necessary information and adjustments to electrical system required to meet code, and accommodate installation of new work.
  - 2. Coordinate with Owner so that work can be scheduled not to interrupt operations, normal activities, building access or access to different areas. Owner will cooperate to best of their ability to assist in coordinated schedule, but will remain final authority as to time of work permitted.
  - 3. Examination:
    - a. Determine exact location of existing utilities and equipment before commencing work, compensate Owner for damages caused by failure to locate and preserve utilities. Replace damaged items with new material to match existing.
    - b. Verify that abandoned wiring and equipment serve only abandoned facilities.
    - c. Demolition drawings are based on casual field observation and existing record documents.
      - 1) Verify accuracy of information shown prior to bidding and provide such labor and material as is necessary to accomplish work.
      - 2) Verify location and number of electrical outlets, luminaires, panels, etc. in field.
    - d. Report discrepancies to Owner before disturbing existing installation.
      - 1) Promptly notify Owner if utilities are found which are not shown on Drawings.
  - 4. Execution:
    - a. Remove existing luminaires, switches, receptacles, and other electrical equipment and devices and associated wiring from walls, ceilings, floors, and other surfaces scheduled for remodeling, relocation, or demolition unless shown as retained or relocated on Drawings.
    - b. Provide temporary wiring and connections to maintain electrical continuity of existing systems during construction. Remove or relocate electrical boxes, conduit, wiring, equipment, and luminaires, as encountered in removed or remodeled areas in existing construction affected by this work.
    - c. Remove and restore wiring which serves usable existing outlets clear of construction or demolition.
    - d. If existing junction boxes will be made inaccessible, or if abandoned outlets serve as feed through boxes for other existing electrical

- equipment which is being retained, provide new conduit and wire to bypass inaccessible junction boxes and abandoned outlets.
- e. If existing conduits pass through partitions or ceiling which are being removed or remodeled, provide new conduit and wire to reroute clear of construction or demolition and maintain service to existing load.
  - f. Extend circuiting and devices in existing walls to be furred out.
  - g. Remove abandoned wiring to source of supply.
  - h. Remove exposed abandoned conduit, including abandoned conduit above accessible ceiling finishes. Cut conduit flush with walls and floors, and patch surfaces.
  - i. Disconnect abandoned outlets and remove devices. Remove abandoned outlets if conduit servicing them is abandoned and removed. Provide blank cover for abandoned outlets which are not removed.
  - j. Disconnect and remove abandoned panelboards and distribution equipment.
  - k. Disconnect and remove electrical devices and equipment serving utilization equipment that has been removed.
  - l. Existing lighting which is to remain, leave luminaires in proper working order.
  - m. Repair adjacent construction and finishes damaged during demolition work.
  - n. Maintain access to existing electrical installations which remain active. Modify installation or provide access panel as appropriate.

### **3.14 ACCEPTANCE**

- A. Confirm requirements in contract documents and the following:
  - 1. System cannot be considered for acceptance until work is completed and demonstrated to Design Builder that installation is in strict compliance with Specifications, Drawings and manufacturer's installation instructions, particularly in reference to following:
    - a. Cleaning
    - b. Operation and Maintenance Manuals
    - c. Training of Operating Personnel
    - d. Record Drawings
    - e. Warranty and Guaranty Certificates
    - f. Start-up/Test Document and Commissioning Reports

### **3.15 FIELD QUALITY CONTROL**

- A. Confirm Field Quality Control requirements in contract documents.
- B. Tests:
  - 1. Conduct tests of equipment and systems to demonstrate compliance with requirements specified. Reference individual Specification Sections for required tests. Document tests and include in operation and maintenance manuals.



2. During site evaluations by Design Builder, provide appropriate personnel with tools to remove and replace trims, covers, and devices so that proper evaluation of installation can be performed.

### **3.16 LETTER OF CONFORMANCE**

- A. Provide Letter of Conformance, copies of manufacturers' warranties and extended warranties with a statement that Electrical items were installed in accordance with manufacturer's recommendations, UL listings and FM Global approvals. Include Letter of Conformance, copies of manufacturers' warranties and extended warranties in Operation and Maintenance Manuals.

### **3.17 SALVAGED EQUIPMENT AND RECYCLED MATERIAL**

- A. Salvage the following equipment not being reused and return to Owner:
  1. Breakers
- B. Electrical equipment that cannot be salvaged for reuse sell/give to recycling company. Recycle following excess, removed, or demolished electrical material:
  1. Copper or aluminum conductors, buses, and motor/transformer windings.
  2. Steel and aluminum from raceways, boxes, enclosures, and housings.
  3. Acrylic and glass from luminaire lenses/refractors.
- C. Provide separate on-site storage space for recycled, recycled and salvaged, or salvaged material. Clearly label space.
- D. Confirm additional salvaged equipment and recycled materials in the Contract Documents.

**END OF DOCUMENT**

**DOCUMENT 26 05 09**  
**EQUIPMENT WIRING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Design Builder is responsible for the engineering, calculation, design, and installation of all upgrades to equipment wiring.
  - 2. Equipment grounding.

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**PART 2 - PRODUCTS**

**2.01 MATERIALS**

- A. Materials and Equipment for Equipment Wiring: As specified in individual Sections.

**2.02 GENERAL**

- A. Unless otherwise noted, the following voltage and phase characteristics apply to motors:
  - 1. 3/4 HP and Under: 120 volt, 1 phase.
  - 2. 1 HP and Over: 208 volt, 3 phase.
  - 3. 1 HP and Over: 480 volt, 3 phase.
- B. Safety Switches: Provide as required by NEC and as specified in Section 26 28 16, Enclosed Switches and Circuit Breakers.

**PART 3 - EXECUTION**

**3.01 EXAMINATION**

- A. Prior to submittal of product data for electrical distribution equipment, obtain and examine product data and shop drawings for equipment furnished by the Owner and by other trades on the project. Update the schedule of equipment electrical connections accordingly, noting proper ratings for overcurrent devices, fuses, safety disconnect

switches, conduit and wiring, and the like. As a minimum, this requirement applies to equipment furnished by Owner and equipment furnished under other divisions of work under this contract.

### **3.02 INSTALLATION**

- A. Do not install unrelated electrical equipment or wiring on mechanical equipment without prior approval of Owner.
- B. Provide moisture tight equipment wiring and switches in ducts or plenums used for environmental air.
- C. Connect motor and appliance/utilization equipment complete from panel to motor/equipment as required by code.
- D. Install motor starters and controllers for equipment furnished by others.
- E. Appliance/Utilization Equipment:
  - 1. Provide appropriate cable and cord cap for final connection unless equipment is provided with same. Provide receptacle configured to receive cord cap.
  - 2. Verify special purpose outlet NEMA configuration and ampere rating with equipment supplier prior to ordering wiring devices and coverplates.

### **3.03 FIELD QUALITY CONTROL**

- A. Perform field inspection and testing in accordance with Division 01, General Requirements.

### **3.04 SYSTEMS STARTUP**

- A. Provide field representative to prepare and start equipment.
  - 1. Test and correct for proper rotation of polyphase motors.
- B. Adjust for proper operation within manufacturer's published tolerances.
- C. Demonstrate proper operation of equipment to Owner's designated representative.

**END OF DOCUMENT**

**DOCUMENT 26 05 19**

**LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

A. Work Included:

1. Design Builder is responsible for the engineering, calculation, design, and installation of all upgrades to low-voltage wiring for all equipment in the project.
2. Wires and Cables
3. Connectors
4. Lugs and Pads

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

A. Wires and Cables:

1. Carol
2. General Cable
3. Okonite
4. Southwire
5. Alcan/Stabiloy
6. Nexans/Energex 8000
7. Raychem
8. Or approved equivalent.

B. Connectors:

1. Stranded conductors by Anderson.
2. Burndy
3. IlSCO
4. 3M

5. Thomas & Betts
6. Or approved equivalent.
- C. Splices:
  1. Branch Circuit Splices:
    - a. Ideal
    - b. Scotch-Lock
    - c. 3M
    - d. Or approved equivalent.
  2. Feeder Splices:
    - a. Compression barrel splice with two layers Scotch 23 and four layers of Scotch 33+ as vapor barrier.
    - b. Not allowed.
- D. Connectors:
  1. Construction:
    - a. T & B Series 60200
    - b. Or approved equivalent.
  2. Aluminum cable connection to mechanical lugs and equipment identified as not suitable for aluminum conductor termination:
    - a. T & B Series 61900
    - b. Or approved equivalent.
  3. Aluminum Cable Connection to Dry-Type Transformer Lugs:
    - a. Burndy Type YA-A-KIT Series
    - b. Or approved equivalent.
  4. Oxide-Inhibiting Joint Compounds:
    - a. PENETROX A-13
    - b. Or approved equivalent.
  5. Fluorescent Luminaire Disconnect:
    - a. Thomas & Betts Sta-Kon
    - b. Lithonia
    - c. Or approved equivalent.
- E. Lugs:
  1. Anderson
  2. IlSCO
  3. Panduit
  4. Thomas & Betts
  5. 3M
  6. Or approved equivalent.

## **2.02 WIRES AND CABLES**

- A. Copper, 600 volt rated throughout. Conductors 12 AWG and 10 AWG, solid or stranded. Conductors 8 AWG and larger, stranded. 12 AWG minimum conductor size. Minimum insulation rating of 90 degrees C. Insulation Type: THWN-2, XHHW-2 or THHN-2.

- B. Annealed copper, Class "B" strand, designed to ensure tensile strength under fire conditions. 2-hour fire-resistive cable. 600 volt rated throughout. Conductors 14 AWG and larger. Insulation type: Thermoset, low smoke zero halogen silicone rubber.
- C. Aluminum, 600 volt rated throughout. Conductors 4 AWG and larger, compact stranded. Aluminum Association 8000(AA-8000) Series alloy conductor material built to ASTM B801 specifications. Connectors and terminations to be those listed by Underwriters Laboratories Standard 486-B and marked "AL7CU" for 60C and 75C rated circuits. Connections and terminations to be installed strictly in accordance with manufacturers recommendations.
- D. Phase color to be consistent at feeder terminations; A-B-C, top to bottom, left to right, front to back.
- E. Color Code Conductors as Follows:

PHASE	208 VOLT WYE	240 VOLT DELTA	480 VOLT
A	Black	Black	Brown
B	Red	Orange (High Leg)	Orange
C	Blue	Blue	Yellow
Neutral	White	White	Gray or White w/colored strip
Ground	Green	Green	Green
Isolated Ground	Green w/yellow trace	N/A	N/A

- F. SO Cord: Annealed copper conductors, 600 volt rated. Minimum size No. 12 AWG with ground wire. Maximum of six conductors and ground per cable. 90 degrees C rated thermoset jacket.
- G. Service Entrance Cable: Copper conductor, 600 volt insulation, XHHW, Type SE.

## 2.03 CONNECTORS

- A. Copper Pads: Drilled and tapped for multiple conductor terminals.
- B. Lugs: Compression type for use with stranded branch circuit or control conductors; mechanical lugs for use with solid branch and feeder circuit conductors.
- C. Split bolt connectors not allowed.
- D. Aluminum Cable Compression Connections:
  - 1. Provide UL-listed compression lugs that are marked AL7CU or AL7CU and have passed UL 486B or UL 486C testing procedures.
  - 2. Construction: Electro tin plated high conductivity aluminum. Connector marked with wire size, die index, color-coded and the proper number and location of crimps. Factory pre-filled with oxide inhibiting compound.
  - 3. Aluminum cable connection to aluminum bus bar: Use 2-hole aluminum compression lug and aluminum hardware. Apply UL-listed lubricant to hardware and surfaces before tightening.
  - 4. Aluminum cable connection to copper bus bar: Use 2-hole aluminum compression lug, plated steel hardware and Belleville washer. Apply UL-listed lubricant to hardware and surfaces before tightening.

5. Aluminum cable connection to mechanical lugs and equipment identified as not suitable for aluminum conductor termination: Provide aluminum compression lug with stranded copper wire/cable pigtail. Equip lug compression body with insulating cover.
6. Aluminum cable connection to dry-type transformer lugs.
7. Aluminum Termination Hardware:
  - a. Bolts: Anodized alloy 2023-T4 and conforming to ANSI B18.2.1 and to ASTM B211 or B221 chemical and mechanical property limits.
  - b. Nuts: Aluminum alloy 6061-T6 or 6262-T9 and conforming to ANSI B18.2.2.
  - c. Washers: Flat aluminum alloy Alclad 2024-T4, Type A plain, standard wide series conforming to ANSI B27.2. SAE or narrow series washers are not permitted.
- E. Conductor Branch Circuits: Wire nuts with integral spring connectors for conductors 12 AWG through 8 AWG. Push-in type connectors where conductors are not required to be twisted together are not acceptable.
- F. Fluorescent Luminaire Disconnect: polycarbonate housing, tin-plated brass contacts, insulated 18 AWG, factory-installed solid copper leads, 105C temperature rating, UL94-V2 flammability, 4A, 600V. NEC Article 410 compliant. Finger-safe line side. Push-and-click connector.

## **2.04 LUGS AND PADS**

- A. Ampacity: Cross-Sectional area of pad for multiple conductor terminations to match ampere rating of panelboard bus or equipment line terminals.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Wires and Cables:
  1. Conductor Installation:
    - a. Install conductors in raceways having adequate, code size cross-Sectional area for wires indicated.
    - b. Install conductors with care to avoid damage to insulation.
    - c. Do not apply greater tension on conductors than recommended by manufacturer during installation.
    - d. Use of pulling compounds is permitted. Clean residue from exposed conductors and raceway entrances after conductor installation. Do not use pulling compounds for installation of conductors connected to GFCI circuit breakers or GFCI receptacles.
    - e. Do not use aluminum wire to make connections to mechanical equipment.
  2. Aluminum Conductor Splices, Joints and Terminations:
    - a. Join conductors using compression splice barrels or bolted compression lugs. Terminate conductors using compression lugs. Apply number of compression indents as directed by the manufacturer instructions.
  3. Conductor Size and Quantity:

- a. Install no conductors smaller than 12 AWG unless otherwise shown.
  - b. Provide required conductors for a fully operable system.
4. Provide dedicated neutrals (one neutral conductor for each phase conductor) in all 120V circuits
5. Conductors in Cabinets:
  - a. Cable and tree wires in panels and cabinets for power and control. Use plastic ties in panels and cabinets.
  - b. Tie and bundle feeder conductors in wireways of panelboards.
  - c. Hold conductors away from sharp metal edges.
6. Homeruns:
  - a. Do not change intent of branch circuit homeruns without approval. Homeruns for 20A branch circuits may be combined to a maximum of six current carrying conductors including neutral conductors in homeruns. Apply derating factors as required per NEC. Increase conductor size as needed.
7. Identify wire and cable under the provisions of Section 26 05 53, Identification for Electrical Systems. Identify each conductor with its panel and circuit number as indicated.
8. Use of MC Cable is limited to the following conditions. Installations that do not comply with the following conditions are to be removed and replaced with no additional expense to the Owner.
  - a. 20 and 30 amp branch wiring where following conditions apply:
    - 1) Where there is a suspended ceiling with accessible space above (example: suspended acoustic ceiling tile).
    - 2) For drops to ceiling mounted luminaires in areas with accessible ceiling space.
    - 3) In residential units where allowed by the NEC.
    - 4) Do not use for homeruns from branch circuit panel to first device or luminaire in circuit.
    - 5) Do not use in walls in areas where MC cable cannot be fished into the walls after construction is completed. For example: walls with glazing or solid beams overhead, partial height walls, etc.
    - 6) No single run of MC cable longer than 50-feet.
9. Exposed cable is not allowed.
10. Exposed cable must be run parallel or perpendicular to building lines and hidden from view when possible.

### 3.02 FIELD QUALITY CONTROL

- A. Test conductor insulation on feeders of 100 amp and greater for conformity with 1000 volt megohmmeter. Use Insulated Cable Engineers Association testing procedures. Minimum insulation resistance acceptable is 1 megohm for systems 600 volts and below. Notify Architect if insulation resistance is less than 1 megohm.
- B. Test Report: Prepare a typed tabular report indicating the testing instrument, the feeder tested, amperage rating of the feeder, insulation type, voltage, the approximate length of the feeder, conduit type, and the measured resistance of the megohmmeter test. Submit test reports with project closeout documents.



- C. Inspect and test in accordance with NETA Standard ATS, except Section 4.
- D. Perform inspections and tests listed in NETA Standard ATS, Section 7.3.2.

**END OF DOCUMENT**

**DOCUMENT 26 05 26**  
**GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Connectors and Accessories
  - 2. Grounding Conductor

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Grounding Connectors:
  - 1. Burndy Hyground Compression System
  - 2. Erico/Cadweld
  - 3. Amp Ampact Grounding System
  - 4. Or approved equivalent.
- B. Pipe Grounding Clamp:
  - 1. Burndy GAR Series
  - 2. O Z Gedney
  - 3. Thomas & Betts
  - 4. Or approved equivalent.

**2.02 CONNECTORS AND ACCESSORIES**

- A. Grounding Connectors: Hydraulic compression tool applied connectors or exothermic welding process connectors or powder actuated compression tool applied connectors.
- B. Pipe Grounding Clamp: Mechanical ground connector with cable parallel or perpendicular to pipe.

## **2.03 GROUNDING CONDUCTOR**

- A. Grounding Electrode Conductor: Soft-draw bare stranded copper for wire sizes larger than #10 AWG Bare. Solid copper for wire sizes #10 AWG and smaller.
- B. Equipment Grounding Conductor: Green insulated, insulation type to match that of associated feeder or branch circuit wiring, size as indicated on drawings.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Verify site conditions prior to beginning work.
- B. Verify that final backfill and compaction have been completed before driving rod electrodes.

### **3.02 INSTALLATION**

- A. Concrete-Encased Electrode ("Ufer ground"):
  - 1. From service equipment ground bus provide grounding electrode conductor to footing/foundation rebar.
  - 2. Bond #4 grounding electrode conductor to one minimum 20-foot long, 0.5-inch diameter independent steel rebar(s).
  - 3. Protect grounding electrode conductor from footing/foundation to service equipment grounding bus with rigid PVC conduit where grounding electrode conductor passes through concrete floor or other concrete structure. Do not use rigid metal conduit for grounding electrode conductor protection.
  - 4. Coordinate bonding of rebar in base of building concrete footing with installer prior to placement of concrete.
- B. Ground Rod Electrode:
  - 1. Bond #6 grounding electrode conductor to driven ground rods as indicated on Drawings.
  - 2. Tap at center ground rod and extend grounding electrode conductor to service grounding bus. Install grounding electrode conductor to service grounding bus in rigid PVC conduit for physical protection where grounding electrode conductor passes through concrete floor or other concrete structure.
- C. Metal Underground Water Service: Bond water service pipe to service equipment ground bus or to the grounding electrode system. Connect to water pipe on utility side of isolating fittings or meters, bond across water meters.
- D. Other Metal Piping Systems: Bond gas piping system, fire sprinkler piping system and other metal piping systems to service equipment ground bus or to the grounding electrode system.
- E. Raceways:
  - 1. Ground metallic raceway systems. Bond to ground terminal with code size jumper except where code size or larger equipment grounding conductor is included with circuit, use grounding bushing with lay-in lug.

2. Connect metal raceways, which terminate within an enclosure but without mechanical connection to enclosure, by grounding bushings and ground conductor to grounding bus.
  3. Where equipment supply conductors are in flexible metallic conduit, install stranded copper equipment grounding conductor from outlet box to equipment frame.
  4. Install equipment grounding conductor, code size minimum unless noted on drawings, in metallic and nonmetallic raceway systems.
- F. Feeders and Branch Circuits:
1. Provide continuous green insulated copper equipment grounding conductors for feeders and branch circuits.
  2. Where installed in a continuous solid metallic raceway system and larger sizes are not detailed, provide insulated equipment grounding conductors for feeders and branch circuits sized in accordance with the latest adopted edition of NEC Article 250, Table 250-122.
- G. Boxes, Cabinets, Enclosures and Panelboards:
1. Bond equipment grounding conductors to enclosure with specified conductors and lugs. Install lugs only on thoroughly cleaned contact surfaces.
  2. Bond Sections of service equipment enclosure to service ground bus.
- H. Motors, Equipment and Appliances: Install code size equipment grounding conductor to (motor) equipment frame or manufacturer's designated ground terminal.
- I. Receptacles: Connect ground terminal of receptacle and associated outlet box to equipment grounding conductor. Self grounding nature of receptacle devices does not eliminate equipment grounding conductor bolted to outlet box.
- J. Separately Derived Systems: Ground each separately derived system per NEC Article 250.
- K. Corrosion inhibitors: Apply a corrosion inhibitor to contact surfaces when making grounding and bonding connections. Use corrosion inhibitor appropriate for protecting a connection between metals used.

### 3.03 FIELD QUALITY CONTROL

- A. Grounding system resistance to ground not to exceed 5 ohms. Make necessary modifications or additions to grounding electrode system for compliance. Submit final tests to assure that this requirement is met.
- B. Resistance of grounding electrode system: measure using a four-terminal fall-of-potential method as defined in IEEE 81. Take ground resistance measurements before electrical distribution system is energized and in normally dry conditions, not less than 48 hours after last rainfall. Take resistance measurements of separate grounding electrode systems before systems are bonded together below grade. Combined resistance of separate systems may be used to meet required resistance, but specified number of electrodes must still be provided.
- C. Inspect and test in accordance with NETA Standard ATS, Except Section 4.

- D. Perform inspections and tests listed in NETA Standard AB, Section 7.13.

**END OF DOCUMENT**

**DOCUMENT 26 05 29**

**HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Hangers, Supports, Anchors, Threaded Rod and Fasteners
  - 2. Support Channel
  - 3. Rooftop Conduit Supports

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.
- B. In addition, meet the following:
  - 1. Manufacturers regularly engaged in the manufacture of bolted metal framing support systems, whose products have been in satisfactory use in similar service for not less than 10 years.
  - 2. Support systems to be supplied by a single manufacturer.
  - 3. Engineering Responsibility: Design and preparation of Shop Drawings and calculations for each multiple pipe support, trapeze, equipment hangers/supports, and seismic restraint by a qualified Structural Professional Engineer.
    - a. Professional Engineer Qualifications: A professional engineer who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing engineering services of the kind indicated. Engineering services are defined as those performed for installations of hangers and supports that are similar to those indicated for this Project in material, design, and extent.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**1.07 PERFORMANCE REQUIREMENTS**

- A. General: Provide conduit and equipment hangers and supports in accordance with the following:

1. When supports, anchorages, and seismic restraints for equipment and supports, anchorages and seismic restraints for conduit, cable tray and equipment are not shown on the Drawings, the Contractor is responsible for their design.
2. Connections to structural framing shall not introduce twisting, torsion, or lateral bending in the framing members. Provide supplementary steel as required.
- B. Engineered Support Systems: The following support systems to be designed, detailed, and bear the seal of a professional engineer registered in the State of California.
  1. Support frames such as conduit racks or stanchions for conduit and equipment which provide support from below.
  2. Equipment and piping support frame anchorage to supporting slab or structure.
- C. Provide channel support systems, for conduits to support multiple conduits capable of supporting combined weight of support systems and system contents.
- D. Provide heavy-duty steel trapezes for piping to support multiple conduit capable of supporting combined weight of supported systems and system contents.
- E. Provide seismic restraint hangers and supports for conduit and equipment.
- F. Obtain approval from AHJ for seismic restraint hanger and support system to be installed for piping and equipment.

## **PART 2 - PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Support Channel:
  1. B-Line
  2. Kindorf
  3. Superstrut
  4. Unistrut
  5. Or approved equivalent.
- B. Anchors:
  1. Anchor It
  2. Epcon System
  3. Hilti-Hit System
  4. Power Fast System
  5. Or approved equivalent.
- C. Rooftop Supports:
  1. Cooper B-Line Dura-Block Rooftop Support Base
  2. Or approved equivalent.

### **2.02 MATERIALS**

- A. Hangers, Supports, Anchors, Threaded Rod and Fasteners - General: Corrosion-resistant materials of size and type adequate to carry the loads of equipment and conduit, including weight of wire in conduit.
  1. Channel Material: Carbon steel.
  2. Coating: Hot dip galvanized.

- B. Concrete Inserts: Cast in concrete for support fasteners for loads up to 800 lbs.
- C. Pipe Straps: Two-hole galvanized or malleable iron.
- D. Luminaire Chain: 90 lb. test with steel hooks.
- E. Anchor Bolts for Area Luminaire Poles: As supplied by area luminaire pole manufacturer.
- F. Anchors and Fasteners:
  - 1. Do not use powder-actuated anchors.
  - 2. Obtain permission from Design Builder before using powder-actuated anchors.
  - 3. Concrete Structural Elements: Use precast inserts.
  - 4. Steel Structural Elements: Use beam clamps.
  - 5. Concrete Surfaces: Use self-drilling anchors.
  - 6. Hollow Masonry, Plaster, and Gypsum Board Partitions: Use toggle bolts.
  - 7. Solid Masonry Walls: Use expansion anchors.
  - 8. Sheet Metal: Use sheet metal screws.
  - 9. Wood Elements: Use wood screws.
- G. Rooftop Conduit Supports:
  - 1. Curb base made of 100 percent recycled rubber and polyurethane prepolymer with a uniform load
  - 2. Capacity of 500 pounds per linear foot of support.
  - 3. UV resistant.
  - 4. Steel Frame: Steel, 14 gauge strut galvanized per ASTM A653 or 12 gauge strut galvanized per ASTM A653 for bridge series.
  - 5. Continuous block channel supports with 1-inch gaps to allow water flow, bridge channel supports, extendable height channel supports and elevated single conduit supports.
  - 6. Attaching Hardware: Zinc-plated threaded rod, nuts and attaching hardware per ASTM B633 fastened directly into rubber material with weather resistant Type 12 lag screws.
  - 7. Provide load distribution plates when required for heavy loads.
  - 8. Finish: Black with safety yellow striping.

## **2.03 MISCELLANEOUS METAL**

- A. Miscellaneous Metal: Provide miscellaneous metal items specified hereunder, including materials, fabrication, fastenings and accessories required for finished installation, where indicated on Drawings or otherwise not shown on drawings that are necessary for completion of the project. The Contractor is responsible for their design.
  - 1. Fabricate miscellaneous units to size shapes and profiles indicated or, if not indicated, of required dimensions to receive adjacent other work to be retained by framing. Except as otherwise shown, fabricate from structural steel shapes and plates and steel bars, of welded construction using mitered joints for field connection. Cut, drill and tap units to receive hardware and similar items.



- B. Structural Shapes: Where miscellaneous metal items are needed to be fabricated from structural steel shapes and plates, provide members constructed of steel conforming with requirements of ASTM A36 or approved equivalent.
- C. Steel Pipe: Provide seamless steel pipe conforming to requirements of ASTM A53, Type S, Grade A, or Grade B. Weight and size required as specified.
- D. Fasteners: Provide fasteners of types as required for assembly and installation of fabricated items; surface-applied fasteners are specified elsewhere.
- E. Bolts: Low carbon steel externally and internally threaded fasteners conforming with requirements of ASTM A307; include necessary nuts and plain hardened washers. For structural steel elements supporting mechanical material or equipment from building structural members or connection thereto, use fasteners conforming to ASTM A325.
- F. Miscellaneous Materials: Provide incidental accessory materials, tools, methods, and equipment required for fabrication.
- G. Provide hot dipped galvanized components for items exposed to weather.

### **PART 3 - EXECUTION**

#### **3.01 INSTALLATION**

- A. Install hangers and supports as required to adequately and securely support electrical system components, in a neat and workmanlike manner, as specified in NECA 1.
- B. Safety factor of 4 required for every fastening device or support for electrical equipment installed. Supports to withstand four times the weight of equipment it supports.
- C. Verify mounting height of luminaires prior to installation when heights are not detailed.
- D. Install vertical support members for equipment and luminaires, straight and parallel to building walls.
- E. Install horizontal support members straight and parallel to ceilings or finished floor unless otherwise noted.
- F. Provide independent supports to structural member for electrical luminaires, materials, or equipment installed in or on ceiling, walls or in void spaces or over suspended ceilings.
- G. Do not use other trade's fastening devices as supporting means for electrical luminaires, equipment or materials.
- H. Do not fasten supports to pipes, ducts, mechanical equipment, or conduit.
- I. Do not use supports or fastening devices to support other than one particular item.
- J. Support conduits within 18-inches of outlets, boxes, panels, cabinets and deflections unless more stringently required by CEC.
- K. Maximum distance between supports not to exceed 8 foot spacing unless otherwise required by CEC.

- L. Support flexible conduits within 12-inches of outlets, boxes, panels, cabinets and deflections unless otherwise required by CEC.
- M. Maximum distance between supports for flexible conduits not to exceed 48-inches spacing unless otherwise required by CEC.
- N. Maximum distance between supports for rigid PVC conduits unless otherwise required by CEC is as follows:
  - 1. 1/2-inch or 3/4-inch and 1-inch conduit, 3-feet apart.
  - 2. 1-1/4-inch or 1-1/2-inch and 2-inch conduit, 4-feet apart.
  - 3. 2-1/2-inch and 3-inch conduit, 5-feet apart.
  - 4. 4-inch and 5-inch conduit, 6-feet apart.
  - 5. 6-inch conduit, 7-feet apart.
- O. Maximum distance between supports for auxiliary gutters and wireways unless otherwise required by CEC is as follows:
  - 1. Sheet metal auxiliary gutters and wireways - 4-feet apart horizontally and 10-feet vertically.
  - 2. Non-metallic auxiliary gutters and wireways - 30-inches apart horizontally and 3-feet vertically.
- P. Install strut hangers as instructed by strut manufacturer. Suspended strut hangers as instructed by strut manufacturer for the load, with a maximum spacing of 8-feet on center and within 2-feet of outlet box, cabinet, junction box or other channel raceway termination unless otherwise required by CEC.
- Q. Coordinate routing of conduit racks with materials and equipment installed by other trades. Where conduit racks are exposed to view, coordinate location and installation with Design Builder for optimal appearance.
- R. Securely suspend junction boxes, pull boxes or other conduit terminating housings located above suspended ceiling from floor above or roof structure to prevent sagging and swaying.
- S. Provide seismic bracing per CBC requirements.
- T. Where service disconnects are mounted on building exterior, physically attach service disconnect to the building or structure served.
- U. Install surface-mounted cabinets and panelboards with minimum of four anchors.
- V. Use sheet metal channel to bridge studs above and below cabinets and panelboards recessed in hollow partitions.
- W. Use spring lock washers under fastener nuts for strut.

### **3.02 CUTTING AND DRILLING**

- A. Do not drill or cut structural members without prior permission from Design Builder.

### **3.03 WET AND DAMP LOCATIONS**

- A. In wet and damp locations use steel channel supports to stand cabinets and panelboards 1-inch off wall.

### 3.04 ROOFTOP SUPPORTS

- A. Consult roofing manufacturer for roof membrane compression capacities. If necessary, provide a compatible sheet of roofing material (rubber pad) under rooftop support to disperse concentrated loads and add further membrane protection.
- B. Do not use supports that will void roof warranty.
- C. Install supports per manufacturer's instructions and recommendations.
- D. Use properly sized clamps to suit conduit sizes.
- E. Install supports for rooftop raceways to raise raceways a minimum of 4-inches above the roof structure unless otherwise noted.

### 3.05 FABRICATION - MISCELLANEOUS METALS

- A. General: Verify dimensions prior to fabrication. Form metal items to accurate sizes and configurations as indicated on Drawings and otherwise required for proper installation; make with lines straight and angles sharp, clean and true; drill, countersink, tap, and otherwise prepare items for connections with work of other trades, as required. Fabricate to detail of structural shapes, plates and bars; weld joints where practicable; provide bolts and other connection devices required. Include anchorages; clip angles, sleeves, anchor plates, and similar devices. Hot dipped galvanize after fabrication items installed in exterior locations. Set accurately in position as required and anchor securely to building construction. Construct items with joints formed for strength and rigidity, accurately machining for proper fit; where exposed to weather, form to exclude water.
- B. Finishes:
  - 1. Ferrous Metal: After fabrication, but before erection, clean surfaces by mechanical or chemical methods to remove rust, scale, oil, corrosion, or other substances detrimental to bonding of subsequently applied protective coatings. For metal items exposed to weather or moisture, galvanize in manner to obtain G90 zinc coating in accordance with ASTM A123. Provide other non-galvanized ferrous metal with one coat of approved rust-resisting paint primer, in manner to obtain not less than 1.0 mil dry film thickness. Touch-up damaged areas in primer with same material, before installation. Apply zinc coatings and paint primers uniformly and smoothly; leave ready for finish painting as specified elsewhere.
  - 2. Metal in contact with Concrete, Masonry and Other Dissimilar Materials: Where metal items are to be erected in contact with dissimilar materials, provide contact surfaces with coating of an approved zinc-chromate primer in manner to obtain not less than 1.0 mil dry film thickness, in addition to other coatings specified in these specifications.
  - 3. For Galvanized Surfaces: Clean field welds, bolted connections, and abraded areas and apply galvanizing repair paint to comply with ASTM A780.

**END OF DOCUMENT**

**DOCUMENT 26 05 33**

**RACEWAYS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Rigid Metal Conduit (RMC)
  - 2. Rigid Aluminum Conduit
  - 3. Electrical Metallic Tubing (EMT)
  - 4. Liquidtight Flexible Metal Conduit (LFMC)
  - 5. Conduit Fittings
- B. Provide a complete system of conduit and fittings, with associated couplings, connectors, and fittings, as shown on drawings and described in these specifications.

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**1.07 DEFINITIONS**

- A. Raceway system is defined as consisting of conduit, tubing, duct, and fittings including but not limited to connectors, couplings, offsets, elbows, bushings, expansion/deflection fittings, and other components and accessories. Complete electrical raceway installation before starting the installation of conductors and cables.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Rigid Metal Conduit (RMC):
  - 1. Allied Tube & Conduit
  - 2. Beck Manufacturing Inc.
  - 3. Picoma
  - 4. Wheatland Tube Company
  - 5. Or approved equivalent.
- B. Rigid Aluminum Conduit:

1. Allied Tube & Conduit
  2. Beck Manufacturing WL
  3. Picoma
  4. Wheatland Tube Company
  5. Or approved equivalent.
- C. Electrical Metallic Tubing (EMT):
1. Allied Tube & Conduit
  2. Beck Manufacturing WL
  3. Picoma
  4. Wheatland Tube Company
  5. Or approved equivalent.
- D. Liquidtight Flexible Metal Conduit (LFMC):
1. AFC Cable Systems Inc.
  2. Electri-Flex Company
  3. International Metal Hose
  4. Or approved equivalent.
- E. Conduit Fittings:
1. Bushings:
    - a. Insulated Type for Threaded Rigid IMC Conduit Without Factory Installed Plastic Throat Conductor Protection:
      - 1) Thomas & Betts 1222 Series
      - 2) O-Z Gedney B Series
      - 3) Or approved Equivalent.
  2. Insulated Grounding Type for Threaded Rigid IMC Conduit:
    - a. O-Z Gedney BLG Series
    - b. Or approved Equivalent.
  3. Expansion/Deflection Fittings:
    - a. EMT, O-Z Gedney Type TX
    - b. RMC, O-Z Gedney Type AX, DX and AXDX, Crouse & Hinds XD
    - c. Or approved equivalent.

## **2.02 RIGID METAL CONDUIT (RMC)**

- A. UL 6, ANSI C80.1. Hot dipped galvanized steel conduit after thread cutting.
1. Fittings: NEMA FB2.10.

## **2.03 RIGID ALUMINUM CONDUIT**

- A. ANSI C80.5. Threaded at each connection.

## **2.04 ELECTRICAL METALLIC TUBING (EMT)**

- A. Description: UL 797, ANSI C80.3; steel galvanized tubing.
- B. Fittings: NEMA FB 1; steel, compression type.

## **2.05 LIQUIDTIGHT FLEXIBLE METAL CONDUIT (LFMC)**

- A. Description: UL 360, inner core made from spiral wound strip of heavy gauge, hot dipped galvanized low carbon steel. 3/4-inch through 1-1/4-inch trade sizes have a

square lock core and contain an integral bonding strip of copper. 1-1/2-inch and larger have fully interlocked core. Jacket material is moisture, oil and sunlight resistant flexible PVC.

B. Fittings: NEMA FB 2.20.

## **2.06 CONDUIT FITTINGS**

A. Bushings:

1. Insulated type for threaded rigid IMC conduit without factory installed plastic throat conductor protection.
2. Insulated grounding type for threaded rigid IMC conduit.

B. Raceway Connectors and EMT Couplings:

1. Steel connectors, couplings, and conduit bodies, with hot-dip galvanized.
2. Connector locknuts are steel, with threads meeting ASTM tolerances. Locknuts are hot-dip galvanized.
3. Connector throats (EMT, flexible conduit, metal clad cable and cordset connectors) have factory installed plastic inserts permanently installed. For normal cable or conductor exiting angles from raceway, the cable jacket or conductor insulation bears only on plastic throat insert.
4. Steel gland, Tomic or Breagle connectors and couplings are recognized for this Contract as having acceptable raceway to fitting electrical conductance.
5. Set screw connectors and couplings, without integral compression glands, are recognized for this contract as not having acceptable raceway to fitting electrical conductance. A ground conductor sized per this Specification must be included and bonded within raceway assembly utilizing this type connector or coupling.

C. Provide expansion/deflection fittings for RMC.

## **PART 3 - EXECUTION**

### **3.01 SEQUENCING AND SCHEDULING**

A. Finished Surfaces: Schedule raceway installation to avoid conflict with installed wall and ceiling surfaces. If unavoidable, coordinate work and repairs with Design Builder.

### **3.02 CONDUIT REQUIREMENTS**

A. Conduit Size:

1. Minimum Size: 1/2-inch for power and control, unless otherwise noted. 3/4-inch for communication/data, unless otherwise noted. 1/2-inch for signal systems, unless otherwise noted.

B. Outdoor Locations Above Grade: Use RMC.

C. In Slab Above Grade:

1. Use PVC.
2. Maximum Size Conduit in Slab: Contact Structural Engineer for maximum outside diameter of conduit.

D. Damp Locations: RMC up to 2-inches in diameter.

E. Dry Locations:

1. Concealed: EMT.
2. Exposed: RMC.
- F. Dry, Protected: EMT.
- G. In areas exposed to severe mechanical damage: RMC.
- H. For security conduits installed exposed and subject to tampering: RMC.
- I. In hazardous areas per CEC 501: RMC.
- J. Provide two pull strings/tapes in empty conduits. Types:
  1. Utility Company Conduit: Polyester measure/pulling tape, Greenlee 4436 or approved equivalent. Coordinate exact requirements with utility company.
  2. Feeders: Polyester measure/pulling tape, Greenlee 4436 or approved.
  3. Branch circuits and low voltage: Greenlee Poly Line 431 or approved.
  4. If fish tape is used for pulling line or low voltage wiring, fiberglass type to be used. Metal fish tapes will not be allowed.
  5. Secure pull string/tape at each end.
  6. Provide caps on ends of empty conduit to be used in future.
  7. Label both ends of empty conduits with location of opposite end.
- K. Elbow for Low Energy Signal Systems: Use long radius factory ells where linking sections of raceway for installation of signal cable.
- L. Elbow for Medium Voltage Systems: Use long radius factory ells where linking sections of raceway per NEC Article 300.34.
- M. Use PVC coated RMC 36-inch radius ells for power service conduits and 48-inch radius ells for telephone service conduits.
- N. For Dry Areas: Motors, recessed luminaires and equipment connections subject to movement or vibration, use flexible metallic conduit.
- O. Motors and equipment connections subject to movement or vibration and subjected to any of following conditions; exterior location, moist or humid atmosphere, water spray, oil, or grease use PVC coated liquidtight flexible metallic conduit.

### **3.03 EXAMINATION**

- A. Verify that field measurements are as shown on drawings.
- B. Plan locations of conduit runs in advance of the installation and coordinate with ductwork, plumbing, ceiling and wall construction in the same areas.
- C. Locate penetrations and holes in advance where they are proposed in the structural sections such as footings, beams, and walls. Penetrations are acceptable only when the following occurs:
  1. Where shown on the structural drawings.
  2. As approved by the Structural Engineer prior to construction, and after submittal of drawing showing location, size, and position of each penetration.
- D. Verify routing and termination locations of conduit prior to rough-in.
- E. Conduit routing is shown on drawings in approximate locations unless dimensioned. Route as required to complete wiring system.

### **3.04 INSTALLATION**

- A. Install raceways securely, in neat and workmanlike manner, as specified in NECA 1, Standard Practices for Good Workmanship in Electrical Construction.
- B. Install steel conduit as specified in NECA 101, Standard for Installing Steel Conduits.
- C. Install nonmetallic conduit in accordance with manufacturer's instructions.
- D. Inserts, anchors and sleeves.
  - 1. Coordinate location of inserts and anchor bolts for electrical systems prior to concrete pour.
  - 2. Coordinate location of sleeves with consideration for other building systems prior to concrete pour.
- E. Conduit Supports:
  - 1. Arrange supports to prevent misalignment during wiring installation.
  - 2. Support conduit using coated steel or malleable iron straps, lay-in adjustable hangers, clevis hangers, and split hangers.
  - 3. Group related conduits; support using conduit rack. Construct rack using steel channel. Provide space on each for 25 percent additional conduits.
  - 4. Do not support conduit with wire or perforated pipe straps. Remove wire used for temporary supports.
  - 5. Do not attach conduit to ceiling support wires.
- F. Flexible steel conduit length not-to-exceed 6-feet, 3-feet in concealed walls. Provide sufficient slack to reduce the effect of vibration.
- G. Install conduit seals at boundaries where ambient temperatures differ by 10 degrees F or more as shown on the drawings. Install seals on warm side of partition.
- H. Seal raceways stubbing up into electrical equipment. Plug raceways with conductors with duct-seal. Cap spare raceways and plug PVC raceway products with plastic plugs as made by Underground Products, or equal, shaped to fit snugly into the stubup.
- I. Seal raceways penetrating an exterior building wall to prevent moisture and vermin from entering into the electrical equipment.
- J. Use suitable caps on spare and empty conduits to protect installed conduit against entrance of dirt and moisture.
- K. Only conduit servicing elevator equipment can be installed through elevator shafts or equipment rooms. These conduits may only enter the room and go directly to the equipment being supplied.
- L. Keep 277/480 volt wiring independent of 120/208 volt wiring, and power wiring. Keep power wiring independent of communication system wiring.
- M. Keep emergency system wiring independent of other wiring systems per NEC 700.
- N. Installation of conduit in structural concrete that is less than 3-inches thick is prohibited without the approval of the Structural Engineer. Maintenance pads, and curbs are exempted.
- O. Conduit Joints: Assemble conduits continuous and secure to boxes, panels, luminaires and equipment with fittings to maintain continuity. Provide watertight joints where



- embedded in concrete, below grade or in damp locations. Seal PVC conduit joints with solvent cement and metal conduit with metal thread primer. Rigid conduit connections to be threaded, clean and tight (metal to metal). Threadless connections are not permitted for RMC and IMC. Seal conduits where penetrating below raised floor area.
- P. Join nonmetallic conduit using cement as recommended by manufacturer. Wipe nonmetallic conduit dry and clean before joining. Apply full even coat of cement to entire area inserted in fitting. Allow joint to cure for 20 minutes, minimum.
  - Q. Arrange conduit to maintain headroom and present neat appearance.
  - R. Do not install conduits on surface of building exterior, along vapor barrier, across roof, on top of parapet walls, or across floors, unless otherwise noted on drawings.
  - S. Exposed conduits are permitted only in following areas:
    - 1. Mechanical rooms, electrical rooms or spaces where walls, ceilings and floors will not be covered with finished material.
    - 2. Existing walls that are concrete or block construction.
    - 3. Where specifically noted on Drawings.
    - 4. Route exposed conduit parallel and perpendicular to walls, tight to finished surfaces and neatly offset into boxes.
  - T. Do not install conduits or other electrical equipment in obvious passages, doorways, scuttles or crawl spaces which would impede or block area passage's intended usage.
  - U. Install continuous conduit and raceways for electrical power wiring.
  - V. Route conduit installed above accessible ceilings parallel and perpendicular to walls.
  - W. Maintain adequate clearance between conduit and piping.
  - X. Keep conduits a minimum of 12-inches away from steam or hot water radiant heating lines (at or above 104 degrees F) or 3-inches away from waste or water lines.
  - Y. Cut conduit square using saw or pipecutter; deburr cut ends.
  - Z. Bring conduit to shoulder of fittings; fasten securely.
  - AA. Use conduit hubs to fasten conduit to cast boxes in damp and wet locations.
  - AB. Install no more than the equivalent of three 90 degree bends between boxes. Use conduit bodies to make sharp changes in direction, as around beams. Use hydraulic one shot bender to fabricate factory elbows for bends in metal conduit larger than 2-inch size.
  - AC. Avoid moisture traps; provide junction box with drain fitting at low points in conduit system.
  - AD. Provide suitable fittings to accommodate expansion and deflection where conduit crosses seismic, control, and expansion joints.
  - AE. Conduit Terminations for Signal Systems: Provide a plastic bushing on the end of conduit used for signal system wiring.
  - AF. Flexible Conduit: Install 12-inch minimum slack loop on flexible metallic conduit and liquidtight flexible metallic conduit.
  - AG. Feeders: Do not combine or change feeder runs.

### **3.05 CONDUIT FITTINGS**

- A. Use set screw type fittings only in dry locations. When set screw fittings are utilized provide insulated continuous equipment ground conductor in conduit, from overcurrent protection device to outlet.
- B. Use compression fittings in dry locations, damp and rain-exposed locations. Maximum size permitted in damp locations and locations exposed to rain is 2-inches in diameter.
- C. Use threaded type fittings in wet locations, and damp or rain-exposed locations where conduit size is greater than 2-inches.
- D. Use PVC coated RMC 36-inch radius ells for power service conduits and 48-inch radius ells for telephone service conduits.
- E. Use insulated type bushings with ground provision at switchboards, panelboards, safety disconnect switches, junction boxes that have feeders 60 amperes and greater.
- F. Condulets and Conduit Bodies:
  - 1. Do not use condulets and conduit bodies in conduits.
  - 2. Do not use condulets and conduit bodies.
- G. Sleeves and Chases - Floor, Ceiling and Wall Penetrations: Provide necessary rigid conduit sleeves, openings and chases where conduits or cables are required to pass through floors, ceilings or walls.
- H. Expansion Joints:
  - 1. Provide conduits crossing expansion joints where cast in concrete with expansion-deflection fittings, equivalent to OZ/Gedney AXDX, installed per manufacturer's recommendations.
  - 2. Secure conduits 3-inches and larger to building structure on opposite sides of a building expansion joint with an expansion-deflection fitting across joint installed per manufacturer's recommendations.
  - 3. Provide conduits less than 3-inches where not cast in concrete with junction boxes securely fastened on both sides of expansion joint, connected together with 15-inches of slack (minimum of 15-inches longer than straight line length) flexible conduit and copper green ground bonding jumper. In lieu of this flexible conduit, an expansion-deflection fitting, as indicated for conduits 3-inch and larger may be installed.
  - 4. Verify expansion/deflection requirements with Structural Engineer prior to installation.
- I. Seismic Joints:
  - 1. No conduits cast in concrete allowed to cross seismic joint.
  - 2. Provide conduits with junction boxes securely fastened on both sides of seismic joint, connected together with 15-inches of slack (minimum of 15-inches longer than straight line length) flexible conduit and copper green ground bonding jumper. Prior to installation, verify with Design Builder that 15-inches is adequate for designed movement, and if not, increase this length as required.
  - 3. Provide conduits less than 3-inches where not cast in concrete with junction boxes securely fastened on both sides of expansion joint, connected together with 15-

inches of slack (minimum of 15-inches longer than straight line length) flexible conduit and copper green ground bonding jumper. In lieu of this flexible conduit, an expansion-deflection fitting, as indicated for conduits 3-inch and larger may be installed.

- J. Provide rigid conduit coupling flush with surface of slab or wall for conduit stubbed in concrete slab or wall to serve electrical equipment or an outlet under table or to supply shop tool, etc. Provide plug where conduit is to be used in future.

### **3.06 INTERFACE WITH OTHER PRODUCTS**

- A. Install conduit to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Division 07, Thermal and Moisture Protection.
- B. Route conduit through roof openings for piping and ductwork wherever possible. Where separate roofing penetration is required, coordinate location and installation method with roofing installation and installer.

**END OF DOCUMENT**

**DOCUMENT 26 05 34**

**BOXES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Outlet Boxes
  - 2. Pull and Junction Boxes
  - 3. Conduit Fittings
  - 4. Weatherproof Outlet Boxes
- B. Provide electrical boxes and fittings for a complete installation. Include but not limited to outlet boxes, junction boxes, pull boxes, bushings, locknuts and other necessary components.

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Outlet Boxes:
  - 1. Bowers
  - 2. Hubbell
  - 3. Racor
  - 4. Steel City
  - 5. Thomas & Betts
  - 6. Or approved equivalent.
- B. Pull and Junction Boxes:
  - 1. B-Line
  - 2. Hoffman
  - 3. Or approved equivalent.
- C. Conduit Fittings:
  - 1. Killark

2. O-Z Gedney
  3. Raco
  4. Steel City
  5. Thomas & Betts
  6. Or approved equivalent.
- D. Weatherproof Outlet Boxes:
1. Pass and Seymour
  2. Bell
  3. Red Dot
  4. Carlon
  5. Or approved equivalent.

## **2.02 OUTLET BOXES**

- A. Luminaire Outlet: 4-inch octagonal box, 1-1/2-inches deep with 3/8-inch luminaire stud if required. Provide raised covers on bracket outlets and on ceiling outlets.
- B. Device Outlet: Installation of one or two devices at common location, minimum 4-inches square, minimum 1-1/2-inches deep. Single- or two-gang flush device raised covers.
- C. Telecom Outlet: Provide 4-inches square, minimum 2-1/8-inch deep box with two-gang plaster ring.
- D. Multiple Devices: Three or more devices at common location. Install one-piece gang boxes with one-piece device cover. Install one device per gang.
- E. Masonry Boxes: Outlets in concrete.
- F. Construction: For interior locations, provide galvanized steel outlet wiring boxes, of the type, shape and size, including depth of box, to suit each respective location and installation; constructed with stamped knockouts in back and sides, and with threaded holes with screws for securing box covers or wiring devices.
- G. Accessories: Provide outlet box accessories for each installation, including mounting brackets, wallboard hangers, extension rings, luminaire studs, cable clamps and metal straps for supporting outlet boxes, compatible with outlet boxes being used and meeting requirements of individual wiring situations.
- H. Noise Control: Provide acoustic putty pad to back side of each outlet box installed in acoustic rated walls.

## **2.03 PULL AND JUNCTION BOXES**

- A. Construction: Provide ANSI 49 gray enamel painted sheet steel junction and pull boxes, with screw-on covers; of type shape and size, to suit each respective location and installation; with welded seams and equipped with stainless steel nuts, bolts, screws and washers.
- B. Location:
  1. Provide junction boxes above accessible ceilings for drops into walls for receptacle outlets from overhead.

2. Provide junction boxes and pull boxes to facilitate installation of conductors and limiting accumulated angular sum of bends between boxes, cabinets and appliances to 270 degrees.

#### **2.04 CONDUIT FITTINGS**

- A. Requirements: Provide corrosion-resistant punched-steel box knockout closures, conduit locknuts and plastic conduit bushings of the type and size to suit each respective use and installation.

#### **2.05 WEATHERPROOF OUTLET BOXES**

- A. Construction: Provide corrosion-resistant cast metal weatherproof outlet wiring boxes, of the type, shape and size, including depth of box, with threaded conduit ends, cast metal faceplate with spring-hinged waterproof cap suitably configured for each application, including faceplate, gasket, blank plugs and corrosion proof fasteners. Weatherproof boxes to be constructed to have smooth sides, gray finish.

### **PART 3 - EXECUTION**

#### **3.01 EXAMINATION**

- A. Coordinate locations of floor boxes and wall mounted wiring device boxes with architectural and structural floor plans prior to rough-in.

#### **3.02 INSTALLATION**

- A. Install boxes securely, in a neat and workmanlike manner, as specified in NECA 1, Standard Practice of Good Workmanship in Electrical Construction.
- B. Secure boxes rigidly to substrate upon which they are being mounted, or solidly embed boxes in concrete or masonry.
- C. Install in locations as shown on Drawings, and as required for splices, taps, wire pulling, equipment connections, and as required by NFPA 70. Locate boxes and conduit bodies so as to ensure accessibility of electrical wiring.
- D. Set wall mounted boxes at elevations to accommodate mounting heights shown on Architectural Elevations.
- E. Electrical boxes are shown on Drawings in approximate locations unless dimensioned.
  1. Adjust box locations up to 10-feet if required to accommodate intended purpose.
- F. Mount outlet boxes, unless otherwise required by ADA, or noted on drawings, following distances above finished floor:
  1. Control Switches:
    - a. 48-inches to the top of outlet box.
    - b. 4-inches above top of backsplash at countertops/workstations, not-to-exceed 44-inches above finished floor to the top of outlet box per ADA requirements.
  2. Receptacles: 15-inches to the bottom of outlet box.
  3. Other Outlets: As indicated in other Sections of specifications or as detailed on drawings.
- G. Install pull boxes and junction boxes above accessible ceilings and in unfinished areas only.

- H. Inaccessible Ceiling Areas: Install outlet and junction boxes no more than 6-inches from ceiling access panel or from removable recessed luminaire.
- I. Flush Outlets in Insulated Spaces: Maintain integrity of insulation and vapor barrier.
- J. Install boxes to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Division 07, Thermal and Moisture Protection.
- K. Coordinate electrical device locations and elevations (switches and receptacles) with architectural drawings to prevent mounting devices in mirrors, back splashes, and behind cabinets.
- L. Locate outlet boxes to allow luminaires positioned as shown on reflected ceiling plan.
- M. Align adjacent wall mounted outlet boxes for switches, thermostats, and similar devices. Adjacent boxes not aligned vertically to be adjusted at no additional cost to Owner.
- N. Use flush mounting outlet box in finished areas.
- O. Locate flush mounting box in masonry wall to require cutting of masonry unit corner only. Coordinate masonry cutting to achieve neat opening.
- P. Do not install flush mounting box back-to-back in walls; provide minimum 6-inches separation. Provide minimum 24-inches in acoustic rated walls.
- Q. Apply acoustic putty pad on outlet box prior to installation of acoustical blanket.
- R. Secure flush mounting box to interior wall and partition studs. Accurately position to allow for surface finish thickness.
- S. Use stamped steel bridges to fasten flush mounting outlet box between studs.
- T. Install flush mounting box without damaging wall insulation or reducing its effectiveness.
- U. Use adjustable steel channel fasteners for hung ceiling outlet box.
- V. Do not fasten boxes to ceiling support wires.
- W. Support boxes independently of conduit, except cast box that is connected to two rigid metal conduits both supported within 12-inches of box.
- X. Use gang box where more than one device is mounted together. Do not use Sectional box.
- Y. Use gang box with plaster ring for single device outlets.
- Z. Use cast outlet box in exterior locations exposed to the weather and wet locations.
- AA. Large Pull Boxes: Use hinged enclosure in interior dry locations, surface-mounted cast metal box in other locations.
- AB. Box Color Coding and Marking: Reference Section 26 05 53, Identification for Electrical Systems.

### 3.03 ADJUSTING

- A. Adjust floor boxes flush with finish flooring material.
- B. Adjust flush-mounting outlets to make front flush with finished wall material.

- C. Adjust boxes to be parallel with building lines. Boxes not plumb to building lines are not acceptable.
- D. Install knockout closures in unused box openings.

**3.04 CLEANING**

- A. Clean interior of boxes to remove dust, debris, and other material.
- B. Clean exposed surfaces and restore finish.

**END OF DOCUMENT**



**DOCUMENT 26 05 53**

**IDENTIFICATION FOR ELECTRICAL SYSTEMS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Nameplates and Labels
  - 2. Equipment Nameplates
  - 3. Device Labels

**1.02 RELATED SECTIONS**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents.
- B. In addition, meet the following:
  - 1. Manufacturer's Qualifications: Firms regularly engaged in manufacture of identification devices of types and sizes required.
  - 2. Codes and Standards: Comply with ANSI A13.1 for lettering size, length of color field, colors, and viewing angles of identification devices unless otherwise indicated.

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. General: Manufacturer's standard products of categories and types required for each application as referenced in other Division 26, Electrical Sections. Where more than a single type is specified for application, provide single selection for each product category.
- B. Equipment Nameplates:
  - 1. B & I Nameplates
  - 2. Intellicum
  - 3. JBR Associates
  - 4. Or approved equivalent.
- C. Device Labels:
  - 1. Kroy

2. Brady
3. Or approved equivalent.

## **2.02 NAMEPLATES AND LABELS**

- A. Nameplates: Engraving stock melamine or lamicoid plastic laminate in the size and thicknesses indicated, engraved with engraver's standard letter style of the sizes and wording indicated, black with white core (letter color), punched for mechanical fastening except where adhesive mounting is necessary because of substrate. Provide 1/8-inch thick material.
  1. Letter Color: White.
  2. Letter Height: 1/2 inch.
  3. Background Color: Black.
  4. Fasteners: Self-tapping stainless steel screws, except contact-type permanent adhesive where screws cannot or should not penetrate the substrate.
  5. Access Panel Markers: Manufacturer's standard 1/16-inch thick engraved plastic laminate access panel markers, with abbreviations and numbers corresponding to concealed valve or devices/equipment. Include center hole to allow attachment.
  6. Locations:
    - a. Each electrical distribution and control equipment enclosure.
    - b. Communication cabinets.
    - c. Transformers.
    - d. Disconnect switches and starters.
- B. Labels: Adhesive tape, with 3/16-inch black letters on clear background. Use only for identification of individual wall switches and receptacles and control stations. Indicate device name, source panel, and source circuits. Panel and circuit designation written in permanent marker on the back of the plate and inside the back-box. Do not provide Dymo tape style labels.
- C. Device plates to have panel and circuit designation engraved in face, and highlighted in a contrasting color, and the circuit written in permanent marker on the back of the plate and inside the back-box.

## **2.03 EQUIPMENT NAMEPLATES**

- A. Engraved phenolic plastic, 1/16-inch thick with beveled edge border matching letter color. All upper case letters in engraver standard letter style. Embossed tape or dymo style labels, or similar, are not acceptable.
- B. Color:
  1. Normal (Utility): White letters on black background.
  2. Life Safety/Critical (Emergency Systems): Black letters on orange background per WAC 296-46B-700.9.
  3. Equipment Branch (Legally Required Standby Systems): Black letters on yellow background.
  4. X-Ray Branch (Optional Standby Systems): Black letters on white background.
- C. Letter Size:

1. Use 1/2-inch letters minimum for identifying major equipment and loads, including switchgear, switchboards, etc.
  2. Use 1/4-inch letters minimum for identifying panels, breakers, etc.
  3. Use 3/16-inch minimum for identifying source, voltage, current, phase, and wire configurations.
- D. The Architect, Engineer, Commissioning Agent, and Owner reserve the right to make modifications to the nameplates as necessary.
- E. Nameplates: Engraving stock melamine or lamicoid plastic laminate, Federal Specification L-P-387, in the size and thicknesses indicated, engraved with engraver's standard letter style of the sizes and wording indicated, black with white core (letter color), punched for mechanical fastening except where adhesive mounting is necessary because of substrate. Provide 1/8-inch thick material.
1. Letter Color: White.
  2. Letter Height: 1/2-inch.
  3. Background Color: Black.
  4. Fasteners: Self-tapping stainless steel screws, except contact-type permanent adhesive where screws cannot or should not penetrate the substrate.

## **2.04 DEVICE LABELS**

- A. Extra strength, laminated, adhesive tape, with 3/16-inch black letters on clear background. Use only for identification of individual wall switches, receptacles, control device stations, etc. Indicate source panel and circuits. Wall switches with engraved buttons do not require labeling. Embossed tape style labels, or similar, are not acceptable.
- B. Label all junction boxes to show system identification, source circuit, or raceway origin. In finished areas, utilize device label. In unfinished areas or above ceilings, use of permanent ink marker is acceptable.
- C. Where labels are provided, write identical information in permanent ink marker on the backside of the cover.

## **PART 3 - EXECUTION**

### **3.01 PREPARATION**

- A. Degrease and clean surfaces to receive nameplates and labels.
- B. Coordinate designations used on Drawings with equipment labels.

### **3.02 INSTALLATION**

- A. Install nameplates and labels parallel to equipment lines.
- B. Secure nameplates to equipment front using rivets or adhesives.
- C. Secure nameplates to inside surface of door on panelboard that is recessed in finished locations.
- D. Identify underground raceways using underground warning tape. Install one continuous tape per underground raceway at 6- to 8-inches below finish grade. Where multiple underground raceways are buried in a common trench and exceeds 16-inch width,

- install multiple warning tapes not over 10-inches apart (edge to edge) over the entire group of underground raceways.
- E. Identify empty conduit and boxes with intended use.
  - F. Provide wire markers on each conductor for power, control, signaling and communications circuits.
  - G. On the back of receptacle and switch finish plates and inside the back-box, legibly write with permanent ink marker, the circuit that each device is connected to.
  - H. On the front of receptacle and switch finish plates, provide label with the circuit that each device is connected to.
  - I. Verify emergency system distribution equipment nameplate colors with Architect/Owner.
  - J. Locations:
    - 1. Switchgear, switchboards, sub-distribution switchboards, distribution panels, and branch panels.
    - 2. Main breakers and distribution breakers in switchgear, switchboards, and distribution panels.
    - 3. Equipment including, but not limited to, motor controllers, disconnects, and VFD's.
    - 4. Low-voltage equipment enclosures including, but not limited to, control panels.
  - K. Provide master nameplate at each incoming utility service to identify the following (each on a separate line):
    - 1. Serving Utility Transformer (ex. Utility Service #1.)
    - 2. Project
    - 3. Serving Utility Company
    - 4. Consulting Engineering Firm of Record
    - 5. Month and Year of Completion
    - 6. Voltage, Phase, and Wire Configuration.
  - L. Switchgear, switchboards, and panels to include name source, voltage, current phase, wire configuration and fault current rating. Transformers to include source KVA, and secondary voltage, phase, and wire configuration.
  - M. Provide nameplates for flush mounted branch panelboards identifying name on front door. On inside of door provide nameplate as noted above.
  - N. Provide a second label at branch panelboards listing the means of identification of branch circuit conductors. This identification legend to consist of the color code used for each voltage system (208Y/120V and 480Y/277V). See specification Section 26 05 19, Low-Voltage Electrical Power Conductors and Cables, for required conductor color code for this project. Include identification of both voltage systems on each label, regardless of the voltage of the panelboard to which the label is affixed. Comply with requirements of NEC 210.5.

- O. Provide engraved nameplate similar to distribution panelboards for transformers, lighting control panels, contactors, relays, time switches, etc. identifying name, service point and circuit number.
- P. For flush mounted panelboards verify label location (inside or outside panelboard door) with Architect/Owner.
- Q. Provide typewritten branch panel schedules with protective clear transparent covers accounting for every breaker installed. Use actual room designations assigned by name or number near completion of the work, and not the designations shown on drawings.
- R. Where changes are made in existing panels, distribution boards, etc., provide new labeling and typewritten schedules to accurately reflect the changes.
- S. Provide labeling where switches control remote lighting or power outlets or where multiple switches are located in the same location.
- T. Where switches control remote lighting or power outlets, or where switches or outlets in same location serve different purposes, such as light, power, intercom, etc. or different areas, such as corridor and outside, plates with 1/8-inch black letters indicating function of each switch or outlet. Also label function light switches where two or more are mounted in same locations.
- U. Provide receptacle device plates with panel and circuit designation labeled on the face, with Dymo-type label, and with circuit written in permanent marker on back of plate and back-box. Provide switch device plates with panel and circuit designation written in permanent marker on back of plate and back-box.

**END OF DOCUMENT**

**DOCUMENT 26 27 26**  
**WIRING DEVICES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included: Provision of materials, installation and testing of:
  - 1. Wall Switches
  - 2. Receptacles
  - 3. Finish Plates
  - 4. Surface Covers

**1.02 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.
- B. In addition, provide:
  - 1. Wall switches and Dimmers
  - 2. Receptacles
  - 3. Wall Plates
  - 4. In-Use Cover

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Wall Switches:
  - 1. Toggle Type Characteristics:
    - a. Leviton 1221
    - b. Pass & Seymour PS20AC1
    - c. Hubbell HBL 1221
    - d. Or approved equivalent.
  - 2. Decorative AC Rocker Switch Characteristics:
    - a. Hubbell
    - b. Leviton
    - c. Pass and Seymour

3. Timer Switches:
    - a. WattStopper TS-400
    - b. Or approved equivalent.
  4. Momentary Center Off:
    - a. Leviton 1257
    - b. Or approved equivalent.
  5. Pilot Light Switches:
    - a. Leviton 1221-PL
    - b. Pass & Seymour PS20AC1CPL
    - c. Hubbell HBL 1221-PL
    - d. Or approved equivalent.
  6. Lighted Handle Switches:
    - a. Hubbell
    - b. Leviton
    - c. Cooper
    - d. Pass & Seymour
    - e. Or approved equivalent.
  7. Key Switches:
    - a. Pass & Seymour PS20AC1-L
    - b. Hubbell HBL 1221-L
    - c. Leviton 1221-2L
    - d. Or approved equivalent.
- B. Receptacles:
1. Industrial Grade:
    - a. Cooper 5362
    - b. Hubbell HBL5362
    - c. Bryant FRY5362
    - d. Leviton 5362
    - e. Pass & Seymour 5362A
    - f. Or approved equivalent.
  2. Commercial Grade - 20 Amp:
    - a. Cooper 5362
    - b. Hubbell 5362
    - c. Bryant 5352
    - d. Leviton 5362S
    - e. Pass & Seymour 5362
    - f. Or approved equivalent.
  3. Commercial Grade - 15 Amp:
    - a. Cooper 5262
    - b. Hubbell 5262
    - c. Bryant 5252
    - d. Leviton 525
    - e. Pass & Seymour 5362

- f. Or approved equivalent.
- 4. Light Duty Commercial Grade:
  - a. 20 Amp:
    - 1) Hubbell BR20
    - 2) Bryant BRS20
    - 3) Or approved Equivalent.
  - b. 15 Amp:
    - 1) Hubbell BR15
    - 2) Bryant BRS15
    - 3) Or approved equivalent.
  - c. Decorative Type - 20 Amp:
    - 1) Cooper 6362
    - 2) Hubbell DR20
    - 3) Leviton 16342
    - 4) Pass & Seymour 26852
    - 5) Or approved equivalent.
- 5. Specification Grade USB Charger Tamper-Resistant Duplex - 20 Amp:
  - a. Cooper TR 7746
  - b. Hubbell USB2OX2
  - c. Leviton T5832-T
  - d. Or approved equivalent.
- 6. Hospital Grade:
  - a. Cooper 8300
  - b. Hubbell HBL 8300
  - c. Bryant BR Y8300
  - d. Leviton 8300
  - e. Pass & Seymour 8300
  - f. Or approved equivalent.
- 7. Hospital Grade USB Charger Tamper-Resistant Duplex - 20 Amp:
  - a. Cooper TR8345
  - b. Hubbell USB 8300
  - c. Leviton T5632-HG
  - d. Or approved equivalent.
- 8. Isolated Ground Receptacle:
  - a. Hubbell CR53621G
  - b. Cooper IG5362
  - c. Leviton 5362-IG
  - d. Pass & Seymour IG5362
  - e. Or approved equivalent.
- 9. Ground Fault Circuit Interrupter (GFCI) Receptacle:
  - a. Hubbell GFR5362SB
  - b. Cooper WRVGF20
  - c. Pass & Seymour 2095TRWR
  - d. Or approved equivalent.



10. Hospital Grade Ground Fault Circuit Interrupter (GFCI) Receptacle:
  - a. Hubbell GFR8300SB
  - b. Leviton T7899-HG
  - c. Pass & Seymour 2095-HG
  - d. Or approved equivalent.
11. Hospital Grade Tamper-Resistant Receptacle:
  - a. Cooper TR8300
  - b. Hubbell HBL8300SGA
  - c. Leviton 8300-SG
  - d. Pass & Seymour 2095HGTR
  - e. Or approved equivalent.
12. Residential Grade Receptacles:
  - a. Tamper Resistant, 15 amp:
    - 1) Cooper TR270
    - 2) Hubbell RR15STR
    - 3) Bryant RR15STR
    - 4) Leviton T5320
    - 5) Pass & Seymour 3232-TR
    - 6) Or approved equivalent.
  - b. Tamper Resistant Decora Style:
    - 1) Cooper TR1107
    - 2) Hubbell RRD15STR
    - 3) Bryant RRD15STR
    - 4) Leviton T5325
    - 5) Pass & Seymour 885-TR
    - 6) Or approved equivalent.
  - c. Tamper Resistant with USB Port(s), 15 amp:
    - 1) Pass & Seymour TM8USB
    - 2) Leviton T5630
    - 3) Hubbell USB15X
    - 4) Cooper TR7746
    - 5) Or approved equivalent.
  - d. GFCI, 20 amp:
    - 1) Cooper TWRVGF20
    - 2) Hubbell GFTR20
    - 3) Pass & Seymour 2095TRWR
    - 4) Or approved equivalent.
  - e. AFCI, Tamper Resistant, 15 amp:
    - 1) Hubbell AFR15R
    - 2) Leviton AFTR-K
    - 3) or approved equivalent.
13. While-in-Use Weatherproof Cover:
  - a. UV Stabilized Polycarbonate Cover:
    - 1) Pass & Seymour

- 2) Intermatic
    - 3) Hubbell
    - 4) Cooper
    - 5) Or approved equivalent.
  - b. Thermoplastic Cover:
    - 1) Leviton
    - 2) Hubbell
    - 3) Or approved equivalent.
  - c. Die Cast Cover:
    - 1) Intermatic
    - 2) Hubbell
    - 3) Cooper
    - 4) Or approved equivalent.
- 14. Hospital Grade Surge Protector Type Receptacles:
  - a. Cooper 8200S Series
  - b. Hubbell HBL8262
  - c. Pass & Seymour 8300 Series
  - d. Or approved equivalent.
- C. Surface Covers:
  - 1. Aluminum with Gasket, Blanks, Single Gang:
    - a. Bell 240-ALF
    - b. Carlon
    - c. Or approved equivalent.
  - 2. 2-Gang:
    - a. Bell 236-ALF
    - b. Carlon
    - c. Or approved equivalent.
- D. Provide lighting switches and receptacles of common manufacturer and appearance.

## **2.02 WALL SWITCHES**

- A. Characteristics: Toggle type, quiet acting, 20 amp, 120/277 volt, UL listed for motor loads up to 80 percent of rated amperage, extra heavy duty.
- B. Finish: White.

## **2.03 RECEPTACLES**

- A. Duplex Receptacles Characteristics: Straight parallel blade, 125 volt, 2 pole, 3 wire grounding.
  - 1. Commercial Grade: Riveted. Back and side wired. Brass ground contact on steel strap. Nylon face and nylon base. 20 amp.
- B. Ground Fault Circuit Interrupter (GFCI) Receptacle: Feed through type, back-and-side wired, tamper-resistant, weather resistant self-testing, 20 amp, 125VAC.
- C. While-in-Use Weatherproof Cover: NEMA 3R when closed over energized plug. Vertical mount for duplex receptacle. Provide continuous use cover with cover capable of closing over energized cord cap with bottom aperture for cord exit.

1. Die cast cover with closed cell neoprene foam gasket: Capable of being locked closed to prevent tampering or unauthorized use.
- D. Special Purpose Receptacles: Reference Drawings for NEMA Standard Specification.
- E. Finish:
  1. Same exposed finish as switches.

#### **2.04 FINISH PLATES**

- A. Finish Plates: Type 302 stainless steel. Smooth satin finish.

#### **2.05 SURFACE COVERS**

- A. Material: Galvanized steel, 1/2-inch raised industrial type with openings appropriate for devices installed on surface outlets.
- B. Cast Box and Extension Adaptors: Aluminum with gasket, blanks single gang.

### **PART 3 - EXECUTION**

#### **3.01 PREPARATION**

- A. Protection:
  1. Devices: Upon installation of finish plates and receptacles, adhere to proper and cautious use of convenience outlets. At time of substantial completion, replace those items which have been damaged, including those burned and scored by faulty receptacles or cord caps.
  2. Finish Plates and Devices: Do not install items until finish painting is complete. Scratched or splattered finish plates and devices not acceptable.

#### **3.02 INSTALLATION**

- A. See Architectural elevations for location and mounting height of wiring devices. Review Architectural elevations prior to rough-in and contact Design Builder immediately if conflicts are found between Architectural and Electrical Drawings. Do not rough-in devices until conflicts are resolved.
- B. Install wiring devices and finish plates plumb with building lines, equipment cabinets and adjacent devices. Devices not plumb will be fixed at no additional cost to Owner.
- C. Orientation:
  1. Wall-Mounted Receptacles: Install with long dimension oriented vertically at centerline height shown on drawings or as specified.
  2. Vertical Alignment: When more than one outlet is shown on drawings in close proximity to each other, but at different elevations, align outlets on a common vertical center line for best appearance. Verify with Design Builder.
  3. Horizontal Alignment: When more than one outlet is shown on Drawings to be stacked in wall vertically, align outlets on a common horizontal center line for best appearance. Verify with Design Builder.
- D. GFCI Outlets: One GFCI receptacle may not be used to provide GFCI protection to downstream duplex receptacles on the same branch circuit.

**3.03 LABELING**

- A. Provide receptacle device plates with panel and circuit designation labeled on the face, with Dymo-type label, and with circuit written in permanent marker on back of plate and back-box. Provide switch device plates with panel and circuit designation written in permanent marker on back of plate and back-box.

**3.04 TESTING**

- A. Submit report of compliance and results of receptacle and equipment tests:
- B. Test wiring devices to ensure electrical continuity of grounding connections, and after energizing circuitry, to demonstrate compliance with requirements. Test receptacles for line to neutral, line to ground and neutral to ground faults. Correct any defective wiring.

**END OF DOCUMENT**

**DOCUMENT 26 28 00**  
**OVERCURRENT PROTECTIVE DEVICES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Molded Case Circuit Breakers

**1.02 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.
- B. In addition, provide:
  - 1. Product data and instantaneous let-through current curves and average melting time current curves for fuses supplied to project.
  - 2. Product data and time/current trip curves for circuit breakers supplied to project.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Circuit Breakers:
  - 1. Eaton Electrical
  - 2. General Electric
  - 3. Square D
  - 4. Or approved equivalent.

**2.02 MOLDED CASE CIRCUIT BREAKERS**

- A. 1-, 2- or 3-pole bolt-on, single handle common trip, 600VAC or 250VAC as indicated on Drawings.
- B. Overcenter toggle-type mechanism, quick-make, quick-break action. Trip indication is by handle position.
- C. Calibrate for operation in 40 degrees C ambient temperature.

- D. 15 to 150 Amp Breakers: Permanent trip unit containing individual thermal and magnetic trip elements in each pole.
- E. 151 to 400 Amp Breakers: Adjustable magnetic trip elements. Provide push-to-trip button on cover of breaker for mechanical tripping.
- F. Greater than 401 Amp: Electronic trip type with adjustments for long-time, instantaneous, and short-time functions.
- G. Provide ground fault function for breakers greater than 800 amps where applied at 480 volts line-to-line; and where indicated on drawings.
- H. Combination AFCI Breaker: UL 1699 compliant. Integral 30mA GFCI trip. Manual test button for AFCI mechanism.

## **PART 3 - EXECUTION**

### **3.01 COORDINATION**

- A. Obtain and review the submitted product data for equipment furnished by the Owner, and furnished under other Divisions of this contract, particularly under Divisions 22 and 23.
- B. Confirm the equipment nameplate maximum overcurrent protection (MOCP) and make accommodations and adjustments to overcurrent protective devices as necessary to coordinate with the nameplate rating.

### **3.02 INSTALLATION**

- A. Provide testing of ground fault interrupting breakers.
- B. Circuit Breakers:
  - 1. Provide circuit breakers, as specified and on Drawings, for installation in panelboards, individual enclosures or combination motor starters.
  - 2. Provide ground fault interrupter circuit breakers for equipment in damp or wet locations.
  - 3. Provide device on handle to lock breaker in "ON" position for breakers feeding time switches, night lights and similar circuits required to be continuously energized.
  - 4. Shunt Trip Circuit Breakers: Provide wiring to remote trip switch/contacts as indicated on Drawings.
  - 5. Provide multi-pole branch circuit breakers for multi-wire branch circuits for simultaneous disconnection of circuits.

**END OF DOCUMENT**

**DOCUMENT 26 28 16**

**ENCLOSED SWITCHES AND CIRCUIT BREAKERS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Toggle Type Disconnect Switches
  - 2. Manual Motor Starters
  - 3. Safety Switches

**1.02 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Toggle Type Disconnect Switches:
  - 1. Cooper
  - 2. Hubbell
  - 3. Leviton
  - 4. Pass & Seymour
  - 5. Slater
  - 6. Or approved equivalent.
- B. Manual Motor Starters:
  - 1. Eaton Electrical
  - 2. General Electric
  - 3. Square D
  - 4. Or approved equivalent.
- C. Safety Switches:
  - 1. Eaton Electrical
  - 2. GE Industrial

3. Square D
4. Or approved equivalent.

## **2.02 TOGGLE TYPE DISCONNECT SWITCHES**

- A. Rating: 120 volt, 1 or 2 pole, 20 amp, 1 hp maximum.
- B. Enclosure:
  1. NEMA 1: Dry locations/Indoors.
  2. NEMA 3R: Damp or wet locations/Outdoors.
- C. Handle lockable in 'off' position.

## **2.03 MANUAL MOTOR STARTERS**

- A. Quick-Make, Quick-Break. Thermal overload protection. Device labeled with maximum voltage, current, and horsepower.
- B. Enclosure:
  1. NEMA 1: Dry locations/Indoors.
  2. NEMA 3R: Damp or wet locations/Outdoors.

## **2.04 SAFETY SWITCHES**

- A. Heavy duty fusible type and non-fusible type (as indicated on drawings), dual rated, quick-make, quick-break with fuse rejection feature for use with Class R fuses only, unless other fuse type is specifically noted.
- B. Clearly marked for maximum voltage, current, and horsepower.
- C. Operable handle interlocked to prevent opening front cover with switch in 'on' position.
- D. Switches rated for maximum available fault current.
- E. Handle lockable in 'off' position.
- F. Enclosure:
  1. NEMA 1: Dry locations/Indoors.
  2. NEMA 3R: Damp or wet locations/Outdoors.

## **PART 3 - EXECUTION**

### **3.01 COORDINATION**

- A. Obtain and review the submitted product data for equipment furnished by the Owner, and furnished under other Divisions of this contract, particularly under Divisions 22 and 23.
- B. Confirm the equipment nameplate maximum overcurrent protection (MOCP) and make accommodations and adjustments to switches, fuses and circuit breakers as necessary to coordinate with the nameplate rating

### **3.02 INSTALLATION**

- A. Provide disconnecting means within sight of each motor controller and of each motor. Motor controller disconnecting means equipped with lock-out/tag-out padlock provisions do not require a disconnect switch at the controlled motor location. Locate disconnect means in view of and not inside of equipment, such that tools are not needed to remove covers to access the disconnecting means.
- B. Install in accordance with manufacturer's instructions.



- C. Install fuses in fusible disconnect switches. Coordinate fuse ampere rating with installed equipment. Do not provide fuses of lower ampere rating than motor starter thermal units.
- D. Apply neatly typed adhesive tag on inside door of each fusible switch indicating NEMA fuse class and size installed.

**END OF DOCUMENT**

**DOCUMENT 26 29 13**  
**ENCLOSED CONTROLLERS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Work Included:
  - 1. Manual Motor Controllers

**1.02 RELATED DOCUMENTS AND PROVISIONS:**

All Contract Documents must be reviewed for applicable provisions related to the provisions in this document.

**1.03 REFERENCES AND STANDARDS**

- A. References and Standards as required by contract documents.

**1.04 SUBMITTALS**

- A. Submittals as required by contract documents.

**1.05 QUALITY ASSURANCE**

- A. Quality assurance as required by contract documents

**1.06 WARRANTY**

- A. Warranty of materials and workmanship as required by contract documents

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Eaton Electrical
- B. General Electric
- C. Square D
- D. Or approved equivalent.

**2.02 MANUAL MOTOR CONTROLLERS**

- A. Quick-make, Quick-break.
- B. Thermal overload protection.
- C. Clearly label device for maximum voltage, current, and horsepower.
- D. Handle lockable in 'off' position.
- E. Enclosure: NEMA 1 in dry locations. NEMA 3R in damp or wet locations.
- F. BACnet communication interface.

**PART 3 - EXECUTION**

**3.01 INSTALLATION**

- A. Install enclosed controllers where indicated, in accordance with manufacturer's instructions.
- B. Install securely, in a neat and workmanlike manner.
- C. Height: 5-feet to operating handle.
- D. Provide fuses for fusible switches; Reference Section 26 28 00 for product requirements.
- E. Select and install overload heater elements in motor controllers to match installed motor characteristics.
- F. Provide engraved plastic nameplates.
- G. Neatly type label inside each motor controller door identifying motor served, nameplate horsepower, full load amperes, code letter, service factor, and voltage/phase rating. Place label in clear plastic holder.

**3.02 FIELD QUALITY CONTROL**

- A. Perform inspections and tests in accordance with manufacturer's recommendations.

**END OF DOCUMENT**